

**Woodard, Marina (UTC)**

---

**From:** Imad, Antoinette M -Toni <antoinette.imad@pse.com>  
**Sent:** Monday, November 19, 2012 8:57 AM  
**To:** Lykken, David (UTC)  
**Cc:** Woodard, Marina (UTC); McGrath, Cheryl; Subsits, Joe (UTC); Gas Compliance -- mail --  
**Subject:** Update- RE: PSE Response | 2012 Natural Gas Standard Inspection Kittitas County

Dear Mr. Lykken,

In its response to the 2012 Kittitas County Inspection letter, PSE expressed its intent to evaluate the use of yellow plastic tags and paint pen to document pressure settings in the field. PSE has reviewed the use of the tags and has determined that changing the type of marker to a paint pen will prevent the markings from fading and still provide the operator with the information. The process for using yellow tags will remain in effect with the above mentioned change. As indicated in the previous response, should the information on the tag become illegible for other reasons, the proper stations pressures are still available to the field technician through SAP or by contacting Gas Operations support staff or Gas Control.

Please do not hesitate to contact me if any questions,

Best Regards,

Toni Imad

RECEIVED  
NOV 19 2012  
State of Washington  
UTC  
Pipeline Safety Program

---

**From:** Imad, Antoinette M -Toni  
**Sent:** Friday, October 05, 2012 2:33 PM  
**To:** 'Lykken, David (UTC)'  
**Cc:** 'Woodard, Marina (UTC)'; McGrath, Cheryl; 'jsubsits@utc.wa.gov'; Gas Compliance -- mail --  
**Subject:** PSE Response | 2012 Natural Gas Standard Inspection Kittitas County

Dear Mr. Lykken,

Pursuant to your request, PSE is hereby submitting a response to address findings noted in the 2012 Kittitas County inspection report dated September 6, 2012.

Best Regards,

Toni Imad

**Antoinette Imad, P.E.**  
*Consulting Engineer, Compliance*  
PUGET SOUND ENERGY  
425-456-2970 tel  
425-213-6219 cell  
355 110th Ave NE EST-07W  
Bellevue, WA 98004  
[www.PSE.com](http://www.PSE.com)