

Inspection Output (IOR)

Generated on 2021. September.29 07:25

Inspection Information

| | | | | | |
|-----------------|---|--------------|---|----------------------|---------------------------------|
| Inspection Name | 8252 CNGC Bremerton Standard Comprehensive | Operator(s) | CASCADE NATURAL GAS CORP (2128) Lead Scott Rukke | Plan Submitted | 12/23/2020 |
| Status | PLANNED | Team Members | David Cullom, Dennis Ritter, Lex Vinsel, Anthony Dorrough, Derek Norwood, Scott Anderson, Darren Tinnerstet | Plan Approval | 04/12/2021 by Joe Subsits |
| Start Year | 2021 | Observer(s) | Deborah Becker, Rell Koizumi | All Activity Start | 07/19/2021 |
| System Type | GD | Supervisor | Joe Subsits | All Activity End | 07/23/2021 |
| Protocol Set ID | WA.GD.2020.02 | Director | Sean Mayo | Inspection Submitted | -- |
| | | | | Inspection Approval | -- |

Inspection Summary

Inspection Scope and Summary

This is a Unit inspection for the Bremerton District #8252

Added OQ Form 15 on 4/7/2021

Facilities visited and Total AFOD

3/24-3/26/2021 - field pre-inspection. 3 AFOD days.

9/16/2021 - reviewed records electronically that would normally have been reviewed in office. 1 AFOD day

9/17/2021 - reviewed records electronically that would normally have been reviewed in office. 1 AFOD day

9/20 to 9/23/2021 - in CNG's Bremerton office for records and field. 4 AFOD days

Exit interview conducted on 8/22/2021

Summary of Significant Findings

No issues noted.

Primary Operator contacts and/or participants

Colby L. Lundstrom

Manager, Compliance and Operations Programs

Cascade Natural Gas Corp. | Intermountain Gas Co.

Office: 509-734-4587

Cell: 509-520-0718

Scope (Assets)

| # | Short Label | Long Label | Asset Type | Asset IDs | Excluded Topics | Planned | Required | Inspected | Total | Required % Complete |
|----|--------------|-------------------------------|------------|-----------|---|---------|----------|-----------|-------|---------------------|
| 1. | 90877 (1919) | Cascade Natural Gas-BREMERTON | unit | 90877 | Abandoned Copper Pipe Cast or Ductile Iron Aluminum/Amphoteric GOM OCS Offshore Bottle/Pipe - Holders Storage Fields Vault | 142 | 142 | 142 | 142 | 100.0% |

1. Percent completion excludes unanswered questions planned as "always observe".

Plans

| # | Plan Assets | Focus Directives | Involved Groups/Subgroups | Qst Type(s) | Extent Notes |
|----|--------------|---|--|-------------|--------------|
| 1. | 90877 (1919) | Baseline Records (Form 2), Baseline Pipeline Field Inspection (Form 2), OQ Field Inspection (Form 15) | PRO, PRR, FR, GDIM, MMLPGIM, MISCTOPICS, GENERIC | P, R, O, S | Detail |

Plan Implementations

| # | Activity Name | SMAR T Act# | Start Date | End Date | Focus Directives | Involved Groups/Subgroups | Asset Types | Qst Type(s) | Planned | Required | Inspected | Total | Required % Complete |
|---|----------------------------|-------------|------------|------------|------------------|---------------------------|-------------|-------------|---------|----------|-----------|-------|---------------------|
| 1 | Records and field insp. p. | -- | 07/19/2021 | 07/23/2021 | n/a | all planned questions | all assets | all types | 142 | 142 | 142 | 142 | 100.0% |

1. Since questions may be implemented in multiple activities, but answered only once, questions may be represented more than once in this table.

2. Percent completion excludes unanswered questions planned as "always observe".

Forms

| No. | Entity | Form Name | Status | Date Completed | Activity Name | Asset |
|-----|-----------------|-------------------------|-----------|----------------|-------------------------|--------------|
| 1. | Attendance List | Records and field insp. | COMPLETED | 09/23/2021 | Records and field insp. | 90877 (1919) |

Results (all values, 142 results)

147 (instead of 142) results are listed due to re-presentation of questions in more than one sub-group.

PRR.REPORT: Reporting

1. Question Result, ID, References **NA, RPT.RR.IMMEDREPORT.R, 191.5(a) (191.7(a), 191.7(d))**
 Question Text *Do records indicate immediate notifications of incidents were made in accordance with 191.5?*
 Assets Covered **90877 (1919)**
 Result Notes **No such event occurred, or condition existed, in the scope of inspection review.**

2. Question Result, ID, References **NA, RPT.RR.INCIDENTREPORT.R, 191.9(a)**
 Question Text *Do records indicate reportable incidents were identified and reports were submitted to DOT on Form 7100.1 within the required time frame?*
 Assets Covered **90877 (1919)**
 Result Notes **No such event occurred, or condition existed, in the scope of inspection review.**

3. Question Result, ID, References **NA, RPT.RR.INCIDENTREPORTSUPP.R, 191.9(b)**
 Question Text *Do records indicate accurate supplemental incident reports were filed and within the required timeframe?*
 Assets Covered **90877 (1919)**
 Result Notes **No such event occurred, or condition existed, in the scope of inspection review.**

4. Question Result, ID, References **NC, RPT.RR.ANNUALREPORT.R, 191.11(a)**
 Question Text *Have complete and accurate Annual Reports been submitted?*
 Assets Covered **90877 (1919)**
 Result Notes **The annual reports will be reviewed during the annual review.**

5. Question Result, ID, References **NC, RPT.RR.UTCANNUALREPORTS.R,**
 Question Text *Have complete and accurate annual reports been submitted to the commission?*
 Assets Covered **90877 (1919)**
 Result Notes **The annual reports will be reviewed during the annual review.**

6. Question Result, ID, References **Sat, RPT.RR.MISDATAREPORTS.R,**
 Question Text *Has the operator submitted a copy of DOT Drug and Alcohol Testing MIS Data Collection Form to the commission when required?*
 Assets Covered **90877 (1919)**
 Result Notes **Submitted 3/14/2021.**

7. Question Result, ID, References **NC, GDIM.RR.MECHANICALFITTINGDATAIMPL.R, 192.1009 (191.12)** (also presented in: GDIM.IMPL)
 Question Text *Have accurate records been maintained documenting mechanical fitting failures that resulted in hazardous leaks?*
 Assets Covered **90877 (1919)**
 Result Notes **These reports will be reviewed during the annual review.**

8. Question Result, ID, References **NA, RPT.RR.SRCR.R, 191.23(a) (191.23(b), 191.25(a), 191.25(c))**
 Question Text *Do records indicate safety-related condition reports were filed as required?*
 Assets Covered **90877 (1919)**
 Result Notes **No such event occurred, or condition existed, in the scope of inspection review.**

9. Question Result, ID, References **NA, RPT.RR.MAOPINCREASENOTIFY.R,**
 Question Text *Do records indicate submittal of a written plan of procedures to the commission at least forty-five days before uprating to a MAOP greater than 60 psig?*
 Assets Covered **90877 (1919)**
 Result Notes **No such event occurred, or condition existed, in the scope of inspection review.**

10. Question Result, ID, References **Sat, RPT.RR.THIRTYDAYRPT.R,**
 Question Text *Has the operator submitted a written report within 30 days following each reportable incident?*
 Assets Covered **90877 (1919)**
11. Question Result, ID, References **Sat, MO.GO.CUSTNOTIFY.R, 192.16(d) (192.16(a), 192.16(b), 192.16(c))**
 Question Text *Do records indicate the customer notification process satisfies the requirements of 192.16?*
 Assets Covered **90877 (1919)**
 Result Notes **New customer 90 days after first receives gas. Existing customers semi-annually.**
12. Question Result, ID, References **Sat, RPT.RR.DAILYCONSTRUCTIONRPT.R,**
 Question Text *Do records indicate daily construction and repair activities were emailed to the commission no later than 10 AM each day work is scheduled?*
 Assets Covered **90877 (1919)**
13. Question Result, ID, References **Sat, RPT.RR.PIPELINEMAPPING.R,**
 Question Text *Has the operator provided accurate maps (or updates) of all pipelines operating over 250 psig to specifications developed by the commission sufficient to meet the needs of first responders?*
 Assets Covered **90877 (1919)**
 Result Notes **Maps were submitted and will be submitted as requested by the Commission.**

PRR.CORROSION: Corrosion Control

14. Question Result, ID, References **Sat, TQ.QU.CORROSION.R, 192.453 (192.807(a), 192.807(b))**
 Question Text *Do records indicate qualification of personnel implementing pipeline corrosion control methods?*
 Assets Covered **90877 (1919)**
 Result Notes **Dustin Knowles is a CP 3 and he handles CNG and Intermountain.**

Senior corrosion technologist.
15. Question Result, ID, References **Sat, TD.CP.RECORDS.R, 192.491(a)**
 Question Text *Do records indicate the location of all items listed in 192.491(a)?*
 Assets Covered **90877 (1919)**
 Result Notes **Shown on as-builts including anodes in galvanic systems.**
16. Question Result, ID, References **Sat, TD.CP.MONITOR.CURRENTTEST.R, 192.491(c) (192.465(b))**
 Question Text *Do records document details of electrical checks of sources of rectifiers or other impressed current sources?*
 Assets Covered **90877 (1919)**
 Result Notes **Reviewed 100% of records for 2018 to 2021.**
17. Question Result, ID, References **Sat, TD.CP.EXPOSED.EXPOSEINSPECT.R, 192.491(c) (192.459)**
 Question Text *Do records adequately document that exposed buried piping was examined for corrosion?*
 Assets Covered **90877 (1919)**
 Result Notes **Documented on the 625 form. Reviewed a sampling of these forms for compliance for 2018, 2019 and 2020.**
18. Question Result, ID, References **Sat, TD.CP.MONITOR.TEST.R, 192.491(c) (192.465(a))**
 Question Text *Do records adequately document cathodic protection monitoring tests have occurred as required?*
 Assets Covered **90877 (1919)**
 Result Notes **Reviewed annual CP records for 2018, 2019 and 2020.**

19. Question Result, ID, References **Sat, TD.CP.MONITOR.REVCURRENTTEST.R, 192.491(c) (192.465(c))**
 Question Text *Do records document details of electrical checks interference bonds, diodes, and reverse current switches?*
 Assets Covered **90877 (1919)**
20. Question Result, ID, References **Sat, TD.CP.MONITOR.DEFICIENCY.R, 192.491(c) (192.465(d))**
 Question Text *Do records adequately document actions taken to correct any identified deficiencies in corrosion control?*
 Assets Covered **90877 (1919)**
21. Question Result, ID, References **NA, TD.CP.UNPROTECT.R, 192.491(c) (192.465(e))**
 Question Text *Do records adequately document that exposed buried piping was examined for corrosion and deteriorated coating?*
 Assets Covered **90877 (1919)**
 Result Notes **No such relevant facilities/equipment existed in the scope of inspection review. No unprotected pipelines.**
22. Question Result, ID, References **NA, FS.FG.CASINGTESTLEAD.R,**
 Question Text *Do records indicate that all casings without vents installed after September 5, 1992 had separate test lead wires installed?*
 Assets Covered **90877 (1919)**
 Result Notes **No such relevant facilities/equipment existed in the scope of inspection review. No casings installed after 1992 without vents.**
23. Question Result, ID, References **Sat, FS.FG.CASINGSEALS.R,**
 Question Text *Do records indicate that mains and service lines installed in casing or conduit are sealed at the ends as required?*
 Assets Covered **90877 (1919)**
24. Question Result, ID, References **Sat, TD.CP.ELECISOLATE.R, 192.491(c) (192.467(a), 192.467(b), 192.467(c), 192.467(d), 192.467(e))**
 Question Text *Do records adequately document electrical isolation of each buried or submerged pipeline from other metallic structures unless they electrically interconnect and cathodically protect the pipeline and the other structures as a single unit?*
 Assets Covered **90877 (1919)**
 Result Notes **Reviews of CP annuals were completed from 2018 to 2020 and all isolation points appeared to be adequate.**
25. Question Result, ID, References **Sat, TD.CP.CASINGINSPECT.R,**
 Question Text *Do records indicate that annual casing inspections have been performed to ensure electrical isolation from the pipeline?*
 Assets Covered **90877 (1919)**
 Result Notes **Reviewed casing records for 2018 to 2021.**
26. Question Result, ID, References **Sat, TD.CP.MONITOR.TESTSTATION.R, 192.469**
 Question Text *Do records identify the location of test stations and show a sufficient number of test stations?*
 Assets Covered **90877 (1919)**
27. Question Result, ID, References **Sat, TD.CP.MONITOR.TESTLEAD.R, 192.491(c) (192.471(a), 192.471(b), 192.471(c))**
 Question Text *Do records document that pipelines with cathodic protection have electrical test leads installed in accordance with requirements of Subpart I?*
 Assets Covered **90877 (1919)**
28. Question Result, ID, References **Sat, TD.CP.MONITOR.INTFRCURRENT.R, 192.491(c) (192.473(a))**

Question Text *Do records document an effective program is in place to minimize detrimental effects of interference currents and that detrimental effects of interference currents from CP systems on other underground metallic structures are minimized?*

Assets Covered 90877 (1919)

29. Question Result, ID, References NA, TD.ICP.CORRGAS.R, 192.491(c) (192.475(a))

Question Text *Do the records demonstrate that the corrosive effect of the gas in the pipeline has been investigated and if determined to be corrosive, steps be taken to minimize internal corrosion?*

Assets Covered 90877 (1919)

Result Notes No such event occurred, or condition existed, in the scope of inspection review. Corrosive gas is not transported by tariff and contract from the interstate supplier.

30. Question Result, ID, References Sat, TD.ICP.EXAMINE.R, 192.491(c) (192.475(a), 192.475(b))

Question Text *Do records document examination of removed pipe for evidence of internal corrosion?*

Assets Covered 90877 (1919)

Result Notes Reviewed a sampling of CNG 336 and CNG 315 forms that document internal corrosion. No issues.

31. Question Result, ID, References NA, TD.ICP.CORRGASACTION.R, 192.491(c) (192.477)

Question Text *Do records document the actions taken when corrosive gas is being transported by pipeline?*

Assets Covered 90877 (1919)

Result Notes No such event occurred, or condition existed, in the scope of inspection review. Corrosive gas is not transported by tariff and contract from the interstate supplier.

32. Question Result, ID, References Sat, TD.ATM.ATMCORRODEINSP.R, 192.491(c) (192.481(a), 192.481(b), 192.481(c))

Question Text *Do records document inspection of aboveground pipe for atmospheric corrosion?*

Assets Covered 90877 (1919)

33. Question Result, ID, References Sat, TD.COAT.NEWPIPE.R, 192.491(c) (192.455(a), 192.461(a), 192.461(b), 192.483(a))

Question Text *Do records document that each buried or submerged pipeline installed after July 31, 1971 has been externally coated with a suitable coating material?*

Assets Covered 90877 (1919)

Result Notes All pipe is coated per CNG specifications.

34. Question Result, ID, References NA, TD.ICP.REPAIR.R, 192.485(a) (192.485(b))

Question Text *Do records document the repair or replacement of pipe that has been internally corroded to an extent that there is not sufficient remaining strength in the pipe wall?*

Assets Covered 90877 (1919)

Result Notes No such relevant facilities/equipment existed in the scope of inspection review. THIS IS A TRANSMISSION QUESTION.

35. Question Result, ID, References NA, TD.ICP.EVALUATE.R, 192.491(c) (192.485(c))

Question Text *Do records document adequate evaluation of internally corroded pipe?*

Assets Covered 90877 (1919)

Result Notes No such relevant facilities/equipment existed in the scope of inspection review. THIS IS A TRANSMISSION QUESTION.

PRR.PT: Pressure Test

36. Question Result, ID, References Sat, DC.PTLOWPRESS.PRESSTESTLOWSTRESS.R, 192.517(a) (192.507(a), 192.507(b), 192.507(c))

Question Text *Do records indicate that pressure testing is conducted in accordance with 192.507?*

Assets Covered 90877 (1919)

Result Notes (Hoop stress less than 30 percent of SMYS and at or above 100 p.s.i.)

Reviewed a high pressure job package for WO# 278474 (Reg Station R0170) in Bremerton.

No issues.

37. Question Result, ID, References Sat, DC.PTLOWPRESS.PRESSTEST100PSIG.R, 192.517(b) (192.509(a), 192.509(b))
Question Text *Do records indicate that pressure testing is conducted in accordance with 192.509(a)?*
Assets Covered 90877 (1919)
Result Notes (Below 100 PSIG)

Reviewed a sampling of CNG forms 338 and 315 which documents pressure tests.

38. Question Result, ID, References Sat, DC.PT.SERVICELINE.R, 192.517(b) (192.511(a), 192.511(b), 192.511(c))
Question Text *Do records indicate that pressure testing is conducted in accordance with 192.511?*
Assets Covered 90877 (1919)
Result Notes (Service lines)

Reviewed a sampling fo form 315 for service line pressure tests.

39. Question Result, ID, References Sat, DC.PT.PRESSTESTPLASTIC.R, 192.517(b) (192.513(a), 192.513(b), 192.513(c), 192.513(d))
Question Text *Do records indicate that pressure testing is conducted in accordance with 192.513?*
Assets Covered 90877 (1919)
Result Notes (Plastic pipelines)

Reviewed a sampling of forms 315 and 336 for PE pressure tests.

PRR.UPRATE: Uprating

40. Question Result, ID, References NA, MO.GOUPRATE.MAOPINCREASE.R, 192.553(a) (192.553(b), 192.553(c))
Question Text *Do records indicate that increases in MAOP of pipeline were determined in accordance with 192.553?*
Assets Covered 90877 (1919)
Result Notes No such event occurred, or condition existed, in the scope of inspection review.
41. Question Result, ID, References NA, MO.GOUPRATE.MAOPINCREASELIMIT.R, 192.553(b) (192.553(c), 192.553(d), 192.557(a))
Question Text *Do records indicate that increases in MAOP are limited in accordance with 192.619 and 192.621?*
Assets Covered 90877 (1919)
Result Notes No such event occurred, or condition existed, in the scope of inspection review.
42. Question Result, ID, References NA, MO.GOUPRATE.MAOPINCREASEPREP.R, 192.553(b) (192.553(c), 192.553(a), 192.557(b), 192.557(c))
Question Text *Do records indicate that increases in MAOP were preceded by the actions specified in 192.557?*
Assets Covered 90877 (1919)
Result Notes No such event occurred, or condition existed, in the scope of inspection review.

PRR.OM: Operations And Maintenance

43. Question Result, ID, References Sat, MO.GO.OMANNUALREVIEW.R, 192.605(a)
Question Text *Have annual reviews of the written procedures or processes in the manual been conducted as required?*
Assets Covered 90877 (1919)
Result Notes CNG is currently undergoing a complete procedural review and modification process. MDU, their parent company is consolidating all of their subsidiary company procedures into one manual.

44. Question Result, ID, References **Sat, MO.GO.OMHISTORY.R, 192.605(a) (192.605(b)(3))**
 Question Text *Are construction records, maps and operating history available to appropriate operating personnel?*
 Assets Covered **90877 (1919)**
 Result Notes **All necessary employees carry laptops with a hyperlink to their GIS system.**
45. Question Result, ID, References **Sat, MO.GO.OMEFFECTREVIEW.R, 192.605(a) (192.605(b)(8))**
 Question Text *Do records indicate periodic review of the work done by operator personnel to determine the effectiveness, and adequacy of the processes used in normal operations and maintenance and modifying the processes when deficiencies are found?*
 Assets Covered **90877 (1919)**
 Result Notes **Reviewed a sampling of CNG 640 form "Construction Inspection Checklist" which is a comprehensive form used to evaluate CNG personnel and contractor construction jobs.**
46. Question Result, ID, References **NA, MO.GO.ABNORMAL.ABNORMALREVIEW.R, 192.605(a) (192.605(c)(4))**
 Question Text *Do records indicate periodic review of work done by operator personnel to determine the effectiveness of the abnormal operation processes and corrective action taken where deficiencies are found?*
 Assets Covered **90877 (1919)**
 Result Notes **No such requirement existed in the scope of inspection review. This is a transmission question.**
47. Question Result, ID, References **Sat, PD.OC.PDPROGRAM.R, 192.614(c)**
 Question Text *Does the damage prevention program meet minimum requirements specified in 192.614(c)?*
 Assets Covered **90877 (1919)**
 Result Notes **CNG meets the requirements. CNG uses PAPA for much of their contact to the public and contractors.**

Reviewed the excavator list.
48. Question Result, ID, References **NA, MO.GO.CLASS.CLASSLOCATESTUDY.R, 192.605(b)(1) (192.609(a), 192.609(b), 192.609(c), 192.609(d), 192.609(e), 192.609(f))**
 Question Text *Do records indicate performance of the required study whenever the population along a pipeline increased or there was an indication that the pipe hoop stress was not commensurate with the present class location?*
 Assets Covered **90877 (1919)**
 Result Notes **No such requirement existed in the scope of inspection review. Transmission question.**
49. Question Result, ID, References **Sat, EP.ERG.POSTEVTREVIEW.R, 192.605(a) (192.615(b)(1), 192.615(b)(3))**
 Question Text *Do records indicate review of employee activities to determine whether the procedures were effectively followed in each emergency?*
 Assets Covered **90877 (1919)**
 Result Notes **Documented on CNG 23001 form. Incident or Hazardous Condition Report.**

Reviewed a sampling of 23001 forms from 2018 to 2020.
50. Question Result, ID, References **Sat, EP.ERG.TRAINING.R, 192.605(a) (192.615(b)(2))**
 Question Text *Has the operator trained the appropriate operating personnel on emergency procedures and verified that the training was effective in accordance with its procedures?*
 Assets Covered **90877 (1919)**
 Result Notes **Employee training and mock drill records were reviewed. CNG form 522 documents Mock Emergency. Form 20231 documents training attendance. Form 20236 documents the Mock Exercise Evaluation Guide.**
51. Question Result, ID, References **Sat, EP.ERG.LIAISON.R, 192.605(a) (192.615(c)(1), 192.615(c)(2), 192.615(c)(3), 192.615(c)(4), 192.616(c), ADB-05-03) (also presented in: MISCTOPICS.PUBAWARE)**
 Question Text *Do records indicate liaisons established and maintained with appropriate fire, police and other public officials and utility owners in accordance with procedures?*
 Assets Covered **90877 (1919)**

- Result Notes Reviewed the spreadsheet of emergency responder contacts and the annual news information flyer mailed to them. CNG also does local contact with emergency responders..
52. Question Result, ID, [Sat, PD.PA.LANGUAGE.R, 192.616\(g\)](#) (API RP 1162 Section 2.3.1) (also presented in: References [MISCTOPICS.PUBAWARE](#))
 Question Text *Were materials and messages developed and delivered in other languages commonly understood by a significant number and concentration of non-English speaking populations in the operator's areas?*
 Assets Covered [90877 \(1919\)](#)
 Result Notes Yes. In addition CNG's website has multiple languages.
53. Question Result, ID, [Sat, PD.PA.EVALEFFECTIVENESS.R, 192.616\(c\)](#) (API RP 1162 Section 8.4) (also presented in: References [MISCTOPICS.PUBAWARE](#))
 Question Text *Have effectiveness evaluation(s) of the program been performed for all stakeholder groups in all notification areas along all systems covered by the program?*
 Assets Covered [90877 \(1919\)](#)
 Result Notes CNG contracted out their effectiveness review. The last one conducted was August 21, 2018.
54. Question Result, ID, [NA, PD.PA.MSTRMETER.R, 192.616\(j\)](#) (192.616(h), API RP 1162 Section 2.7 (Step 12), API RP 1162 Section 8.5) (also presented in: [MISCTOPICS.PUBAWARE](#))
 Question Text *Do records indicate the public awareness program for a master meter or petroleum gas system operator has met the requirements of Part 192?*
 Assets Covered [90877 \(1919\)](#)
 Result Notes No such relevant facilities/equipment existed in the scope of inspection review.
55. Question Result, ID, [NA, EP.ERG.INCIDENTANALYSIS.R, 192.605\(a\)](#) (192.617)
 References
 Question Text *Do records indicate actions initiated to analyze accidents and failures, including the collection of appropriate samples for laboratory examination to determine the causes of the failure and minimize the possibility of recurrence, in accordance with its procedures?*
 Assets Covered [90877 \(1919\)](#)
 Result Notes No such event occurred, or condition existed, in the scope of inspection review.

 No accidents since last inspection.
56. Question Result, ID, [Sat, MO.GOMAOP.MAOPDETERMINE.R, 192.619\(a\)](#) (192.619(b), 192.621(a), 192.621(b), 192.623(a), 192.623(b))
 References
 Question Text *Do records indicate determination of the MAOP of pipeline segments in accordance with 192.619 and limiting of the operating pressure as required?*
 Assets Covered [90877 \(1919\)](#)
57. Question Result, ID, [Sat, MO.GOODOR.ODORIZE.R, 192.709\(c\)](#) (192.625(a), 192.625(b), 192.625(c), 192.625(d), 192.625(e), 192.625(f))
 References
 Question Text *Do records indicate appropriate odorization of its combustible gases in accordance with its processes and conduct of the required testing to verify odorant levels met requirements?*
 Assets Covered [90877 \(1919\)](#)
 Result Notes 100% of sniff test records were reviewed for 2018 thru 2020.
58. Question Result, ID, [NA, MO.RW.TRANSPATROL.R, 192.709\(c\)](#) (192.705(a), 192.705(b), 192.705(c))
 References
 Question Text *Do records indicate that transmission line ROW surface conditions have been patrolled as required?*
 Assets Covered [90877 \(1919\)](#)
 Result Notes No such requirement existed in the scope of inspection review. Transmission question.
59. Question Result, ID, [NA, MO.RW.TRANSLEAKAGE.R, 192.709\(c\)](#) (192.706, 192.706(a), 192.706(b))
 References
 Question Text *Do records indicate transmission leakage surveys conducted as required?*
 Assets Covered [90877 \(1919\)](#)
 Result Notes No such requirement existed in the scope of inspection review. Transmission question.
60. Question Result, ID, [Sat, MO.RW.DISTPATROL.R, 192.603\(b\)](#) (192.721(a), 192.721(b))
 References
 Question Text *Do records indicate distribution patrolling was conducted as required?*

Assets Covered 90877 (1919)

Result Notes Reviewed 100% of patrols for 2018 to 2021. No issues.

We will follow up and inspect two of the patrols where exposed pipelines on a bridge and a wharf have follow-up work orders created.

61. Question Result, ID, References Sat, MO.RW.LEAKFOLLOW.R,

Question Text Do records indicate that a follow-up inspection was performed not more than thirty days following a repair where residual gas remained in the ground?

Assets Covered 90877 (1919)

62. Question Result, ID, References NA, MO.RW.DOWNGRADELEAKREPAIR.R,

Question Text Do records indicate that leaks that have been downgraded are repaired within twenty-one months?

Assets Covered 90877 (1919)

Result Notes No such event occurred, or condition existed, in the scope of inspection review.

63. Question Result, ID, References Sat, MO.RW.LEAKREPAIRTIME.R,

Question Text Do records indicate that leaks were repaired and re-evaluated in the timeframes specified in WAC 480-93-18601?

Assets Covered 90877 (1919)

64. Question Result, ID, References Sat, MO.RW.LEAKRECORDS.R,

Question Text Have gas leak records been prepared and maintained as required?

Assets Covered 90877 (1919)

65. Question Result, ID, References Sat, MO.RW.DISTPATROLLEAKAGE.R, 192.603(b) (192.723(a), 192.723(b))

Question Text Do records indicate distribution leakage surveys were conducted as required?

Assets Covered 90877 (1919)

Result Notes Reviewed a sampling of leak surveys conducted in the Bremerton District.

Keyport Section 1 Business District 2018 and 2019

Poulsbo Section 2 Residential 2013 and 2018

Chico Section 1 Business District 2018 and 2019

Poulsbo Section 1 Business District 2018 and 2019

Manchester Section 2 Residential 2013 and 2018

Port Orchard Section 3 Residential 2013 and 2018

66. Question Result, ID, References NA, MO.RW.CASINGLEAKSURVEY.R,

Question Text Do records indicate shorted casings were leak surveyed as required?

Assets Covered 90877 (1919)

Result Notes No such event occurred, or condition existed, in the scope of inspection review. No shorted casings were noted in the records from 2018 to 2021.

67. Question Result, ID, References Sat, MO.RW.MARKERSURVEY.R,

Question Text Do records indicate that pipeline marker surveys were completed in the timeframe specified by WAC 480-93-124?

Assets Covered 90877 (1919)

Result Notes Pipeline markers are completed during leak surveys and bridge and pipeline patrols. No issues.

68. Question Result, ID, References Sat, MO.RW.MARKERREPLACE.R,
Question Text *Do records indicate that damaged or missing markers were replaced within forty-five days of discovery?*
Assets Covered 90877 (1919)
69. Question Result, ID, References Sat, AR.RMP.TESTREINSTATE.R, 192.603(b) (192.725(a), 192.725(b))
Question Text *From the review of records, did the operator properly test disconnected service lines?*
Assets Covered 90877 (1919)
Result Notes A sampling of leak repair records was inspected from 2018 to 2021. All broken service lines were tested as required.
70. Question Result, ID, References Sat, MO.GMOPP.PRESSREGTEST.R, 192.709(c) (192.739(a), 192.739(b))
Question Text *Do records indicate inspection and testing of pressure limiting, relief devices, and pressure regulating stations?*
Assets Covered 90877 (1919)
Result Notes Reviewed 100% of regulator and relief maintenance records for 2018 to 2021.
71. Question Result, ID, References Sat, MO.GMOPP.PRESSREGCAP.R, 192.709(c) (192.743(a), 192.743(b), 192.743(c))
Question Text *Do records indicate testing or review of the capacity of each pressure relief device at each pressure limiting station and pressure regulating station as required?*
Assets Covered 90877 (1919)
Result Notes Reviewed annual station calculations for 2018 to 2021. No issues.
72. Question Result, ID, References Sat, DC.METERREGSVC.REGTEST.R,
Question Text *Do records indicate that service regulators have been installed, operated, maintained, tested during initial turn-on and tested when customers experience pressure problems?*
Assets Covered 90877 (1919)
Result Notes Reviewed a sampling of new meter turn on records which record the set point pressures and flow and lock-up.
73. Question Result, ID, References Sat, MO.GM.DISTVALVEINSPECT.R, 192.603(b) (192.747(a), 192.747(b))
Question Text *Do records indicate proper inspection of each distribution system valve that might be required in an emergency at intervals not exceeding 15 months, but at least once each calendar year, and prompt remedial action to correct any valve found inoperable?*
Assets Covered 90877 (1919)
Result Notes 100% of valve records were reviewed from 2018 to 2021.
74. Question Result, ID, References Sat, MO.GM.IGNITION.R, 192.709 (192.751(a), 192.751(b), 192.751(c))
Question Text *Do records indicate personnel followed processes for minimizing the danger of accidental ignition where the presence of gas constituted a hazard of fire or explosion?*
Assets Covered 90877 (1919)
Result Notes CP 760 and OPS 603. Policy 406.

Form 640 is a construction review form and indicates that fire extinguishers were in use on the job site.
75. Question Result, ID, References Sat, DC.DPC.FLANGE.R, 192.147(a) (192.147(b), 192.147(c))
Question Text *Do records indicate flanges and flange accessories meet the requirements of 192.147?*
Assets Covered 90877 (1919)
Result Notes Job packages and as-builts were reviewed and flanges were properly marked and appropriate for the MAOP of the system they were installed on.
76. Question Result, ID, References Sat, DC.WELDPROCEDURE.WELD.R, 192.225(a) (192.225(b))

Question Text *Do records indicate weld procedures are being qualified in accordance with 192.225?*

Assets Covered 90877 (1919)

Result Notes CP 760 welding procedures meets this requirement.

77. Question Result, ID, References Sat, DC.WELDPROCEDURE.ESSENTIAL.R,

Question Text *Do records indicate that essential variables were measured and documented when welders and procedures were qualified?*

Assets Covered 90877 (1919)

Result Notes Reviewed the Bremerton qualified welders records and essential variables were measured during the tests. Procedure qualification records were not reviewed.

78. Question Result, ID, References Sat, TQ.QUOMCONST.WELDER.R, 192.227(a) (192.227(b), 192.229(a), 192.229(b), 192.229(c), 192.229(d), 192.328(a), 192.328(b), 192.807(a), 192.807(b))

Question Text *Do records indicate adequate qualification of welders?*

Assets Covered 90877 (1919)

79. Question Result, ID, References Sat, TQ.QUOMCONST.NDT.R, 192.243(b)(2) (192.807(a), 192.807(b), 192.328(a), 192.328(b))

Question Text *Do records indicate the qualification of nondestructive testing personnel?*

Assets Covered 90877 (1919)

Result Notes Reviewed a large high pressure job package for R-170. All NDE personnel were contracted. All certifications reviewed were good.

80. Question Result, ID, References Sat, DC.CO.PLASTICJOINTPROCEDURE.R, 192.273(b) (192.283(a), 192.283(b), 192.283(c), 192.283(d))

Question Text *Have plastic pipe joining procedures been qualified in accordance with 192.283?*

Assets Covered 90877 (1919)

Result Notes TR-33 plastic pipe institute procedures are used by CNG.

81. Question Result, ID, References Sat, DC.CO.PLASTICJOINTQUAL.R, 192.285(d) (192.285(a), 192.285(b), 192.285(c), 192.807(a), 192.807(b))

Question Text *Do records indicate persons making joints in plastic pipelines are qualified in accordance with 192.285?*

Assets Covered 90877 (1919)

82. Question Result, ID, References Sat, DC.CO.PLASTICJOINTINSR.R, 192.287 (192.807(a), 192.807(b))

Question Text *Do records indicate persons inspecting the making of plastic pipe joints have been qualified?*

Assets Covered 90877 (1919)

Result Notes CNG's plastic joiners inspect their own joints.

83. Question Result, ID, References Sat, DC.CO.PLASTICPIPESEP.R,

Question Text *Do records indicate minimum separation requirements are met for plastic pipelines?*

Assets Covered 90877 (1919)

Result Notes 315 R form and 336. Records for joint trench require minimum separation.

All observations in the field during random crew inspections indicate that minimum separation requirements have been met.

84. Question Result, ID, References Sat, MO.GM.EQUIPPLASTICJOINT.R, 192.603(b) (192.756)

Question Text *Do records indicate equipment used in joining plastic pipe was maintained in accordance with the manufacturer's recommended practices or with written procedures that have been proven by test and experience to produce acceptable joints?*

Assets Covered 90877 (1919)

Result Notes Reviewed calibration records for the electrofusion machine by EF Technologies. Machines are calibrated every 3 years. Form C also has documentation for equipment.

85. Question Result, ID, References NA, MO.GM.RECORDS.R, 192.605(b)(1) (192.243(f), 192.709(a), 192.709(b), 192.709(c))

Question Text *Do records indicate that records are maintained of each pipe/"other than pipe" repair, NDT required record, and (as required by subparts L or M) patrol, survey, inspection or test?*

Assets Covered 90877 (1919)

Result Notes No such requirement existed in the scope of inspection review. Transmission question.

86. Question Result, ID, References NA, MO.GM.MOVEANDLOWER.R,

Question Text *Do records indicate that a study was prepared before moving or lowering a steel gas pipeline as required?*

Assets Covered 90877 (1919)

Result Notes No such event occurred, or condition existed, in the scope of inspection review.

87. Question Result, ID, References NA, MO.GM.MOVEANDLOWERSURVEY.R,

Question Text *Do records indicate that a leak survey was conducted not more than thirty days after moving and/or lowering a metallic pipeline?*

Assets Covered 90877 (1919)

Result Notes No such event occurred, or condition existed, in the scope of inspection review.

88. Question Result, ID, References Sat, MO.RW.MARKERSMAPSDRAW.R,

Question Text *Are records sufficient to indicate class location and other areas where pipeline markers are required?*

Assets Covered 90877 (1919)

Result Notes CNG has marker locations on their leak survey maps.

Bridge crossings are inspected annually or more frequently as necessary.

FR.FIELDPIPE: Pipeline Inspection (Field)

89. Question Result, ID, References Sat, DC.MA.MARKING.O, 192.63(a) (192.63(b), 192.63(c), 192.63(d))

Question Text *Are pipe, valves, and fittings properly marked for identification?*

Assets Covered 90877 (1919)

Result Notes All fittings observed in the field were properly marked.

An inspection of the pipe storage yard was conducted and pipe was properly marked.

90. Question Result, ID, References Sat, DC.DPC.FLANGE.O, 192.141 (192.147(a), 192.147(b), 192.147(c))

Question Text *Do flanges and flange accessories meet the requirements of 192.147?*

Assets Covered 90877 (1919)

Result Notes As built records were reviewed on a sampling basis and all flange assemblies were appropriately rated.

91. Question Result, ID, References Sat, DC.DPC.GDVALVEPLACEMENT.O, 192.141 (192.181(a), 192.181(b), 192.181(c))

Question Text *Are distribution line valves being installed as required of 192.181?*

Assets Covered 90877 (1919)

92. Question Result, ID, References Sat, DC.CO.PLASTICPIPEPROC.O,

Question Text *Is plastic pipe handled, stored and installed in accordance with manufacturer's recommendations, including maximum ultraviolet exposure?*

Assets Covered 90877 (1919)

Result Notes CNG's storage yard was inspected. No issues.

93. Question Result, ID, References NA, DC.CO.PLASTICWEAKLINK.O,

Question Text *Is a weak link installed when pulling plastic pipe by mechanical means?*

Assets Covered 90877 (1919)

Result Notes No such activity/condition was observed during the inspection.

94. Question Result, ID, References **NA, DC.CO.PLASTICPIPESEP.O,**
 Question Text *Are plastic pipelines installed with the minimum separation from other utilities as required?*
 Assets Covered **90877 (1919)**
 Result Notes **No such activity/condition was observed during the inspection.**
95. Question Result, ID, References **NA, DC.CO.PLASTICBACKFILL.O,**
 Question Text *Is plastic pipe buried in essentially rock-free material or material recommended by the pipe manufacturer?*
 Assets Covered **90877 (1919)**
 Result Notes **No such activity/condition was observed during the inspection.**
96. Question Result, ID, References **Sat, DC.CO.PLASTICSQUEEZING.O,**
 Question Text *Verify that the operator has limits in place for squeezing plastic pipe.*
 Assets Covered **90877 (1919)**
97. Question Result, ID, References **Sat, DC.METERREGSVC.CUSTOMETERREGLOC.O, 192.351 (192.353(a), 192.353(b), 192.353(c), 192.353(d))**
 Question Text *Are meters and service regulators being located consistent with the requirements of 192.353?*
 Assets Covered **90877 (1919)**
98. Question Result, ID, References **Sat, DC.METERREGSVC.CUSTOMETERREGPROT.O, 192.351 (192.355(a), 192.355(b), 192.355(c))**
 Question Text *Are meters and service regulators being protected from damage consistent with the requirements of 192.355?*
 Assets Covered **90877 (1919)**
99. Question Result, ID, References **Sat, DC.METERREGSVC.CUSTOMETERREGINSTALL.O, 192.351 (192.357(a), 192.357(b), 192.357(c), 192.357(d))**
 Question Text *Are meters and service regulators being installed consistent with the requirements of 192.357?*
 Assets Covered **90877 (1919)**
100. Question Result, ID, References **Sat, DC.METERREGSVC.CUSTOMETEROPPRESS.O, 192.351 (192.359(a), 192.359(b), 192.359(c))**
 Question Text *Are customer meter operating pressures consistent with the requirements of 192.359?*
 Assets Covered **90877 (1919)**
 Result Notes **Records review of set points only.**
101. Question Result, ID, References **Sat, DC.METERREGSVC.SVCLINEINSTALL.O, 192.351 (192.361(a), 192.361(b), 192.361(c), 192.361(d), 192.361(e), 192.361(f), 192.361(g))**
 Question Text *Are customer service lines being installed consistent with the requirements of 192.361?*
 Assets Covered **90877 (1919)**
102. Question Result, ID, References **Sat, DC.METERREGSVC.SVCLINEVLVLOCATEREQT.O, 192.351 (192.363(a), 192.363(b), 192.363(c), 192.365(a), 192.365(b), 192.365(c))**
 Question Text *Are customer service line valves being installed meeting the valve and locations requirements of 192.363 and 192.365?*
 Assets Covered **90877 (1919)**
103. Question Result, ID, References **Sat, DC.METERREGSVC.SVCLINECONNECT.O, 192.351 (192.367(a), 192.367(b), 192.369(a), 192.369(b))**
 Question Text *Are customer service lines being installed with connections meeting the requirements of 192.367 and 192.369?*
 Assets Covered **90877 (1919)**
104. Question Result, ID, References **Sat, DC.METERREGSVC.SVCLINEMATERIAL.O, 192.351 (192.371, 192.373(a), 192.373(b), 192.373(c), 192.375(a), 192.375(b), 192.377)**
 Question Text *Are customer service lines being installed constructed appropriately for the types of materials used?*
 Assets Covered **90877 (1919)**

105. Question Result, ID, References **Sat, DC.METERREGSVC.NEWSVCLINENOTUSED.O, 192.351 (192.379, 192.379(a), 192.379(b), 192.379(c))**
 Question Text *Are new customer service lines not in use configured in accordance with the requirements of 192.379?*
 Assets Covered **90877 (1919)**
106. Question Result, ID, References **Sat, DC.METERREGSVC.EXCSFLOWVLVLOCATE.O, 192.351 (192.381(c), 192.381(d), 192.381(e))**
 Question Text *Are service line excess flow valves located and identified in accordance with the requirements of 192.381?*
 Assets Covered **90877 (1919)**
107. Question Result, ID, References **Sat, DC.METERREGSVC.REGTEST.O,**
 Question Text *Are service regulators operated, maintained, installed and tested during the initial turn-on in accordance with manufacturer's recommendations and WAC requirements?*
 Assets Covered **90877 (1919)**
108. Question Result, ID, References **Sat, DC.WELDPROCEDURE.ONSITE.O,**
 Question Text *Are qualified written welding procedures located onsite where welding is being performed?*
 Assets Covered **90877 (1919)**
109. Question Result, ID, References **Sat, DC.WELDPROCEDURE.ESSENTIAL.O,**
 Question Text *Does the operator document essential variables when qualifying welders and weld procedures?*
 Assets Covered **90877 (1919)**
 Result Notes **Records review only.**
110. Question Result, ID, References **NA, TD.COAT.NEWPIPEINSTALL.O, 192.461(d)**
 Question Text *Is external protective coating being protected from damage that could result from adverse ditch conditions or supporting blocks?*
 Assets Covered **90877 (1919)**
 Result Notes **No such activity/condition was observed during the inspection.**
111. Question Result, ID, References **Sat, TD.CPMONITOR.MONITORCRITERIA.O, 192.465(a) (192.463(b), 192.463(c), 192.463(a))**
 Question Text *Are methods used for taking CP monitoring readings that allow for the application of appropriate CP monitoring criteria?*
 Assets Covered **90877 (1919)**
112. Question Result, ID, References **Sat, TD.CPMONITOR.CURRENTTEST.O, 192.465(b)**
 Question Text *Are impressed current sources properly maintained and are they functioning properly?*
 Assets Covered **90877 (1919)**
113. Question Result, ID, References **Sat, TD.CP.ELECISOLATE.O, 192.467(a) (192.467(b), 192.467(c), 192.467(d), 192.467(e))**
 Question Text *Are measures performed to ensure electrical isolation of each buried or submerged pipeline from other metallic structures unless they electrically interconnect and cathodically protect the pipeline and the other structures as a single unit?*
 Assets Covered **90877 (1919)**
114. Question Result, ID, References **Sat, TD.CP.CASINGINSPECT.O,**
 Question Text *Are casings electrically isolated from the pipeline?*
 Assets Covered **90877 (1919)**
115. Question Result, ID, References **Sat, TD.CPMONITOR.TESTSTATION.O, 192.469**
 Question Text *Do cathodically protected pipelines have a sufficient number of test stations?*
 Assets Covered **90877 (1919)**

116. Question Result, ID, References **Sat, TD.CP.MONITOR.TESTLEAD.O, 192.471(a)**
 Question Text *Do pipelines with cathodic protection have electrical test leads installed in accordance with requirements of Subpart I?*
 Assets Covered **90877 (1919)**
117. Question Result, ID, References **NA, TD.CP.MONITOR.INTFRCURRENT.O, 192.473(a)**
 Question Text *Are areas of potential stray current identified, and if found, the detrimental effects of stray currents minimized?*
 Assets Covered **90877 (1919)**
 Result Notes **No such event occurred, or condition existed, in the scope of inspection review.**
118. Question Result, ID, References **Sat, TD.CP.ADJACENTMETAL.O, 192.473(b)**
 Question Text *Are impressed current type cathodic protection systems and galvanic anode systems installed so as to minimize any adverse effect on existing adjacent underground metallic structures?*
 Assets Covered **90877 (1919)**
119. Question Result, ID, References **Sat, TD.ICP.CORRGASPRVNT.O, 192.475(a)**
 Question Text *If the transportation of corrosive gas is not allowed, is the transportation of corrosive gas prevented?*
 Assets Covered **90877 (1919)**
120. Question Result, ID, References **NA, TD.ICP.CORRGASACTION.O, 192.477**
 Question Text *Are adequate actions taken when corrosive gas is being transported by pipeline?*
 Assets Covered **90877 (1919)**
 Result Notes **No such event occurred, or condition existed, in the scope of inspection review.**
121. Question Result, ID, References **Sat, TD.ATM.ATMCORRODEINSP.O, 192.481(b) (192.481(c), 192.479(a), 192.479(b), 192.479(c))**
 Question Text *Is pipe that is exposed to atmospheric corrosion protected?*
 Assets Covered **90877 (1919)**
122. Question Result, ID, References **Sat, AR.COM.REMEDIATIONOM.O, 192.487(a) (192.487(b))**
 Question Text *Is anomaly remediation and documentation of remediation adequate for all segments?*
 Assets Covered **90877 (1919)**
123. Question Result, ID, References **Sat, MO.GOODOR.ODORIZE.O, 192.625(a) (192.625(c), 192.625(d), 192.625(e), 192.625(f))**
 Question Text *Is sampling of combustible gases adequate using an instrument capable of determining the percentage of gas in air at which it becomes readily detectable?*
 Assets Covered **90877 (1919)**
124. Question Result, ID, References **NA, MO.GO.PURGE.O, 192.629(a) (192.629(b))**
 Question Text *Are lines being purged in accordance with 192.629?*
 Assets Covered **90877 (1919)**
 Result Notes **No such activity/condition was observed during the inspection.**
125. Question Result, ID, References **Sat, MO.RW.ROWMARKER.O, 192.707(a) (192.707(b), 192.707(d), CGA Best Practices, v4.0, Practice 2-5, CGA Best Practices, v4.0, Practice 4-20)**
 Question Text *Are line markers placed and maintained as required?*
 Assets Covered **90877 (1919)**
126. Question Result, ID, References **Sat, MO.RW.ROWMARKERABOVE.O, 192.707(c) (CGA Best Practices, v4.0, Practice 2-5, CGA Best Practices, v4.0, Practice 4-20)**
 Question Text *Are line markers placed and maintained as required for above ground pipelines?*
 Assets Covered **90877 (1919)**

127. Question Result, ID, References **NA, MO.GMOPP.PRESSREGTEST.O, 192.739(a) (192.739(b))**
 Question Text *Are field or bench tests or inspections of regulating stations, pressure limiting stations or relief devices adequate?*
 Assets Covered **90877 (1919)**
 Result Notes **No such activity/condition was observed during the inspection.**
128. Question Result, ID, References **Sat, MO.GMOPP.PRESSREGMETER.O, 192.741(a) (192.741(b), 192.741(c))**
 Question Text *Are telemetering or recording gauges properly utilized as required for distribution systems?*
 Assets Covered **90877 (1919)**
129. Question Result, ID, References **Sat, MO.GMOPP.MULTIPRESSREG.O,**
 Question Text *Are regulator stations installed in a manner to provide protection between regulator stages?*
 Assets Covered **90877 (1919)**
130. Question Result, ID, References **Sat, MO.GM.DISTVALVEINSPECT.O, 192.747(a) (192.747(b))**
 Question Text *Is proper inspection being performed for each distribution system valve that might be required in an emergency, and prompt remedial action to correct any valves found inoperable?*
 Assets Covered **90877 (1919)**
131. Question Result, ID, References **Sat, FS.FG.CASING.O,**
 Question Text *Are all casings bare steel and do they have test leads installed on new casings without vents?*
 Assets Covered **90877 (1919)**
132. Question Result, ID, References **NA, FS.FG.CASESEAL.O,**
 Question Text *Does the operator seal both ends of casings/conduits for mains and transmission lines and seal the end nearest the building for service lines?*
 Assets Covered **90877 (1919)**
 Result Notes **No such activity/condition was observed during the inspection.**
133. Question Result, ID, References **Sat, AR.RMP.IGNITION.O, 192.751(a) (192.751(b), 192.751(c))**
 Question Text *Perform observations of selected locations to verify that adequate steps have been taken by the operator to minimize the potential for accidental ignition.*
 Assets Covered **90877 (1919)**
134. Question Result, ID, References **Sat, MO.GM.EQUIPPLASTICJOINT.O, 192.756**
 Question Text *Is proper maintenance being performed on equipment used in joining plastic pipe in accordance with the manufacturer's recommended practices or with written procedures that have been proven by test and experience to produce acceptable joints?*
 Assets Covered **90877 (1919)**
135. Question Result, ID, References **Sat, MO.GM.ONSITEPROCS.O,**
 Question Text *Are procedures applicable to the work being done located onsite where the work is being done?*
 Assets Covered **90877 (1919)**
136. Question Result, ID, References **Sat, AR.PTI.EQUIPCALIB.O,**
 Question Text *Is pressure testing equipment calibrated according to calibration schedules and procedures?*
 Assets Covered **90877 (1919)**
137. Question Result, ID, References **NA, AR.PTI.PLASTICPRESSURETEST.O,**
 Question Text *Is plastic pipe installed and backfilled prior to pressure testing?*

Assets Covered 90877 (1919)

Result Notes No such activity/condition was observed during the inspection.

GDIM.IMPL: GDIM Implementation

138. Question Result, ID, References NC, GDIM.RR.MECHANICALFITTINGDATAIMPL.R, 192.1009 (191.12) (also presented in: PRR.REPORT)

Question Text *Have accurate records been maintained documenting mechanical fitting failures that resulted in hazardous leaks?*

Assets Covered 90877 (1919)

Result Notes These reports will be reviewed during the annual review.

MISCTOPICS.PROT9: OQ Field Inspection

139. Question Result, ID, References Sat, TQ.PROT9.CORRECTION.O, 192.801(a) (192.809(a))

Question Text *Have potential issues identified by the OQ plan inspection process been corrected at the operational level?*

Assets Covered 90877 (1919)

140. Question Result, ID, References Sat, TQ.PROT9.QUALIFICATIONSTATUS.O, 192.801(a) (192.809(a))

Question Text *Verify the individuals performing the observed covered tasks are currently qualified to perform the covered tasks.*

Assets Covered 90877 (1919)

141. Question Result, ID, References Sat, TQ.PROT9.TASKPERFORMANCE.O, 192.801(a) (192.809(a))

Question Text *Verify the qualified individuals performed the observed covered tasks in accordance with the operator's procedures or operator approved contractor procedures.*

Assets Covered 90877 (1919)

142. Question Result, ID, References Sat, TQ.PROT9.AOCRECOG.O, 192.801(a) (192.809(a))

Question Text *Verify the individuals performing covered tasks are cognizant of the AOCs that are applicable to the tasks observed.*

Assets Covered 90877 (1919)

143. Question Result, ID, References NA, TQ.PROT9.VERIFYQUAL.O, 192.801(a) (192.809(a))

Question Text *Observe in the field (job site, local office, etc.) that the foreman/supervisor/manager has verified the qualification of the individual performing the task, that the qualification records are current, and ensure the personal identification of all individuals performing covered tasks are checked, prior to task performance.*

Assets Covered 90877 (1919)

Result Notes No such activity/condition was observed during the inspection.

MISCTOPICS.PUBAWARE: Public Awareness Program Effectiveness

144. Question Result, ID, References Sat, EP.ERG.LIAISON.R, 192.605(a) (192.615(c)(1), 192.615(c)(2), 192.615(c)(3), 192.615(c)(4), 192.616(c), ADB-05-03) (also presented in: PRR.OM)

Question Text *Do records indicate liaisons established and maintained with appropriate fire, police and other public officials and utility owners in accordance with procedures?*

Assets Covered 90877 (1919)

Result Notes Reviewed the spreadsheet of emergency responder contacts and the annual news information flyer mailed to them. CNG also does local contact with emergency responders..

145. Question Result, ID, References Sat, PD.PA.LANGUAGE.R, 192.616(g) (API RP 1162 Section 2.3.1) (also presented in: PRR.OM)

Question Text *Were materials and messages developed and delivered in other languages commonly understood by a significant number and concentration of non-English speaking populations in the operator's areas?*

Assets Covered 90877 (1919)

Result Notes Yes. In addition CNG's website has multiple languages.

146. Question Result, ID, References Sat, PD.PA.EVALEFFECTIVENESS.R, 192.616(c) (API RP 1162 Section 8.4) (also presented in: PRR.OM)

Question Text *Have effectiveness evaluation(s) of the program been performed for all stakeholder groups in all notification areas along all systems covered by the program?*

Assets Covered 90877 (1919)

Result Notes CNG contracted out their effectiveness review. The last one conducted was August 21, 2018.

147. Question Result, ID, References NA, PD.PA.MSTRMETER.R, 192.616(j) (192.616(h), API RP 1162 Section 2.7 (Step 12), API RP 1162 Section 8.5) (also presented in: PRR.OM)

Question Text *Do records indicate the public awareness program for a master meter or petroleum gas system operator has met the requirements of Part 192?*

Assets Covered 90877 (1919)

Result Notes No such relevant facilities/equipment existed in the scope of inspection review.

Report Parameters: Results: all

Except as required to be disclosed by law, any inspection documentation, including completed protocol forms, summary reports, executive summary reports, and enforcement documentation are for internal use only by federal or state pipeline safety regulators. Some inspection documentation may contain information which the operator considers to be confidential. In addition, supplemental inspection guidance and related documents in the file library are also for internal use only by federal or state pipeline safety regulators (with the exception of documents published in the federal register, such as advisory bulletins). Do not distribute or otherwise disclose such material outside of the state or federal pipeline regulatory organizations. Requests for such information from other government organizations (including, but not limited to, NTSB, GAO, IG, or Congressional Staff) should be referred to PHMSA Headquarters Management.

Inspection Results (IRR)

Generated on 2021. September.29 07:23

• 90877 (1919) (147)

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Assets | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|------------|------------|-------------------------------------|--|--|
| 1. | (and 1 other asset) | NA | | PRR.REPORT | 1. | RPT.RR.IMMEDREPORT.R | 191.5(a) (191.7(a), 191.7(d)) | Do records indicate immediate notifications of incidents were made in accordance with 191.5? |
| 2. | (and 1 other asset) | NA | | PRR.REPORT | 2. | RPT.RR.INCIDENTREPORT.R | 191.9(a) | Do records indicate reportable incidents were identified and reports were submitted to DOT on Form 7100.1 within the required time frame? |
| 3. | (and 1 other asset) | NA | | PRR.REPORT | 3. | RPT.RR.INCIDENTREPORTSUPP.R | 191.9(b) | Do records indicate accurate supplemental incident reports were filed and within the required timeframe? |
| 4. | (and 1 other asset) | NC | | PRR.REPORT | 4. | RPT.RR.ANNUALREPORT.R | 191.11(a) | Have complete and accurate Annual Reports been submitted? |
| 5. | (and 1 other asset) | NC | | PRR.REPORT | 5. | RPT.RR.UTCANNUALREPORTS.R | | Have complete and accurate annual reports been submitted to the commission? |
| 6. | (and 1 other asset) | Sat | | PRR.REPORT | 6. | RPT.RR.MISDATAREPORTS.R | | Has the operator submitted a copy of DOT Drug and Alcohol Testing MIS Data Collection Form to the commission when required? |
| 7. | (and 1 other asset) | NC | (2) | PRR.REPORT | 7. | GDIM.RR.MECHANICALFITTINGDATAIMPL.R | 192.1009 (191.12) | Have accurate records been maintained documenting mechanical fitting failures that resulted in hazardous leaks? |
| 8. | (and 1 other asset) | NA | | PRR.REPORT | 8. | RPT.RR.SRCR.R | 191.23(a) (191.23(b), 191.25(a), 191.25(c)) | Do records indicate safety-related condition reports were filed as required? |
| 9. | (and 1 other asset) | NA | | PRR.REPORT | 9. | RPT.RR.MAOPINCREASENOTIFY.R | | Do records indicate submittal of a written plan of procedures to the commission at least forty-five days before uprating to a MAOP greater than 60 psig? |
| 10. | (and 1 other asset) | Sat | | PRR.REPORT | 10. | RPT.RR.THIRTYDAYRPT.R | | Has the operator submitted a written report within 30 days |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Asset | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|---------------|------------|-------------------------------|--|---|
| | other asset) | | | | | | | following each reportable incident? |
| 11. | (and 1 other asset) | Sat | | PRR.REPORT | 11 | MO.GO.CUSTNOTIFY.R | 192.16(d) (192.16(a), 192.16(b), 192.16(c)) | Do records indicate the customer notification process satisfies the requirements of 192.16? |
| 12. | (and 1 other asset) | Sat | | PRR.REPORT | 12 | RPT.RR.DAILYCONSTRUCTIONRPT.R | | Do records indicate daily construction and repair activities were emailed to the commission no later than 10 AM each day work is scheduled? |
| 13. | (and 1 other asset) | Sat | | PRR.REPORT | 13 | RPT.RR.PIPELINEMAPPING.R | | Has the operator provided accurate maps (or updates) of all pipelines operating over 250 psig to specifications developed by the commission sufficient to meet the needs of first responders? |
| 14. | (and 1 other asset) | Sat | | PRR.CORROSION | 1. | TQ.QU.CORROSION.R | 192.453 (192.807(a), 192.807(b)) | Do records indicate qualification of personnel implementing pipeline corrosion control methods? |
| 15. | (and 1 other asset) | Sat | | PRR.CORROSION | 2. | TD.CP.RECORDS.R | 192.491(a) | Do records indicate the location of all items listed in 192.491(a)? |
| 16. | (and 1 other asset) | Sat | | PRR.CORROSION | 3. | TD.CPMONITOR.CURRENTTEST.R | 192.491(c) (192.465(b)) | Do records document details of electrical checks of sources of rectifiers or other impressed current sources? |
| 17. | (and 1 other asset) | Sat | | PRR.CORROSION | 4. | TD.CPEXPOSED.EXPOSEINSPECT.R | 192.491(c) (192.459) | Do records adequately document that exposed buried piping was examined for corrosion? |
| 18. | (and 1 other asset) | Sat | | PRR.CORROSION | 5. | TD.CPMONITOR.TEST.R | 192.491(c) (192.465(a)) | Do records adequately document cathodic protection monitoring tests have occurred as required? |
| 19. | (and 1 other asset) | Sat | | PRR.CORROSION | 6. | TD.CPMONITOR.REVCURRENTTEST.R | 192.491(c) (192.465(c)) | Do records document details of electrical checks interference bonds, diodes, and reverse current switches? |
| 20. | (and 1 other asset) | Sat | | PRR.CORROSION | 7. | TD.CPMONITOR.DEFICIENCY.R | 192.491(c) (192.465(d)) | Do records adequately document actions taken to correct any identified deficiencies in corrosion control? |
| 21. | (and 1 other asset) | NA | | PRR.CORROSION | 8. | TD.CP.UNPROTECT.R | 192.491(c) (192.465(e)) | Do records adequately document that exposed buried piping was examined for corrosion |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Assets | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|---------------|------------|-----------------------------|--|--|
| | | | | | | | | and deteriorated coating? |
| 22. | (and 1 other asset) | NA | | PRR.CORROSION | 9. | FS.FG.CASINGTESTLEAD.R | | Do records indicate that all casings without vents installed after September 5, 1992 had separate test lead wires installed? |
| 23. | (and 1 other asset) | Sat | | PRR.CORROSION | 10 | FS.FG.CASINGSEALS.R | | Do records indicate that mains and service lines installed in casing or conduit are sealed at the ends as required? |
| 24. | (and 1 other asset) | Sat | | PRR.CORROSION | 11 | TD.CP.ELECISOLATE.R | 192.491(c) (192.467(a), 192.467(b), 192.467(c), 192.467(d), 192.467(e)) | Do records adequately document electrical isolation of each buried or submerged pipeline from other metallic structures unless they electrically interconnect and cathodically protect the pipeline and the other structures as a single unit? |
| 25. | (and 1 other asset) | Sat | | PRR.CORROSION | 12 | TD.CP.CASINGINSPECT.R | | Do records indicate that annual casing inspections have been performed to ensure electrical isolation from the pipeline? |
| 26. | (and 1 other asset) | Sat | | PRR.CORROSION | 13 | TD.CPMONITOR.TESTSTATION.R | 192.469 | Do records identify the location of test stations and show a sufficient number of test stations? |
| 27. | (and 1 other asset) | Sat | | PRR.CORROSION | 14 | TD.CPMONITOR.TESTLEAD.R | 192.491(c) (192.471(a), 192.471(b), 192.471(c)) | Do records document that pipelines with cathodic protection have electrical test leads installed in accordance with requirements of Subpart I? |
| 28. | (and 1 other asset) | Sat | | PRR.CORROSION | 15 | TD.CPMONITOR.INTFRCURRENT.R | 192.491(c) (192.473(a)) | Do records document an effective program is in place to minimize detrimental effects of interference currents and that detrimental effects of interference currents from CP systems on other underground metallic structures are minimized? |
| 29. | (and 1 other asset) | NA | | PRR.CORROSION | 16 | TD.ICP.CORRGAS.R | 192.491(c) (192.475(a)) | Do the records demonstrate that the corrosive effect of the gas in the pipeline has been investigated and if determined to be corrosive, steps be taken to minimize internal corrosion? |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Asset | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|---------------|------------|------------------------------------|---|--|
| 30. | (and 1 other asset) | Sat | | PRR.CORROSION | 17 | TD.ICP.EXAMINE.R | 192.491(c) (192.475(a), 192.475(b)) | Do records document examination of removed pipe for evidence of internal corrosion? |
| 31. | (and 1 other asset) | NA | | PRR.CORROSION | 18 | TD.ICP.CORRGASACTION.R | 192.491(c) (192.477) | Do records document the actions taken when corrosive gas is being transported by pipeline? |
| 32. | (and 1 other asset) | Sat | | PRR.CORROSION | 19 | TD.ATM.ATMCORRODEINSP.R | 192.491(c) (192.481(a), 192.481(b), 192.481(c)) | Do records document inspection of aboveground pipe for atmospheric corrosion? |
| 33. | (and 1 other asset) | Sat | | PRR.CORROSION | 20 | TD.COAT.NEWPIPE.R | 192.491(c) (192.455(a), 192.461(a), 192.461(b), 192.483(a)) | Do records document that each buried or submerged pipeline installed after July 31, 1971 has been externally coated with a suitable coating material? |
| 34. | (and 1 other asset) | NA | | PRR.CORROSION | 21 | TD.ICP.REPAIR.R | 192.485(a) (192.485(b)) | Do records document the repair or replacement of pipe that has been internally corroded to an extent that there is not sufficient remaining strength in the pipe wall? |
| 35. | (and 1 other asset) | NA | | PRR.CORROSION | 22 | TD.ICP.EVALUATE.R | 192.491(c) (192.485(c)) | Do records document adequate evaluation of internally corroded pipe? |
| 36. | (and 1 other asset) | Sat | | PRR.PT | 1. | DC.PTLOWPRESS.PRESSTESTLOWSTRESS.R | 192.517(a) (192.507(a), 192.507(b), 192.507(c)) | Do records indicate that pressure testing is conducted in accordance with 192.507? |
| 37. | (and 1 other asset) | Sat | | PRR.PT | 2. | DC.PTLOWPRESS.PRESSTEST100PSIG.R | 192.517(b) (192.509(a), 192.509(b)) | Do records indicate that pressure testing is conducted in accordance with 192.509(a)? |
| 38. | (and 1 other asset) | Sat | | PRR.PT | 3. | DC.PT.SERVICELINE.R | 192.517(b) (192.511(a), 192.511(b), 192.511(c)) | Do records indicate that pressure testing is conducted in accordance with 192.511? |
| 39. | (and 1 other asset) | Sat | | PRR.PT | 4. | DC.PT.PRESSTESTPLASTIC.R | 192.517(b) (192.513(a), 192.513(b), 192.513(c), 192.513(d)) | Do records indicate that pressure testing is conducted in accordance with 192.513? |
| 40. | (and 1 other asset) | NA | | PRR.UPRATE | 1. | MO.GOUPRATE.MAOPINCREASE.R | 192.553(a) (192.553(b), 192.553(c)) | Do records indicate that increases in MAOP of pipeline were determined in accordance with 192.553? |
| 41. | (and 1 other asset) | NA | | PRR.UPRATE | 2. | MO.GOUPRATE.MAOPINCREASELIMIT.R | 192.553(b) (192.553(c), 192.553(d), 192.557(a)) | Do records indicate that increases in MAOP are limited in accordance with 192.619 and 192.621? |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Asset | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|------------|------------|--------------------------------|--|---|
| 42. | (and 1 other asset) | NA | | PRR.UPRATE | 3. | MO.GOUPRATE.MAOPINCREASEPREP.R | 192.553(b) (192.553(c), 192.557(b), 192.557(c)) | Do records indicate that increases in MAOP were preceded by the actions specified in 192.557? |
| 43. | (and 1 other asset) | Sat | | PRR.OM | 1. | MO.GO.OMANNUALREVIEW.R | 192.605(a) | Have annual reviews of the written procedures or processes in the manual been conducted as required? |
| 44. | (and 1 other asset) | Sat | | PRR.OM | 2. | MO.GO.OMHISTORY.R | 192.605(a) (192.605(b)(3)) | Are construction records, maps and operating history available to appropriate operating personnel? |
| 45. | (and 1 other asset) | Sat | | PRR.OM | 3. | MO.GO.OMEFFECTREVIEW.R | 192.605(a) (192.605(b)(8)) | Do records indicate periodic review of the work done by operator personnel to determine the effectiveness, and adequacy of the processes used in normal operations and maintenance and modifying the processes when deficiencies are found? |
| 46. | (and 1 other asset) | NA | | PRR.OM | 4. | MO.GOABNORMAL.ABNORMALREVIEW.R | 192.605(a) (192.605(c)(4)) | Do records indicate periodic review of work done by operator personnel to determine the effectiveness of the abnormal operation processes and corrective action taken where deficiencies are found? |
| 47. | (and 1 other asset) | Sat | | PRR.OM | 5. | PD.OC.PDPROGRAM.R | 192.614(c) | Does the damage prevention program meet minimum requirements specified in 192.614(c)? |
| 48. | (and 1 other asset) | NA | | PRR.OM | 6. | MO.GOCLASS.CLASSLOCATESTUDY.R | 192.605(b)(1) (192.609(a), 192.609(b), 192.609(c), 192.609(d), 192.609(e), 192.609(f)) | Do records indicate performance of the required study whenever the population along a pipeline increased or there was an indication that the pipe hoop stress was not commensurate with the present class location? |
| 49. | (and 1 other asset) | Sat | | PRR.OM | 7. | EP.ERG.POSTEVTREVIEW.R | 192.605(a) (192.615(b)(1), 192.615(b)(3)) | Do records indicate review of employee activities to determine whether the procedures were effectively followed in each emergency? |
| 50. | (and 1 other asset) | Sat | | PRR.OM | 8. | EP.ERG.TRAINING.R | 192.605(a) (192.615(b)(2)) | Has the operator trained the appropriate operating personnel on emergency procedures |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Asset | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|-----------|------------|---------------------------|--|---|
| | | | | | | | | and verified that the training was effective in accordance with its procedures? |
| 51. | (and 1 other asset) | Sat | (2) | PRR.OM | 9. | EP.ERG.LIAISON.R | 192.605(a) (192.615(c)(1), 192.615(c)(2), 192.615(c)(3), 192.615(c)(4), 192.616(c), ADB-05-03) | Do records indicate liaisons established and maintained with appropriate fire, police and other public officials and utility owners in accordance with procedures? |
| 52. | (and 1 other asset) | Sat | (2) | PRR.OM | 10 | PD.PA.LANGUAGE.R | 192.616(g) (API RP 1162 Section 2.3.1) | Were materials and messages developed and delivered in other languages commonly understood by a significant number and concentration of non-English speaking populations in the operator's areas? |
| 53. | (and 1 other asset) | Sat | (2) | PRR.OM | 11 | PD.PA.EVALEFFECTIVENESS.R | 192.616(c) (API RP 1162 Section 8.4) | Have effectiveness evaluation(s) of the program been performed for all stakeholder groups in all notification areas along all systems covered by the program? |
| 54. | (and 1 other asset) | NA | (2) | PRR.OM | 12 | PD.PA.MSTRMETER.R | 192.616(j) (192.616(h), API RP 1162 Section 2.7 (Step 12), API RP 1162 Section 8.5) | Do records indicate the public awareness program for a master meter or petroleum gas system operator has met the requirements of Part 192? |
| 55. | (and 1 other asset) | NA | | PRR.OM | 13 | EP.ERG.INCIDENTANALYSIS.R | 192.605(a) (192.617) | Do records indicate actions initiated to analyze accidents and failures, including the collection of appropriate samples for laboratory examination to determine the causes of the failure and minimize the possibility of recurrence, in accordance with its procedures? |
| 56. | (and 1 other asset) | Sat | | PRR.OM | 14 | MO.GOMAOP.MAOPDETERMINE.R | 192.619(a) (192.619(b), 192.621(a), 192.621(b), 192.623(a), 192.623(b)) | Do records indicate determination of the MAOP of pipeline segments in accordance with 192.619 and limiting of the operating pressure as required? |
| 57. | (and 1 other asset) | Sat | | PRR.OM | 15 | MO.GOODOR.ODORIZE.R | 192.709(c) (192.625(a), 192.625(b), | Do records indicate appropriate odorization of its combustible gases |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Asset | Result | (Note 1) | Sub-Group | Question ID | References | Question Text |
|-----|---------------------|--------|----------|-----------|--------------------------------|--|---|
| | other asset) | | | | | 192.625(c), 192.625(d), 192.625(e), 192.625(f)) | in accordance with its processes and conduct of the required testing to verify odorant levels met requirements? |
| 58. | (and 1 other asset) | NA | | PRR.OM | 16 MO.RW.TRANSPATROL.R | 192.709(c) (192.705(a), 192.705(b), 192.705(c)) | Do records indicate that transmission line ROW surface conditions have been patrolled as required? |
| 59. | (and 1 other asset) | NA | | PRR.OM | 17 MO.RW.TRANSLEAKAGE.R | 192.709(c) (192.706, 192.706(a), 192.706(b)) | Do records indicate transmission leakage surveys conducted as required? |
| 60. | (and 1 other asset) | Sat | | PRR.OM | 18 MO.RW.DISTPATROL.R | 192.603(b) (192.721(a), 192.721(b)) | Do records indicate distribution patrolling was conducted as required? |
| 61. | (and 1 other asset) | Sat | | PRR.OM | 19 MO.RW.LEAKFOLLOW.R | | Do records indicate that a follow-up inspection was performed not more than thirty days following a repair where residual gas remained in the ground? |
| 62. | (and 1 other asset) | NA | | PRR.OM | 20 MO.RW.DOWNGRADELEAKREPAIR.R | | Do records indicate that leaks that have been downgraded are repaired within twenty-one months? |
| 63. | (and 1 other asset) | Sat | | PRR.OM | 21 MO.RW.LEAKREPAIRTIME.R | | Do records indicate that leaks were repaired and re-evaluated in the timeframes specified in WAC 480-93-18601? |
| 64. | (and 1 other asset) | Sat | | PRR.OM | 22 MO.RW.LEAKRECORDS.R | | Have gas leak records been prepared and maintained as required? |
| 65. | (and 1 other asset) | Sat | | PRR.OM | 23 MO.RW.DISTPATROLLEAKAGE.R | 192.603(b) (192.723(a), 192.723(b)) | Do records indicate distribution leakage surveys were conducted as required? |
| 66. | (and 1 other asset) | NA | | PRR.OM | 24 MO.RW.CASINGLEAKSURVEY.R | | Do records indicate shorted casings were leak surveyed as required? |
| 67. | (and 1 other asset) | Sat | | PRR.OM | 25 MO.RW.MARKERSURVEY.R | | Do records indicate that pipeline marker surveys were completed in the timeframe specified by WAC 480-93-124? |
| 68. | (and 1 other asset) | Sat | | PRR.OM | 26 MO.RW.MARKERREPLACE.R | | Do records indicate that damaged or missing markers were replaced within forty-five days of discovery? |
| 69. | (and 1 other asset) | Sat | | PRR.OM | 27 AR.RMP.TESTREINSTATE.R | 192.603(b) (192.725(a), 192.725(b)) | From the review of records, did the operator properly test |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Assets | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|-----------|------------|------------------------------|--|--|
| | | | | | | | | disconnected service lines? |
| 70. | (and 1 other asset) | Sat | | PRR.OM | 29 | MO.GMOPP.PRESSREGTEST.R | 192.709(c) (192.739(a), 192.739(b)) | Do records indicate inspection and testing of pressure limiting, relief devices, and pressure regulating stations? |
| 71. | (and 1 other asset) | Sat | | PRR.OM | 30 | MO.GMOPP.PRESSREGCAP.R | 192.709(c) (192.743(a), 192.743(b), 192.743(c)) | Do records indicate testing or review of the capacity of each pressure relief device at each pressure limiting station and pressure regulating station as required? |
| 72. | (and 1 other asset) | Sat | | PRR.OM | 31 | DC.METERREGSVC.REGTEST.R | | Do records indicate that service regulators have been installed, operated, maintained, tested during initial turn-on and tested when customers experience pressure problems? |
| 73. | (and 1 other asset) | Sat | | PRR.OM | 32 | MO.GM.DISTVALVEINSPECT.R | 192.603(b) (192.747(a), 192.747(b)) | Do records indicate proper inspection of each distribution system valve that might be required in an emergency at intervals not exceeding 15 months, but at least once each calendar year, and prompt remedial action to correct any valve found inoperable? |
| 74. | (and 1 other asset) | Sat | | PRR.OM | 34 | MO.GM.IGNITION.R | 192.709 (192.751(a), 192.751(b), 192.751(c)) | Do records indicate personnel followed processes for minimizing the danger of accidental ignition where the presence of gas constituted a hazard of fire or explosion? |
| 75. | (and 1 other asset) | Sat | | PRR.OM | 36 | DC.DPC.FLANGE.R | 192.147(a) (192.147(b), 192.147(c)) | Do records indicate flanges and flange accessories meet the requirements of 192.147? |
| 76. | (and 1 other asset) | Sat | | PRR.OM | 37 | DC.WELDPROCEDURE.WELD.R | 192.225(a) (192.225(b)) | Do records indicate weld procedures are being qualified in accordance with 192.225? |
| 77. | (and 1 other asset) | Sat | | PRR.OM | 38 | DC.WELDPROCEDURE.ESSENTIAL.R | | Do records indicate that essential variables were measured and documented when welders and procedures were qualified? |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Asset | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|-----------|------------|--------------------------------|--|---|
| 78. | (and 1 other asset) | Sat | | PRR.OM | 39 | TQ.QUOMCONST.WELDER.R | 192.227(a), 192.227(b), 192.229(a), 192.229(b), 192.229(c), 192.229(d), 192.328(a), 192.328(b), 192.807(a), 192.807(b) | Do records indicate adequate qualification of welders? |
| 79. | (and 1 other asset) | Sat | | PRR.OM | 40 | TQ.QUOMCONST.NDT.R | 192.243(b)(2), 192.807(a), 192.807(b), 192.328(a), 192.328(b) | Do records indicate the qualification of nondestructive testing personnel? |
| 80. | (and 1 other asset) | Sat | | PRR.OM | 41 | DC.CO.PLASTICJOINTPROCEDURE.R | 192.273(b), 192.283(a), 192.283(b), 192.283(c), 192.283(d) | Have plastic pipe joining procedures been qualified in accordance with 192.283? |
| 81. | (and 1 other asset) | Sat | | PRR.OM | 42 | DC.CO.PLASTICJOINTQUAL.R | 192.285(d), 192.285(a), 192.285(b), 192.285(c), 192.807(a), 192.807(b) | Do records indicate persons making joints in plastic pipelines are qualified in accordance with 192.285? |
| 82. | (and 1 other asset) | Sat | | PRR.OM | 43 | DC.CO.PLASTICJOINTINSPECTION.R | 192.287, 192.807(a), 192.807(b) | Do records indicate persons inspecting the making of plastic pipe joints have been qualified? |
| 83. | (and 1 other asset) | Sat | | PRR.OM | 44 | DC.CO.PLASTICPIPESEP.R | | Do records indicate minimum separation requirements are met for plastic pipelines? |
| 84. | (and 1 other asset) | Sat | | PRR.OM | 45 | MO.GM.EQUIPPLASTICJOINT.R | 192.603(b), 192.756 | Do records indicate equipment used in joining plastic pipe was maintained in accordance with the manufacturer's recommended practices or with written procedures that have been proven by test and experience to produce acceptable joints? |
| 85. | (and 1 other asset) | NA | | PRR.OM | 46 | MO.GM.RECORDS.R | 192.605(b)(1), 192.243(f), 192.709(a), 192.709(b), 192.709(c) | Do records indicate that records are maintained of each pipe/"other than pipe" repair, NDT required record, and (as required by subparts L or M) patrol, survey, inspection or test? |
| 86. | (and 1 other asset) | NA | | PRR.OM | 47 | MO.GM.MOVEANDLOWER.R | | Do records indicate that a study was prepared before moving or lowering a steel gas pipeline as required? |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Assets | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|--------------|------------|--|--|--|
| 87. | (and 1 other asset) | NA | | PRR.OM | 48 | MO.GM.MOVEANDLOWERSURVEY.R | | Do records indicate that a leak survey was conducted not more than thirty days after moving and/or lowering a metallic pipeline? |
| 88. | (and 1 other asset) | Sat | | PRR.OM | 49 | MO.RW.MARKERSMAPSDRAW.R | | Are records sufficient to indicate class location and other areas where pipeline markers are required? |
| 89. | (and 1 other asset) | Sat | | FR.FIELDPIPE | 1. | DC.MA.MARKING.O | 192.63(a) (192.63(b), 192.63(c), 192.63(d)) | Are pipe, valves, and fittings properly marked for identification? |
| 90. | (and 1 other asset) | Sat | | FR.FIELDPIPE | 2. | DC.DPC.FLANGE.O | 192.141 (192.147(a), 192.147(b), 192.147(c)) | Do flanges and flange accessories meet the requirements of 192.147? |
| 91. | (and 1 other asset) | Sat | | FR.FIELDPIPE | 3. | DC.DPC.GDVALVEPLACEMENT.O | 192.141 (192.181(a), 192.181(b), 192.181(c)) | Are distribution line valves being installed as required of 192.181? |
| 92. | (and 1 other asset) | Sat | | FR.FIELDPIPE | 4. | DC.CO.PLASTICPIPEPROC.O | | Is plastic pipe handled, stored and installed in accordance with manufacturer's recommendations, including maximum ultraviolet exposure? |
| 93. | (and 1 other asset) | NA | | FR.FIELDPIPE | 5. | DC.CO.PLASTICWEAKLINK.O | | Is a weak link installed when pulling plastic pipe by mechanical means? |
| 94. | (and 1 other asset) | NA | | FR.FIELDPIPE | 6. | DC.CO.PLASTICPIPESEP.O | | Are plastic pipelines installed with the minimum separation from other utilities as required? |
| 95. | (and 1 other asset) | NA | | FR.FIELDPIPE | 7. | DC.CO.PLASTICBACKFILL.O | | Is plastic pipe buried in essentially rock-free material or material recommended by the pipe manufacturer? |
| 96. | (and 1 other asset) | Sat | | FR.FIELDPIPE | 8. | DC.CO.PLASTICSQUEEZING.O | | Verify that the operator has limits in place for squeezing plastic pipe. |
| 97. | (and 1 other asset) | Sat | | FR.FIELDPIPE | 9. | DC.METERREGSVC.CUSTOMETERREGLOC.O | 192.351 (192.353(a), 192.353(b), 192.353(c), 192.353(d)) | Are meters and service regulators being located consistent with the requirements of 192.353? |
| 98. | (and 1 other asset) | Sat | | FR.FIELDPIPE | 10 | DC.METERREGSVC.CUSTOMETERREGPRO.T.O | 192.351 (192.355(a), 192.355(b), 192.355(c)) | Are meters and service regulators being protected from damage consistent with the requirements of 192.355? |
| 99. | (and 1 other asset) | Sat | | FR.FIELDPIPE | 11 | DC.METERREGSVC.CUSTOMETERREGINS.TALL.O | 192.351 (192.357(a), | Are meters and service regulators being |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Asset | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|--------------|------------|--|---|--|
| | other asset) | | | | | | 192.357(b), 192.357(c), 192.357(d)) | installed consistent with the requirements of 192.357? |
| 100 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 12 | DC.METERREGSVC.CUSTOMETEROPPRES.S.O | 192.351 (192.359(a), 192.359(b), 192.359(c)) | Are customer meter operating pressures consistent with the requirements of 192.359? |
| 101 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 13 | DC.METERREGSVC.SVCLINEINSTALL.O | 192.351 (192.361(a), 192.361(b), 192.361(c), 192.361(d), 192.361(e), 192.361(f), 192.361(g)) | Are customer service lines being installed consistent with the requirements of 192.361? |
| 102 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 14 | DC.METERREGSVC.SVCLINEVLVLOCATE.REQT.O | 192.351 (192.363(a), 192.363(b), 192.363(c), 192.365(a), 192.365(b), 192.365(c)) | Are customer service line valves being installed meeting the valve and locations requirements of 192.363 and 192.365? |
| 103 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 15 | DC.METERREGSVC.SVCLINECONNECT.O | 192.351 (192.367(a), 192.367(b), 192.369(a), 192.369(b)) | Are customer service lines being installed with connections meeting the requirements of 192.367 and 192.369? |
| 104 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 16 | DC.METERREGSVC.SVCLINEMATERIAL.O | 192.351 (192.371, 192.373(a), 192.373(b), 192.373(c), 192.375(a), 192.375(b), 192.377) | Are customer service lines being installed constructed appropriately for the types of materials used? |
| 105 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 17 | DC.METERREGSVC.NEWSVCLINENOTUSED.O | 192.351 (192.379, 192.379(a), 192.379(b), 192.379(c)) | Are new customer service lines not in use configured in accordance with the requirements of 192.379? |
| 106 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 18 | DC.METERREGSVC.EXCSFLOWVLVLOCATE.O | 192.351 (192.381(c), 192.381(d), 192.381(e)) | Are service line excess flow valves located and identified in accordance with the requirements of 192.381? |
| 107 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 19 | DC.METERREGSVC.REGTEST.O | | Are service regulators operated, maintained, installed and tested during the initial turn-on in accordance with manufacturer's recommendations and WAC requirements? |
| 108 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 20 | DC.WELDPROCEDURE.ONSITE.O | | Are qualified written welding procedures located onsite where welding is being performed? |
| 109 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 21 | DC.WELDPROCEDURE.ESSENTIAL.O | | Does the operator document essential |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Asset | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|--------------|------------|--------------------------------|--|--|
| | other asset) | | | | | | | variables when qualifying welders and weld procedures? |
| 110 | (and 1 other asset) | NA | | FR.FIELDPIPE | 22 | TD.COAT.NEWPIPEINSTALL.O | 192.461(d) | Is external protective coating being protected from damage that could result from adverse ditch conditions or supporting blocks? |
| 111 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 23 | TD.CPMONITOR.MONITORCRITERIA.O | 192.465(a), (192.463(b), 192.463(c), 192.463(a)) | Are methods used for taking CP monitoring readings that allow for the application of appropriate CP monitoring criteria? |
| 112 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 24 | TD.CPMONITOR.CURRENTTEST.O | 192.465(b) | Are impressed current sources properly maintained and are they functioning properly? |
| 113 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 25 | TD.CP.ELECISOLATE.O | 192.467(a), (192.467(b), 192.467(c), 192.467(d), 192.467(e)) | Are measures performed to ensure electrical isolation of each buried or submerged pipeline from other metallic structures unless they electrically interconnect and cathodically protect the pipeline and the other structures as a single unit? |
| 114 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 26 | TD.CP.CASINGINSPECT.O | | Are casings electrically isolated from the pipeline? |
| 115 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 27 | TD.CPMONITOR.TESTSTATION.O | 192.469 | Do cathodically protected pipelines have a sufficient number of test stations? |
| 116 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 28 | TD.CPMONITOR.TESTLEAD.O | 192.471(a) | Do pipelines with cathodic protection have electrical test leads installed in accordance with requirements of Subpart I? |
| 117 | (and 1 other asset) | NA | | FR.FIELDPIPE | 29 | TD.CPMONITOR.INTFRCURRENT.O | 192.473(a) | Are areas of potential stray current identified, and if found, the detrimental effects of stray currents minimized? |
| 118 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 30 | TD.CP.ADJACENTMETAL.O | 192.473(b) | Are impressed current type cathodic protection systems and galvanic anode systems installed so as to minimize any adverse effect on existing adjacent underground metallic structures? |
| 119 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 31 | TD.ICP.CORRGASPRVNT.O | 192.475(a) | If the transportation of corrosive gas is not |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Asset | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|--------------|------------|--------------------------|---|---|
| | other asset) | | | | | | | allowed, is the transportation of corrosive gas prevented? |
| 120 | (and 1 other asset) | NA | | FR.FIELDPIPE | 32 | TD.ICP.CORRGASACTION.O | 192.477 | Are adequate actions taken when corrosive gas is being transported by pipeline? |
| 121 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 34 | TD.ATM.ATMCORRODEINSP.O | 192.481(b), (192.481(c), 192.479(a), 192.479(b), 192.479(c)) | Is pipe that is exposed to atmospheric corrosion protected? |
| 122 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 35 | AR.RCOM.REMEDIATIONOM.O | 192.487(a), (192.487(b)) | Is anomaly remediation and documentation of remediation adequate for all segments? |
| 123 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 37 | MO.GOODOR.ODORIZE.O | 192.625(a), (192.625(c), 192.625(d), 192.625(e), 192.625(f)) | Is sampling of combustible gases adequate using an instrument capable of determining the percentage of gas in air at which it becomes readily detectable? |
| 124 | (and 1 other asset) | NA | | FR.FIELDPIPE | 38 | MO.GO.PURGE.O | 192.629(a), (192.629(b)) | Are lines being purged in accordance with 192.629? |
| 125 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 39 | MO.RW.ROWMARKER.O | 192.707(a), (192.707(b), 192.707(d), CGA Best Practices, v4.0, Practice 2-5, CGA Best Practices, v4.0, Practice 4-20) | Are line markers placed and maintained as required? |
| 126 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 40 | MO.RW.ROWMARKERABOVE.O | 192.707(c), (CGA Best Practices, v4.0, Practice 2-5, CGA Best Practices, v4.0, Practice 4-20) | Are line markers placed and maintained as required for above ground pipelines? |
| 127 | (and 1 other asset) | NA | | FR.FIELDPIPE | 41 | MO.GMOPP.PRESSREGTEST.O | 192.739(a), (192.739(b)) | Are field or bench tests or inspections of regulating stations, pressure limiting stations or relief devices adequate? |
| 128 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 42 | MO.GMOPP.PRESSREGMETER.O | 192.741(a), (192.741(b), 192.741(c)) | Are telemetering or recording gauges properly utilized as required for distribution systems? |
| 129 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 43 | MO.GMOPP.MULTIPRESSREG.O | | Are regulator stations installed in a manner to |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Asset | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|--------------|------------|-------------------------------------|---|---|
| | other asset) | | | | | | | provide protection between regulator stages? |
| 130 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 44 | MO.GM.DISTVALVEINSPECT.O | 192.747(a) (192.747(b)) | Is proper inspection being performed for each distribution system valve that might be required in an emergency, and prompt remedial action to correct any valves found inoperable? |
| 131 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 45 | FS.FG.CASING.O | | Are all casings bare steel and do they have test leads installed on new casings without vents? |
| 132 | (and 1 other asset) | NA | | FR.FIELDPIPE | 46 | FS.FG.CASESEAL.O | | Does the operator seal both ends of casings/conduits for mains and transmission lines and seal the end nearest the building for service lines? |
| 133 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 48 | AR.RMP.IGNITION.O | 192.751(a) (192.751(b), 192.751(c)) | Perform observations of selected locations to verify that adequate steps have been taken by the operator to minimize the potential for accidental ignition. |
| 134 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 51 | MO.GM.EQUIPPLASTICJOINT.O | 192.756 | Is proper maintenance being performed on equipment used in joining plastic pipe in accordance with the manufacturer's recommended practices or with written procedures that have been proven by test and experience to produce acceptable joints? |
| 135 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 52 | MO.GM.ONSITEPROCS.O | | Are procedures applicable to the work being done located onsite where the work is being done? |
| 136 | (and 1 other asset) | Sat | | FR.FIELDPIPE | 53 | AR.PTI.EQUIPCALIB.O | | Is pressure testing equipment calibrated according to calibration schedules and procedures? |
| 137 | (and 1 other asset) | NA | | FR.FIELDPIPE | 54 | AR.PTI.PLASTICPRESSURETEST.O | | Is plastic pipe installed and backfilled prior to pressure testing? |
| 138 | (and 1 other asset) | NC | (2) | GDIM.IMPL | 34 | GDIM.RR.MECHANICALFITTINGDATAIMPL.R | 192.1009 (191.12) | Have accurate records been maintained documenting mechanical fitting failures that |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Asset | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|----------------------|------------|--------------------------------|--|--|
| | | | | | | | | resulted in hazardous leaks? |
| 139 | (and 1 other asset) | Sat | | MISCTOPICS.PROT9 | 1. | TQ.PROT9.CORRECTION.O | 192.801(a) (192.809(a)) | Have potential issues identified by the OQ plan inspection process been corrected at the operational level? |
| 140 | (and 1 other asset) | Sat | | MISCTOPICS.PROT9 | 2. | TQ.PROT9.QUALIFICATIONSTATUS.O | 192.801(a) (192.809(a)) | Verify the individuals performing the observed covered tasks are currently qualified to perform the covered tasks. |
| 141 | (and 1 other asset) | Sat | | MISCTOPICS.PROT9 | 3. | TQ.PROT9.TASKPERFORMANCE.O | 192.801(a) (192.809(a)) | Verify the qualified individuals performed the observed covered tasks in accordance with the operator's procedures or operator approved contractor procedures. |
| 142 | (and 1 other asset) | Sat | | MISCTOPICS.PROT9 | 4. | TQ.PROT9.AOCRECOG.O | 192.801(a) (192.809(a)) | Verify the individuals performing covered tasks are cognizant of the AOCs that are applicable to the tasks observed. |
| 143 | (and 1 other asset) | NA | | MISCTOPICS.PROT9 | 5. | TQ.PROT9.VERIFYQUAL.O | 192.801(a) (192.809(a)) | Observe in the field (job site, local office, etc.) that the foreman/supervisor/manager has verified the qualification of the individual performing the task, that the qualification records are current, and ensure the personal identification of all individuals performing covered tasks are checked, prior to task performance. |
| 144 | (and 1 other asset) | Sat | (2) | MISCTOPICS.PUBAW ARE | 11 | EP.ERG.LIAISON.R | 192.605(a) (192.615(c)(1), 192.615(c)(2), 192.615(c)(3), 192.615(c)(4), 192.616(c), ADB-05-03) | Do records indicate liaisons established and maintained with appropriate fire, police and other public officials and utility owners in accordance with procedures? |
| 145 | (and 1 other asset) | Sat | (2) | MISCTOPICS.PUBAW ARE | 13 | PD.PA.LANGUAGE.R | 192.616(g) (API RP 1162 Section 2.3.1) | Were materials and messages developed and delivered in other languages commonly understood by a significant number and concentration of non-English speaking populations in the operator's areas? |

Inspection Results Report (ALL Non-Empty Results) - Scp_PK 90877 (1919)

| Row | Asset | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------------|--------|----------|----------------------|------------|---------------------------|---|---|
| 146 | (and 1 other asset) | Sat | (2) | MISCTOPICS.PUBAW ARE | 18 | PD.PA.EVALEFFECTIVENESS.R | 192.616(c) (API RP 1162 Section 8.4) | Have effectiveness evaluation(s) of the program been performed for all stakeholder groups in all notification areas along all systems covered by the program? |
| 147 | (and 1 other asset) | NA | (2) | MISCTOPICS.PUBAW ARE | 25 | PD.PA.MSTRMETER.R | 192.616(j) (192.616(h), API RP 1162 Section 2.7 (Step 12), API RP 1162 Section 8.5) | Do records indicate the public awareness program for a master meter or petroleum gas system operator has met the requirements of Part 192? |

1. Result is repeated (N) times in this report due to re-presentation of the question in multiple sub-groups.

Report Parameters: All non-empty Results

Except as required to be disclosed by law, any inspection documentation, including completed protocol forms, summary reports, executive summary reports, and enforcement documentation are for internal use only by federal or state pipeline safety regulators. Some inspection documentation may contain information which the operator considers to be confidential. In addition, supplemental inspection guidance and related documents in the file library are also for internal use only by federal or state pipeline safety regulators (with the exception of documents published in the federal register, such as advisory bulletins). Do not distribute or otherwise disclose such material outside of the state or federal pipeline regulatory organizations. Requests for such information from other government organizations (including, but not limited to, NTSB, GAO, IG, or Congressional Staff) should be referred to PHMSA Headquarters Management.

UTC Standard Inspection Report
 Intrastate Gas Distribution
 RC - State Statutes and Rules
 Records Review and Field Inspections

Inspector and Operator Information

| | | |
|---|--|--|
| Inspection Link 8252 | Inspector - Lead Rukke, Scott | Inspector - Assist |
| Operator Cascade Natural Gas Corporation | Unit CNG- Bremerton District | Records Location - City & State Bremerton |
| Inspection Start Date 09-21-2021 | Inspection Exit Interview Date 09-22-2021 | Engineer Submit Date 09-29-2021 |

Inspection Summary

Inspection Scope and Summary

This is a Unit inspection for the Bremerton District #8252
 Added OQ Form 15 on 4/7/2021

Facilities visited and Total AFOD

3/24-3/26/2021 - field pre-inspection. 3 AFOD days.
 9/16/2021 - reviewed records electronically that would normally have been reviewed in office. 1 AFOD day
 9/17/2021 - reviewed records electronically that would normally have been reviewed in office. 1 AFOD day
 9/20 to 9/23/2021 - in CNG's Bremerton office for records and field. 4 AFOD days
 Exit interview conducted on 8/22/2021

Summary of Significant Findings

No issues noted.

Primary Operator contacts and/or participants

Colby L. Lundstrom
 Manager, Compliance and Operations Programs
 Cascade Natural Gas Corp. | Intermountain Gas Co.
Office: 509-734-4587
Cell: 509-520-0718

Instructions and Ratings Definitions

INSTRUCTIONS

S - Satisfactory

U - Unsatisfactory

Area Of Concern

N/A - Not Applicable (does not apply in this inspection)

N/C - Not Checked/Evaluated (was not inspected during this inspection)

Unanswered Questions

0

INSPECTION RESULTS

Satisfactory Responses

9

Unsatisfactory Responses

0

Area of Concern Responses

0

Not Applicable Responses

8

Not Checked / Evaluated Responses

0

Unanswered Questions List

Satisfactory List

2,3,7,8,9,10,11,15,16,

Unsatisfactory List

Area of Concern List

Not Applicable List

1,4,5,6,12,13,14,17

Not Checked / Evaluated List

**If an item is marked Form a- annual review. U, N/Form a- annual review or N/C, an explanation must be included in this report.

Records, Procedures and Reports

Question #1.

Has the operator provided accurate maps (or updates) of pipelines operating over 250PSIG to specifications developed by the commission and sufficient to meet the needs of first responders?

| Statutory Reference | 1. Result | Q1. Within Scope of this Inspection: | 1. Notes |
|---------------------|----------------|--------------------------------------|--|
| RCW 81.88.080 | Not Applicable | No such requirement existed. | This question exists in updated IA protocols WA.GD.2020.02 (v14.0.0) as RPT.RR.PIPELINEMAPPING.R |

Question #2.

Do records indicate that the operator appropriately addresses discovered mapping errors, including all mapping errors that have resulted in excavation damage?

| Statutory Reference | 2. Result | 2. Notes |
|---------------------|--------------|---|
| WAC 480-93-018 | Satisfactory | OPS 706 Step 5.6. Mapping discrepancies and errors found during leak survey and annual review shall be documented in the compliance tracking software application (e.g. IQGeo, Maximo) and work orders generated in Maximo. |

Question #3.

Do records indicate that the operator's mapping corrections are made in a timely manner and in accordance with the operator's written procedures?

| Statutory Reference | 3. Result | 3. Notes |
|---------------------|--------------|--|
| WAC 480-93-018 | Satisfactory | Leak survey maps indicate that changes were made prior to each new cycle. OPS 706, step 9 allows 180 days to make corrections. No mapping error work orders were reviewed during this inspection. |

Question #4

Do records indicate that the operator has and follows a quality assurance program for monitoring the locating and marking of facilities? Do records show that the operator conducts regular field audits of the performance of locators/contractors and takes action when necessary?

| Reference: | 4. Results | Q4. Within Scope of this Inspection: | 4. Notes |
|--|----------------|--------------------------------------|--|
| Operator Internal Performance Measures; PHMSA State Program Guidelines | Not Applicable | No such requirement existed. | N/A. CNG does not use contract locators. |

Question #5.

Does operator include performance measures in facility locating services contracts with corresponding and meaningful incentives and penalties?

| Statutory Reference | Statutory Reference | Reference: | 5. Result | Q5. Within Scope of this Inspection: | 5. Notes |
|---------------------|---------------------|--------------------------------|----------------|--------------------------------------|--|
| WAC 480-93-007 | WAC 480-93-013 | PHMSA State Program Guidelines | Not Applicable | No such requirement existed. | N/A. CNG does not use contract locators. |

Question #6.

Do operator contracted (or organic) locators address performance problems for persons performing locating services through mechanisms such as re-training, process change, or changes in staffing levels?

| Statutory Reference | Statutory Reference | 6. Result | Q6. Within Scope of this Inspection: | 6. Notes |
|---------------------|---------------------|----------------|--------------------------------------|--|
| WAC 480-93-007 | WAC 480-93-013 | Not Applicable | No such requirement existed. | N/A. CNG does not use contract locators. |

Question #7.

Does the operator periodically review the Operator Qualification plan criteria and methods used to qualify personnel to perform locates?

| Statutory Reference | Statutory Reference | 7. Result | 7. Notes |
|---------------------|---------------------|--------------|--|
| WAC 480-93-007 | WAC 480-93-013 | Satisfactory | OPS 10 Step 10. PLAN EVALUATION Step 10.1. In accordance with 49 CFR Part 192.605(a), (b)(8), Operations Services with assistance from the Safety and Technical Training Department, shall evaluate the Plan's Covered Tasks once each calendar year, not to exceed 15 months. |

Question #8.

Do records indicate that operator locating and excavation practices are in compliance with the requirements for facility owners prescribed by RCW 19.122?

| Statutory Reference | Statutory Reference | 8. Result | 8. Notes |
|---------------------|---------------------|--------------|--|
| RCW 19.122 | WAC 480-93-250 | Satisfactory | CP 836 Line Locating and Marking and CP 835 Damage Prevention cover the requirements of RCW 19.122 |

Question #9.

Are locates made within the required timelines specified within RCW 19.122 (2 full business days)? Examine record sample.

| Statutory Reference | Statutory Reference | 9. Result | 9. Notes |
|---------------------|---------------------|--------------|--|
| RCW 19.122 | WAC 480-93-250 | Satisfactory | CP 836 Step 8.3.5. Complete the locate request no later than two business days after receipt of the locate work order. |

Question #10.

Are locating and excavating personnel properly qualified in accordance with the operator's Operator Qualification plan and with federal and state requirements?

| Statutory Reference | Statutory Reference | 10. Result | 10. Notes |
|---------------------|---------------------|--------------|---|
| WAC 480-93-007 | WAC 480-93-013 | Satisfactory | OQ records were reviewed for the employees performing covered tasks during this inspection. |

Question #11.

Do records indicate that the operator has and follows a procedure for leaks caused by excavation damage near buildings such that the procedure adequately addresses the possibility of multiple leaks and underground migration of gas into nearby buildings/structures?

| Reference: | 11. Result | 11. Notes |
|--|--------------|---|
| PHMSA State Program Guidelines Operator Internal Performance Measures | Satisfactory | OPS 617 Outside Leak Investigation and Grading. A sampling of leak records were reviewed. |

Question #12.

Do the operator's leak records indicate that the operator is conducting detailed leak investigations, evaluations, classification, and remedial action/repair prioritization steps in sufficient detail to ensure compliance with WACs 480-93-185, -186, and -18601?

| Reference: | 12. Result | Q12. Within Scope of this Inspection: | 12. Notes |
|--|----------------|---------------------------------------|---|
| PHMSA State Program Guidelines Operator Internal Performance Measures | Not Applicable | No such requirement existed. | This question exists in updated IA protocols WA.GD.2020.02 (v14.0.0) in questions MO.RW.LEAKREPAIRTIME.R , MO.RW.LEAKFOLLOW.R MO.RW.DOWNGRADELEAKREPAIR.R |

Question #13

Do records indicate that shorted conditions are leak surveyed within ninety (90) days of discovery and twice annually, not to exceed 7.5 months thereafter?

| Statutory Reference | 13. Result | Q13. Within Scope of this Inspection: | 13. Notes |
|---------------------|----------------|---------------------------------------|--|
| WAC 480-93-200 | Not Applicable | No such requirement existed. | This question exists in updated IA protocols WA.GD.2020.02 (v14.0.0) as MO.RW.CASINGLEAKSURVEY.R |

Question #14.

Did the operator submit a copy of DOT Drug and Alcohol Testing MIS Data Collection Form to the commission when required?

| Statutory Reference | 14. Result | Q14. Within Scope of this Inspection: | 14. Notes |
|---------------------|----------------|---------------------------------------|---|
| WAC 480-93-200(13) | Not Applicable | No such requirement existed. | This question exists in updated IA protocols WA.GD.2020.02 (v14.0.0) as RPT.RR.MISDATAREPORTS.R |

Question #15

Does the operator file all appropriate Annual Reports and Material/Failure Analysis reports as required by WAC 480-93-200 no thanter than March 15 for the preceding year?

| Statutory Reference | 15. Result | 15. Notes |
|-----------------------|--------------|--|
| WAC 480-93-200(10)(b) | Satisfactory | Focus on submission of Material/Failure Analysis reports Annual report timeliness is covered by RPT.RR.UTCANNUALREPORTS.R in updated IA protocol revision WA.GD.2020.02(v14.0.0 Updated question should read "Does the operator file all appropriate Material/Failure Analysis reports as required by WAC 480-93-200(10)(b) no later than March 15..." |

Comments - Records, Procedures & Reports

RECORDS REVIEW SUMMARY: Comments are required for any rating other than "Satisfactory". Summarize the "Notes" blocks above, and ensure you annotate the question number for each comment.

All questions were satisfactory except those covered in IA protocols. Those were marked as NOT APPLICABLE.

FIELD INSPECTION OBSERVATIONS

Question #16

Are welding procedures located on site where welding is performed?

Statutory Reference **16. Results** **16. Notes**

WAC 480-93-080(1)(e) Satisfactory On company provided laptops which personnel carry in their vehicles.

Question #17

Is the operator using testing equipment necessary to record and document essential variables during welder and procedure testing/qualifications?

Statutory Reference

WAC 480-93-080(1)(c)

17. Results

Not Applicable

Q17. Within Scope of this

Inspection:

No such requirement existed.

17. Notes

This question exists in updated IA protocols WA.GD.2020.02 (v14.0.0) **DC.WELDPROCEDURE.ESSENTIAL.R**

Comments - Field Observations

FIELD OBSERVATION SUMMARY: Comments are required for any rating other than "Satisfactory". Summarize the "Notes" blocks above, and ensure you annotate the question number for each comment.

All questions were satisfactory except those covered in IA protocols. Those were marked as NOT APPLICABLE.