

Inspection Output (IOR)

Generated on 2022.May.03 16:14

Report Filters

Assets Puget Sound Energy-GIG HARBOR LNG SATELLITE PLANT / 90874 (1609)

Results All

Inspection Information

Inspection Name	8451 Gig Harbor LNG Standard Inspection	Operator(s)	PUGET SOUND ENERGY (22189)	Plan Submitted	04/18/2022
Status	PLANNED	Lead	Derek Norwood	Plan Approval	04/19/2022 by Scott Rukke
Start Year	2022	Team Members	David Cullom, Dennis Ritter, Lex Vinsel, Anthony Dorrough, Scott Anderson, Darren Tinnerstet	All Activity Start	04/25/2022
System Type	LNG	Observer(s)	Deborah Becker, Rell Koizumi	All Activity End	04/27/2022
Protocol Set ID	LNG.2022.01	Supervisor	Scott Rukke	Inspection Submitted	--
		Director	Sean Mayo	Inspection Approval	--

Inspection Summary

Inspection Scope and Summary

2022 PSE Gig Harbor LNG satellite plant inspection. Last inspection was completed in 2020.

The major components of the facility include two 70,000-gallon LNG Storage Tanks, LNG Truck Unloading Station, one 650 MSCFH LNG vaporizer, Send-out Skid with boil-off compressor and odorant injection system, emergency generator, fire protection system, security system, spill impoundment system, and a Multipurpose Building which houses the Control Room, Motor Control Center, and Compressed Air Skid. There is also a storage shelter which houses PSE's portable vaporizer. Provisions have been incorporated in the facility design to allow for operation of the portable vaporizer at the Gig Harbor site.

Facilities visited and Total AFOD

Total AFODs: 3 days

2 days for records review and 1 day for field inspection

Records review completed remotely via Microsoft Teams and Email

Field Inspection completed at the LNG Plant in Gig Harbor, WA

Summary of Significant Findings

(DO NOT Discuss Enforcement options)

There were no probable violations or areas of concern as a result of this inspection

Primary Operator contacts and/or participants

Justin Wahlborg, Compliance Program Manager

