



## PUGET SOUND ENERGY

Puget Sound Energy  
P.O. Box 97034  
Bellevue, WA 98009-9734  
PSE.com

RECEIVED

FEB 09 2013

State of Washington  
UTC  
Pipeline Safety Program

February 9, 2013

David Lykken, Director Pipeline Safety  
Washington Utilities and Transportation Commission  
Pipeline Safety Section  
1300 S. Evergreen Park Drive S.W.  
PO Box 47250  
Olympia, WA 98504-7250

Dear Mr. Lykken,

Enclosed is a "PSE - Incident Report - Telephone Notification" form on which are provided details of an emergency event that occurred on January 11, 2013 in Tacoma, Pierce Co. The event resulted in a release of gas for more than 2 hours and property damage valued at more than fifty thousand dollars.

PSE responded to a report of a natural gas odor by the Tacoma Fire department. Falling demolition debris damaged an underground gas line and resulted in a gas leak.

The Commission was notified of this event at 16:25 on January 11, 2013. Ms. Patti Johnson received the call.

On February 8<sup>th</sup> and following discovery that this event resulted in estimated property damage greater than \$50,000 PSE reported this incident to NRC.

This event resulted in no injuries. The cost of the response and repair associated with this event is estimated to be \$76,000.

Sincerely,

Antoinette Imad  
Consulting Engineer, Compliance

encl.

cc: Cheryl McGrath, Manager of Gas Compliance and Regulatory Audits

## INCIDENT REPORT – TELEPHONE NOTIFICATION

INCIDENT DATE 1/11/13		STATUTORY REPORTING REQUIREMENT Release of Gas for more than 2 Hours		INCIDENT CATEGORY Underground pipe damage	
FIRST NOTICE TO PSE 14:24		FIRST PSE ARRIVAL 14:45	EMERGENCY CONTROLLED 20:30		TIME OF REPAIR <input type="checkbox"/> TEMP 22:15 (1/12/13) <input checked="" type="checkbox"/> PERM
REPORT RECEIVED BY Dispatch			REPORTED BY Tacoma Fire Department		
ADDRESS OF INCIDENT S. Tacoma Way and Sprague St				CITY Tacoma	
DESCRIPTION OF INCIDENT AND RESPONSE <p>Large concrete section of SR-16 (currently under demolition by WSDOT) fell onto pavement at on S. Tacoma way at Sprague intersection. Damaged underground gas line and water main. Underground damage was identified due to odor in area of accident, even though broken main was not exposed and blowing.</p> <p>Isolated damage main section by squeezing 6" STW in 2 places and closing 4" ST valve on branch. Arranged for CNG injection to keep ~12 customers online D/S of valve during main repair process. Final repair completed 11/12 at 10:15 PM.</p> <p>During response, updated Ms. Patti Johnson several times with progress reports, at her request.</p>					
INJURY: NONE <input checked="" type="checkbox"/> PSE <input type="checkbox"/> OTHER <input type="checkbox"/> FATALITY: NONE <input checked="" type="checkbox"/> PSE <input type="checkbox"/> OTHER <input type="checkbox"/>					
NAME		ADDRESS		CITY	
PHONE		INJURY (Describe)			
NAME		ADDRESS		CITY	
PHONE		INJURY (Describe)			
ENVIRONMENTAL IMPACT Bridge section damaged water main and power lines at same location.					
PROPERTY DAMAGE					
PSE FACILITY MAIN: <input type="checkbox"/> TRANS <input type="checkbox"/> SUPPLY <input checked="" type="checkbox"/> DIST SERVICE: <input type="checkbox"/> STUB <input type="checkbox"/> EXTN OP PRESS: 42 MAOP: 45 PIPE SIZE: 4"/6" DEPTH: ~3 ft MATERIAL: STW/PE MSA SIZE: N/A					
CUSTOMER OUTAGE WAC 480-93-200(1)(e)		NUMBER OF OUTAGES 4	TIME OFF 20:30	TIME RELIGHT BEGAN ~22:15 (1/12/13)	
OTHER PSE FACILITY INVOLVED					
MEDIA / AGENCY COVERAGE					
ESTIMATED INCIDENT COST		PSE		OTHER	
<b>REPORTED TO</b>					
NO. 1 AGENCY WUTC		NAME Patti Johnson			
BY J. Wahlborg		DATE 1/11/13		TIME 16:25	
NO. 2 AGENCY		NAME			
BY		DATE		TIME	

ALCOHOL OR DRUG TESTING INITIATED <input type="checkbox"/> YES <input type="checkbox"/> NO		OPERATOR QUALIFICATION REVIEW REQUIRED <input type="checkbox"/> YES <input type="checkbox"/> NO	
SEE ATTACHMENT FOR ADDITIONAL INFORMATION <input type="checkbox"/> YES <input type="checkbox"/> NO		30 DAY FOLLOW UP ENGINEERING REPORT REQUIRED <input type="checkbox"/> YES <input type="checkbox"/> NO	

RECEIVED  
FEB 09 2013

NOTICE: This report is required by 49 CFR Part 191. Failure to report can result in a civil penalty not to exceed 100,000 for each violation for each day that such violation persists except that the maximum civil penalty shall not exceed \$1,000,000 as provided in 49 USC 60122.		OMB NO: 2137-0522 EXPIRATION DATE: 01/31/2014
 U.S Department of Transportation Pipeline and Hazardous Materials Safety Administration	<b>Report Date:</b>	02/08/2013
	<b>No.</b>	20130013- 15601
		(DOT Use Only)

**INCIDENT REPORT - GAS DISTRIBUTION SYSTEM**

A federal agency may not conduct or sponsor, and a person is not required to respond to, nor shall a person be subject to a penalty for failure to comply with a collection of information subject to the requirements of the Paperwork Reduction Act unless that collection of information displays a current valid OMB Control Number. The OMB Control Number for this information collection is 2137-0522. Public reporting for this collection of information is estimated to be approximately 10 hours per response, including the time for reviewing instructions, gathering the data needed, and completing and reviewing the collection of information. All responses to this collection of information are mandatory. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden to: Information Collection Clearance Officer, PHMSA, Office of Pipeline Safety (PHP-30) 1200 New Jersey Avenue, SE, Washington, D.C. 20590.

**INSTRUCTIONS**

*Important: Please read the separate instructions for completing this form before you begin. They clarify the information requested and provide specific examples. If you do not have a copy of the instructions, you can obtain one from the PHMSA Pipeline Safety Community Web Page at <http://www.phmsa.dot.gov/pipeline>.*

**PART A - KEY REPORT INFORMATION**

Report Type: <i>(select all that apply)</i>	Original: Yes	Supplemental:	Final:
Last Revision Date			
1. Operator's OPS-issued Operator Identification Number (OPID):	22189		
2. Name of Operator	PUGET SOUND ENERGY		
3. Address of Operator:			
3a. Street Address	PO BOX 90868		
3b. City	BELLEVUE		
3c. State	Washington		
3d. Zip Code	98009-0868		
4. Local time (24-hr clock) and date of the Incident:	01/11/2013 14:24		
5. Location of Incident:			
5a. Street Address or location description	S Tacoma Way and Sprague St		
5b. City	Tacoma		
5c. County or Parish	Pierce		
5d. State:	Washington		
5e. Zip Code:	98409		
5f. Latitude:	47.232115		
Longitude:	-122.463065		
6. National Response Center Report Number:	1037945		
7. Local time (24-hr clock) and date of initial telephonic report to the National Response Center:	02/08/2013 12:25		
8. Incident resulted from:	Unintentional release of gas		
9. Gas released:	Natural Gas		
- Other Gas Released Name:			
10. Estimated volume of gas released - Thousand Cubic Feet (MCF):			
11. Were there fatalities?	No		
- If Yes, specify the number in each category:			
11a. Operator employees			
11b. Contractor employees working for the Operator			
11c. Non-Operator emergency responders			
11d. Workers working on the right-of-way, but NOT associated with this Operator			
11e. General public			
11f. Total fatalities (sum of above)			
12. Were there injuries requiring inpatient hospitalization?	No		
- If Yes, specify the number in each category:			
12a. Operator employees			
12b. Contractor employees working for the Operator			
12c. Non-Operator emergency responders			
12d. Workers working on the right-of-way, but NOT associated with this Operator			
12e. General public			
12f. Total injuries (sum of above)			
13. Was the pipeline/facility shut down due to the incident?	Yes		
- If No, Explain:			

- If Yes, complete Questions 13a and 13b: (use local time, 24-hr clock)	
13a. Local time and date of shutdown:	01/11/2013 20:30
13b. Local time pipeline/facility restarted:	01/12/2013 22:15
- Still shut down? (* Supplemental Report Required)	
14. Did the gas ignite?	No
15. Did the gas explode?	No
16. Number of general public evacuated:	
17. Time sequence (use local time, 24-hour clock):	
17a. Local time operator identified incident:	01/11/2013 14:24
17b. Local time operator resources arrived on site:	01/11/2013 14:45
<b>PART B - ADDITIONAL LOCATION INFORMATION</b>	
1. Was the Incident on Federal land?	No
2. Location of Incident:	Public property
3. Area of Incident:	Underground
	Specify: Under pavement
	If Other, Describe:
	Depth of Cover:
4. Did Incident occur in a crossing?	No
- If Yes, specify type below:	
- If Bridge crossing –	
	Cased/ Uncased:
- If Railroad crossing –	
	Cased/ Uncased/ Bored/drilled
- If Road crossing –	
	Cased/ Uncased/ Bored/drilled
- If Water crossing –	
	Cased/ Uncased
	Name of body of water (If commonly known):
	Approx. water depth (ft):
<b>PART C - ADDITIONAL FACILITY INFORMATION</b>	
1. Indicate the type of pipeline system:	Natural Gas Distribution, privately owned
	- If Other, specify:
2. Part of system involved in Incident:	Main
	- If Other, specify:
2a. Year "Part of system involved in Incident" was installed:	2007
	Unknown?
3. When "Main" or "Service" is selected as the "Part of system involved in Incident" (from PART C, Question 2), provide the following:	
3a. Nominal diameter of pipe (in):	4
3b. Pipe specification (e.g., API 5L, ASTM D2513):	ASTM D2513
	Unknown?
3c. Pipe manufacturer:	Unknown?
	Yes
3d. Year of manufacture:	Unknown?
	Yes
4. Material involved in Incident:	Plastic
	- If Other, specify:
4a. If Steel, Specify seam type:	None/Unknown?
4b. If Steel, Specify wall thickness (inches):	Unknown?
4c. If Plastic, Specify type:	Polyethylene (PE)
	- If Other, describe:
4d. If Plastic, Specify Standard Dimension Ratio (SDR):	11.5
	Or wall thickness:
	Unknown?
4e. If Polyethylene (PE) is selected as the type of plastic in Part C, Question 4.c:	
	- Specify PE Pipe Material Designation Code (i.e. 2406, 3408, etc.)
	Unknown?
5. Type of release involved :	Leak
	- If Mechanical Puncture - Specify Approx size:
	Approx. size: in. (axial):
	in. (circumferential):
	- If Leak - Select Type:
	Crack
	- If Other, Describe:

- If Rupture - Select Orientation:	
- If Other, Describe:	
Approx. size: (widest opening):	
(length circumferentially or axially):	
- If Other - Describe:	
<b>PART D - ADDITIONAL CONSEQUENCE INFORMATION</b>	
1. Class Location of Incident :	Class 3 Location
2. Estimated Property Damage :	
2a. Estimated cost of public and non-Operator private property damage	\$ 0
2b. Estimated cost of Operator's property damage & repairs	\$ 46,100
2c. Estimated cost of Operator's emergency response	\$ 29,867
2d. Estimated other costs	\$ 0
- Describe:	
2e. Total estimated property damage (sum of above)	\$ 75,967
<b>Cost of Gas Released</b>	
2f. Estimated cost of gas released	\$ 100
3. Estimated number of customers out of service:	
3a. Commercial entities	4
3b. Industrial entities	0
3c. Residences	0
<b>PART E - ADDITIONAL OPERATING INFORMATION</b>	
1. Estimated pressure at the point and time of the Incident (psig):	41.00
2. Normal operating pressure at the point and time of the Incident (psig):	41.00
3. Maximum Allowable Operating Pressure (MAOP) at the point and time of the Incident (psig):	45.00
4. Describe the pressure on the system relating to the Incident:	Pressure did not exceed MAOP
5. Was a Supervisory Control and Data Acquisition (SCADA) based system in place on the pipeline or facility involved in the Incident?	No
- If Yes:	
5a. Was it operating at the time of the Incident?	
5b. Was it fully functional at the time of the Incident?	
5c. Did SCADA-based information (such as alarm(s), alert(s), event(s), and/or volume or pack calculations) assist with the detection of the Incident?	
5d. Did SCADA-based information (such as alarm(s), alert(s), event(s), and/or volume calculations) assist with the confirmation of the Incident?	
6. How was the Incident initially identified for the Operator?	Notification from Emergency Responder
6a. If "Controller", "Local Operating Personnel, including contractors", "Air Patrol", or "Ground Patrol by Operator or its contractor" is selected in Question 6, specify the following:	
- If Other, Specify:	
7. Was an investigation initiated into whether or not the controller(s) or control room issues were the cause of or a contributing factor to the Incident?	No, the Operator did not find that an investigation of the controller(s) actions or control room issues was necessary due to: (provide an explanation for why the Operator did not investigate)
- If No, the operator did not find that an investigation of the controller(s) actions or control room issues was necessary due to: (provide an explanation for why the operator did not investigate)	This incident was caused by falling demolition debris
- If Yes, Specify investigation result(s) (select all that apply):	
- Investigation reviewed work schedule rotations, continuous hours of service (while working for the Operator), and other factors associated with fatigue	
- Investigation did NOT review work schedule rotations, continuous hours of service (while working for the Operator), and other factors associated with fatigue	
- Provide an explanation for why not:	
- Investigation identified no control room issues	
- Investigation identified no controller issues	
- Investigation identified incorrect controller action or controller error	
- Investigation identified that fatigue may have affected the controller(s) involved or impacted the involved controller(s) response	
- Investigation identified incorrect procedures	
- Investigation identified incorrect control room equipment operation	

- Investigation identified maintenance activities that affected control room operations, procedures, and/or controller response	
- Investigation identified areas other than those above	
Describe:	
<b>PART F - DRUG &amp; ALCOHOL TESTING INFORMATION</b>	
1. As a result of this Incident, were any Operator employees tested under the post-accident drug and alcohol testing requirements of DOT's Drug & Alcohol Testing regulations?	No
- If Yes:	
1a. Specify how many were tested:	
1b. Specify how many failed:	
2. As a result of this Incident, were any Operator contractor employees tested under the post-accident drug and alcohol testing requirements of DOT's Drug & Alcohol Testing regulations?	No
- If Yes:	
2a. Specify how many were tested:	
2b. Specify how many failed:	
<b>PART G - CAUSE INFORMATION</b>	
<i>Select only one box from PART G in shaded column on left representing the Apparent Cause of the Incident, and answer the questions on the right. Describe secondary, contributing, or root causes of the Incident in the narrative (PART H).</i>	
<b>Apparent Cause:</b>	G4 - Other Outside Force Damage
<b>G1 - Corrosion Failure</b> – only one sub-cause can be picked from shaded left-hand column	
<b>Corrosion Failure Sub-Cause:</b>	
<b>- If External Corrosion:</b>	
1. Results of visual examination:	
- If Other, Specify:	
2. Type of corrosion:	
- Galvanic	
- Atmospheric	
- Stray Current	
- Microbiological	
- Selective Seam	
- Other	
- If Other, Describe:	
3. The type(s) of corrosion selected in Question 2 is based on the following:	
- Field examination	
- Determined by metallurgical analysis	
- Other	
- If Other, Describe:	
4. Was the failed item buried under the ground?	
- If Yes:	
4a. Was failed item considered to be under cathodic protection at the time of the incident?	
- If Yes, Year protection started:	
4b. Was shielding, tenting, or disbonding of coating evident at the point of the incident?	
4c. Has one or more Cathodic Protection Survey been conducted at the point of the incident?	
If "Yes, CP Annual Survey" – Most recent year conducted:	
If "Yes, Close Interval Survey" – Most recent year conducted:	
If "Yes, Other CP Survey" – Most recent year conducted:	
- If No:	
4d. Was the failed item externally coated or painted?	
5. Was there observable damage to the coating or paint in the vicinity of the corrosion?	
6. Pipeline coating type, if steel pipe is involved:	
- If Other, Describe:	
<b>- If Internal Corrosion:</b>	
7. Results of visual examination:	
- If Other, Describe:	
8. Cause of corrosion ( <i>select all that apply</i> ):	
- Corrosive Commodity	

- Water drop-out/Acid	
- Microbiological	
- Erosion	
- Other	
- If Other, Specify:	
9. The cause(s) of corrosion selected in Question 8 is based on the following: <i>(select all that apply)</i> :	
- Field examination	
- Determined by metallurgical analysis	
- Other	
- If Other, Describe:	
10. Location of corrosion <i>(select all that apply)</i> :	
- Low point in pipe	
- Elbow	
- Drop-out	
- Other	
- If Other, Describe:	
11. Was the gas/fluid treated with corrosion inhibitor or biocides?	
12. Were any liquids found in the distribution system where the Incident occurred?	
<b>Complete the following if any Corrosion Failure sub-cause is selected AND the "Part of system involved in incident" (from PART C, Question 2) is Main, Service, or Service Riser.</b>	
13. Date of the most recent Leak Survey conducted	
14. Has one or more pressure test been conducted since original construction at the point of the Incident?	
- If Yes:	
Most recent year tested:	
Test pressure:	
<b>G2 – Natural Force Damage – only one sub-cause can be picked from shaded left-handed column</b>	
<b>Natural Force Damage – Sub-Cause:</b>	
<b>- If Earth Movement, NOT due to Heavy Rains/Floods:</b>	
1. Specify:	
- If Other, Specify:	
<b>- If Heavy Rains/Floods:</b>	
2. Specify:	
- If Other, Specify:	
<b>- If Lightning:</b>	
3. Specify:	
<b>- If Temperature:</b>	
4. Specify:	
- If Other, Specify:	
<b>- If High Winds:</b>	
<b>- Other Natural Force Damage:</b>	
5. Describe:	
<b>Complete the following if any Natural Force Damage sub-cause is selected.</b>	
6. Were the natural forces causing the Incident generated in conjunction with an extreme weather event?	
6.a If Yes, specify <i>(select all that apply)</i> :	
- Hurricane	
- Tropical Storm	
- Tornado	
- Other	
- If Other, Specify:	
<b>G3 – Excavation Damage – only one sub-cause can be picked from shaded left-hand column</b>	
<b>Excavation Damage – Sub-Cause:</b>	
<b>- If Excavation Damage by Operator (First Party):</b>	
<b>- If Excavation Damage by Operator's Contractor (Second Party):</b>	
<b>- If Excavation Damage by Third Party:</b>	
<b>- If Previous Damage due to Excavation Activity:</b>	

<b>Complete the following ONLY IF the "Part of system involved in Incident" (from Part C, Question 2) is Main, Service, or Service Riser.</b>	
1. Date of the most recent Leak Survey conducted	
2. Has one or more pressure test been conducted since original construction at the point of the Incident?	
- If Yes:	
Most recent year tested:	
Test pressure:	
<b>Complete the following if Excavation Damage by Third Party is selected.</b>	
3. Did the operator get prior notification of the excavation activity?	
3a. If Yes, Notification received from: <i>(select all that apply)</i> :	
- One-Call System	
- Excavator	
- Contractor	
- Landowner	
<b>Complete the following mandatory CGA-DIRT Program questions if any Excavation Damage sub-cause is selected.</b>	
4. Do you want PHMSA to upload the following information to CGA-DIRT ( <a href="http://www.cga-dirt.com">www.cga-dirt.com</a> )?	
5. Right-of-Way where event occurred <i>(select all that apply)</i> :	
- Public	
- If Public, Specify:	
- Private	
- If Private, Specify:	
- Pipeline Property/Easement	
- Power/Transmission Line	
- Railroad	
- Dedicated Public Utility Easement	
- Federal Land	
- Data not collected	
- Unknown/Other	
6. Type of excavator :	
7. Type of excavation equipment :	
8. Type of work performed :	
9. Was the One-Call Center notified?	
9a. If Yes, specify ticket number:	
9b. If this is a State where more than a single One-Call Center exists, list the name of the One-Call Center notified:	
10. Type of Locator:	
11. Were facility locate marks visible in the area of excavation?	
12. Were facilities marked correctly?	
13. Did the damage cause an interruption in service?	
13a. If Yes, specify duration of the interruption:	
14. Description of the CGA-DIRT Root Cause <i>(select only the one predominant first level CGA-DIRT Root Cause and then, where available as a choice, the one predominant second level CGA-DIRT Root Cause as well)</i> :	
- Root Cause Description:	
- If One-Call Notification Practices Not Sufficient, specify:	
- If Locating Practices Not Sufficient, specify:	
- If Excavation Practices Not Sufficient, specify:	
- If Other/None of the Above (explain), specify:	
<b>G4 - Other Outside Force Damage - only one sub-cause can be selected from the shaded left-hand column</b>	
<b>Other Outside Force Damage – Sub-Cause:</b>	<b>Other Outside Force Damage</b>
<b>- If Nearby Industrial, Man-made, or Other Fire/Explosion as Primary Cause of Incident:</b>	
<b>- If Damage by Car, Truck, or Other Motorized Vehicle/Equipment NOT Engaged in Excavation:</b>	
1. Vehicle/Equipment operated by:	
<b>- If Damage by Boats, Barges, Drilling Rigs, or Other Maritime Equipment or Vessels Set Adrift or Which Have Otherwise Lost Their Mooring:</b>	
2. Select one or more of the following IF an extreme weather event was a factor:	
- Hurricane	
- Tropical Storm	
- Tornado	
- Heavy Rains/Flood	

- Other	
- If Other, Specify:	
<b>- If Routine or Normal Fishing or Other Maritime Activity NOT Engaged in Excavation:</b>	
<b>- If Electrical Arcing from Other Equipment or Facility:</b>	
<b>- If Previous Mechanical Damage NOT Related to Excavation:</b>	
<i>Complete the following ONLY IF the "Part of system involved in Incident" (from Part C, Question 2) is Main, Service, or Service Riser.</i>	
3. Date of the most recent Leak Survey conducted:	
4. Has one or more pressure test been conducted since original construction at the point of the Incident?	
- If Yes:	
	Most recent year tested:
	Test pressure (psig):
<b>- If Intentional Damage:</b>	
5. Specify:	
	- If Other, Specify:
<b>- If Other Outside Force Damage:</b>	
6. Describe:	Falling construction debris from elevated roadway demolition
<b>G5 - Pipe, Weld, or Joint Failure</b> - only one sub-cause can be selected from the shaded left-hand column	
<b>Pipe, Weld or Joint Failure – Sub-Cause:</b>	
<b>- If Body of Pipe:</b>	
1. Specify:	
	- If Other, Describe:
<b>- If Butt Weld:</b>	
2. Specify:	
	- If Other, Describe:
<b>- If Fillet Weld:</b>	
3. Specify:	
	- If Other, Describe:
<b>- If Pipe Seam:</b>	
4. Specify:	
	- If Other, Describe:
<b>- If Threaded Metallic Pipe:</b>	
<b>- If Mechanical Fitting:</b>	
5. Specify the mechanical fitting involved:	
	- If Other, Describe:
6. Specify the type of mechanical fitting:	
	- If Other, Describe:
7. Manufacturer:	
8. Year manufactured:	
9. Year Installed:	
10. Other attributes:	
11. Specify the two materials being joined:	
11a. First material being jointed:	
	- Steel
	- Cast/Wrought Iron
	- Ductile Iron
	- Copper
	- Plastic
	- Unknown
	- Other
	- If Other, Specify:
11b. If Plastic, specify:	
	- If Other Plastic, specify:
11c. Second material being joined:	
	- Steel
	- Cast/Wrought Iron
	- Ductile Iron
	- Copper
	- Plastic

- Unknown	
- Other	
	- If Other, Specify:
11d. If Plastic, specify:	
	- If Other Plastic, Specify:
12. If used on plastic pipe, did the fitting – as designed by the manufacturer – include restraint?	
12a. If Yes, specify:	
<b>- If Compression Fitting:</b>	
13. Fitting type:	
14. Manufacturer:	
15. Year manufactured:	
16. Year installed:	
17. Other attributes:	
18. Specify the two materials being joined:	
18a. First material being joined:	
- Steel	
- Cast/Wrought Iron	
- Ductile Iron	
- Copper	
- Plastic	
- Unknown	
- Other	
	- If Other, specify:
18b. If Plastic, specify:	
	- If Other Plastic, specify:
18c. Second material being joined:	
- Steel	
- Cast/Wrought Iron	
- Ductile Iron	
- Copper	
- Plastic	
- Unknown	
- Other	
	If Other, specify:
18d. If Plastic, specify:	
	- Other Plastic, specify:
<b>- If Fusion Joint:</b>	
19. Specify:	
	- If Other, Specify:
20. Year installed:	
21. Other attributes:	
22. Specify the two materials being joined:	
22a. First material being joined:	
	- If Other, Specify:
22b. Second material being joined:	
	- If Other, Specify:
<b>- If Other Pipe, Weld, or Joint Failure:</b>	
23. Describe:	
<b>Complete the following if any Pipe, Weld, or Joint Failure sub-cause is selected.</b>	
24. Additional Factors ( <i>select all that apply</i> ):	
- Dent	
- Gouge	
- Pipe Bend	
- Arc Burn	
- Crack	
- Lack of Fusion	
- Lamination	
- Buckle	
- Wrinkle	
- Misalignment	
- Burnt Steel	
- Other	
25. Was the Incident a result of:	
- Construction defect	
	Specify:
- Material defect	

	Specify:	
	- If Other, Specify:	
	- Design defect	
	- Previous damage	
26. Has one or more pressure test been conducted since original construction at the point of the Incident?		
	- If Yes:	
	Most recent year tested:	
	Test pressure:	
<b>G6 - Equipment Failure</b> - only one sub-cause can be selected from the shaded left-hand column		
<b>Equipment Failure – Sub-Cause:</b>		
<b>- If Malfunction of Control/Relief Equipment:</b>		
1. Specify:		
	- Control Valve	
	- Instrumentation	
	- SCADA	
	- Communications	
	- Block Valve	
	- Check Valve	
	- Relief Valve	
	- Power Failure	
	- Stopple/Control Fitting	
	- Pressure Regulator	
	- Other	
	- If Other, Specify:	
<b>- If Threaded Connection Failure:</b>		
2. Specify:		
	- If Other, Specify:	
<b>- If Non-threaded Connection Failure:</b>		
3. Specify:		
	- If Other, Specify:	
<b>- If Valve:</b>		
4. Specify:		
	- If Other, Specify:	
	4a. Valve type:	
	4b. Manufactured by:	
	4c. Year manufactured:	
<b>- If Other Equipment Failure:</b>		
5. Describe:		
<b>G7 - Incorrect Operation</b> - only one sub-cause can be selected from the shaded left-hand column		
<b>Incorrect Operation Sub-Cause:</b>		
<b>- If Damage by Operator or Operator's Contractor NOT Related to Excavation and NOT due to Motorized Vehicle/Equipment Damage:</b>		
<b>- If Valve Left or Placed in Wrong Position, but NOT Resulting in an Overpressure:</b>		
<b>- If Pipeline or Equipment Overpressured:</b>		
<b>- If Equipment Not Installed Properly:</b>		
<b>- If Wrong Equipment Specified or Installed:</b>		
<b>- If "Other Incorrect Operation:</b>		
1. Describe:		
<b>Complete the following if any Incorrect Operation sub-cause is selected.</b>		
2. Was this Incident related to: (select all that apply)		
	- Inadequate procedure	
	- No procedure established	
	- Failure to follow procedure	
	- Other	
	- If Other, Describe:	
3. What category type was the activity that caused the Incident:		
4. Was the task(s) that led to the Incident identified as a covered task in your		

Operator Qualification Program?			
4a. If Yes, were the individuals performing the task(s) qualified for the task(s)?			
<b>G8 - Other Incident Cause</b> - only one sub-cause can be selected from the shaded left-hand column			
<b>Other Incident Cause – Sub-Cause:</b>			
<b>- If Miscellaneous:</b>			
1. Describe:			
<b>- If Unknown:</b>			
2. Specify:			
<b>PART H - NARRATIVE DESCRIPTION OF THE INCIDENT</b>			
<p>On January 1st, 2013, a large concrete section of SR-16 under demolition by WSDOT at the time, fell onto the pavement at the intersection of S. Tacoma way and Sprague Street. As a result, a leak occurred on an underground gas line at this location. The event was reported to the Washington Utilities and Transportation Commission for a gas release exceeding 2 hours.</p> <p>On February 8th and at about 12:00pm, following a review of the cost of this incident, PSE discovered that the cost of this event exceeded \$50,000 and telephonically reported it to NRC.</p>			
<table border="1"> <tr> <td><b>File Full Name</b> Note: The users have to sign in to view the attachment if there is no current user session.</td> </tr> <tr> <td> </td> </tr> </table>		<b>File Full Name</b> Note: The users have to sign in to view the attachment if there is no current user session.	
<b>File Full Name</b> Note: The users have to sign in to view the attachment if there is no current user session.			
<b>PART I - PREPARER AND AUTHORIZED SIGNATURE</b>			
Preparer's Name	Antoinette Imad		
Preparer's Title	Consulting Engineer		
Preparer's Telephone Number	425 213 6219		
Preparer's E-mail Address	Antoinette.Imad@pse.com		
Preparer's Facsimile Number	425 462 3770		
Authorized Signature			
Authorize Signature's Name	Cheryl McGrath		
Authorized Signature's Title	Manager Compliance and Regulatory Audits - Gas		
Authorized Signature Telephone Number	425 462 3207		
Authorized Signature's Email Address	Cheryl.McGrath@pse.com		
Date	02/08/2013		