

FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

NOTES-FIELD INSPECTION

Company: Northwest Natural Gas

Date(s): April 6, 8-9, 2015

Unit: Clark County, WA

Field Readings									
Line & Location	Line		CP Volts		Rectifier		Pressures		Remarks
	Size	In.	P/S	Casing	Volts	Amps	Set	Actual	
4/6/14 Bridge Patrol									
NW 269 th @ Gcc Creek, Ridgefield	3.5"								3.5" steel inside casing hung under bridge. Techs not OQ'd to take CP. Checked OQ for bridge patrols, leak survey. Tech checked for leaks at each location. No issues identified
NW Heron Dr @ Gee Creek Ridgefield	4"								4" steel on hangers. Wax wrap. No issues.
Private Dr. @ Gee Creek, Ridgefield	2"								2" steel, wax wrap hung on bridge. Steel on bridge, PE service. No issues.
NW 36 th Ave @ Salmon Creek	4"								4" steel FBE. Corrosion under insulators at hanger roller. North end at air/soil interface, no wrap or tape. Possible corrosion issue. NWN to repair this crossing this summer. New hangers, new epoxy. This is an AOC.
NE 50 th Ave @ Salmon Creek	4"								4" steel "lilycoat". Black epoxy? 54 mls thick. On hangers. No issues.

FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

NE 88 th @ Fifth Plain Creek	4"								4" Steel, FBE PO 42493, 0.188 wall, X42 No issues
87 th @ Burnt Bridge Creek	4"								4" steel, wax wrap. No issues
NE Hazel Dell Ave @ BNRR	4"								4" steel, wax wrap. Hung on bridge, over BNRR. No issues. Re wrapped in 2011
4/9/15 Regulators									
1-003-025 Felida Gate 5207 NW McCann Rd.							225 180 245 220	218 176 245 No L/U	Run 1-RA Run 2-RB Relief-RC By pass Note this station remotely controlled by gas control Operated all inlet/outlet valves for each run. No issues noted
1-012-023-G-01 W. Vancouver Gate							510 490 227 252 227	510 485 227 252 227	Run 1-RA Run 2-RB Run 3-RC Relief 1 Relief 2 Operated all inlet/outlet valves for each run. No issues noted
1-015-028-M-09 1830 W 16TH ST, Vancouver, WA Industrial meter set							122 15 15 502	120 15 14 15	1 st stage 2 nd stage bypass Inlet/outlet Northwest Packing Filter OK No issues noted
1-020-047-M-01 SEH America/HP 18110 SE 34th Street Vancouver							7 5 45	6 5 5	Run 1 Run 2 Inlet/outlet SHE America

