



Targa Sound Terminal LLC  
2628 Marine View Drive  
Tacoma WA 98422  
www.targaresources.com

January 20, 2016

Mr. Alan E. Rathbun  
Pipeline Safety Director  
Utilities and Transportation Commission  
1300 S. Evergreen Park Drive S.W.  
Olympia, WA 98504

**RE: Targa Sound Terminal LLC  
2015 Hazardous Liquid Standard Inspection  
Inspection No. 6207  
Notice of Violation Response**

RECEIVED  
JAN 20 2016  
State of Washington  
UTC  
Pipeline Safety Program

Dear Mr. Rathbun:

Targa Sound Terminal LLC (Targa) received your letter dated December 10, 2015, regarding a Hazardous Liquid Standard Inspection that was conducted by the UTC on November 4, 2015. This letter is intended to provide the response required by your letter in regards to a listed finding from the November inspection. Targa's response to the findings stated in your December 10, 2015 letter is as follows:

- 1. UTC Observation:** 49 CFR 195.428 Overpressure safety devices and overfill protection systems – Targa personnel were unable to produce a record indicating that the overfill protection system for Targa's breakout tank was tested in 2014.

**Targa Response:** Targa remains confident that the breakout tank was maintained in a manner that would have prevented an overfill condition. However Targa agrees with the finding from the November 4 inspection and cannot provide a copy of the record in question.

Between Targa's demonstration of compliance for 2015 and the use of our compliance tracking software systems, Targa is confident that continued compliance with the requirements of 195.428 will be maintained. Targa requests that no further action be needed to rectify this issue.

If you have any questions regarding this information, please feel free to contact me.

Sincerely,

A handwritten signature in blue ink, appearing to read 'M. Kolata'.

Matthew Kolata  
Environmental Specialist  
253-579-1947  
mkolata@targaresources.com