

July 20, 2016

Re: 2016 Natural Gas Standard Inspection – Weyerhaeuser Longview

Alan Rathbun  
Pipeline Safety Director  
Washington Utilities and Transportation Commission  
1300 S. Evergreen Park Dr. SW  
Olympia WA, 98504-7250


**RECEIVED**  
**JUL 25 2016**  
**WASH. UT. & TP. COMM**

Dear Mr. Rathbun:

Please find attached the Weyerhaeuser Longview response to the 2016 Natural Gas Standard Inspection.

Should you have any questions please do not hesitate to contact us directly.

Sincerely,



Andrew Cooper  
Vice President/Mill Manager  
Longview Operations  
Weyerhaeuser Company

cc Cosentino Consulting Inc.  
Pipeline facility files

## Response to 2016 Natural Gas Standard Inspection – Weyerhaeuser Longview

### Probable Violations

#### 1. 49 CFR §192.615 Emergency Plans

*(b) Each operator shall:*

*(2) Train the appropriate operating personnel to assure that they are knowledgeable of the emergency procedures and verify that the training is effective.*

#### **Finding(s):**

A records review revealed that Weyerhaeuser could not provide documentation to support any emergency procedure training, or verification of the effectiveness of any emergency procedure training, i.e. run tables or drills since the last audit.

#### **Response(s):**

- a. Weyerhaeuser will schedule emergency procedure training to be completed in 2016
- b. Weyerhaeuser has added the training to its reoccurring pipeline activities schedule.