

INCIDENT

Incident ID	2468	1523
Company Name	Olympic Pipe Line Company	
Facility Name	Olympic Pipe Line - North	
Address	2319 Lind Ave SW	
Reported by	Teresa Malone	
Received Report	Scott Rukke	
NRC#	1010163	
Investigator	Scott Rukke	
City	Renton	
County	King	
Non-Jurisdictional	<input type="checkbox"/>	
State Reportable	<input type="checkbox"/>	
Federal Reportable	<input checked="" type="checkbox"/>	

FORM NAVIGATION

Add Incident
Update Incident
Save Incident
Print Incident
Main Menu

Report Date and Time	4/30/2012	7:09 PM	Safety-Related?	No	Fire	No	No of Fatalities	0
Incident Date and Time	4/30/2012	5:45 PM	Outage Dur. (hrs)		Water Pollution	No	No. of Injuries	0
Gas/Liquid Controlled Date, Time	4/30/2012		DOP (min)		Line Type	Transmission	No. of Customers	0
Personnel On Site Date and Time	4/30/2012		Diameter of Line		Peak Pressure			
30 Day Report Received					MOP/MAOP			
30 Day Report Received Date					Volume Lost (gal)			
Property Damage	Unknown				OP at failure			
Property Damage \$	\$0.00							

Information

Call placed to Teresa Malone asking for size, MOP, actual pressures prior to release, and material that leaked. 5/3/2012 SR
 Call placed to Kurt Hyashida(?) at [REDACTED] . 8.7.2013. Kurt will get additional information on what materials failed. SR
 Response from Kurt:

Scott,

Here's the follow up on the inquiry that you made today on the April 30, 2012 spill at Renton Station. From our internal reporting tool, I pulled the report that puts the spill at 2.52 gallons to our containment system (not to the soil). The leak was from a threaded connection to the nipple that connects to a thermal relief valve that was replaced the previous month. We suspect that the thread sealant may have failed since we could find no evidence of damage to either sets of threads and that the fact that the relief valve had been in place without leaking for several weeks. We replaced the entire nipple and thermal relief valve set. We also change out the thread sealant that the vendor recommended for the application.

Let me know if you have any further questions. I'm off Thursday and Friday, but will be in the office on Monday.

Thanks,
 Kurt

Olympic Pipeline reported at 7:09 PM on April 30, 2012, that at 5:45 PM, an employee noticed an above ground pump flange dripping diesel oil. Approximately 10 gallons leaked into the dirt and gravel below the flange.