

RECEIVED

OCT 28 2013

WASH. UT. & TP. COMM

October 24, 2013

re: 2013 Natural Gas Standard Inspection – Cardinal Glass

David Lykken
Pipeline Safety Director
Washington Utilities and Transportation Commission
1300 S. Evergreen Park Dr. SW
Olympia WA, 98504-7250

Dear Mr. Lykken:

Please find attached the Cardinal Glass response to the 2013 Natural Gas Standard Inspection.

Should you have any questions please do not hesitate to contact us directly.

Sincerely,



Steve Smith
Plant Manager
Cardinal Pacific FG

cc Cosentino Consulting Inc.
Pipeline facility files

Response to 2013 Natural Gas Standard Inspection – Cardinal Glass

WAC 480-93-179 Tests And Reports For Gas Pipelines

(10) Pressure testing equipment must be maintained, tested for accuracy, or calibrated, in accordance with the manufacturer's recommendations. When there are no manufacturer's recommendations, then pressure testing equipment must be tested for accuracy at an appropriate schedule determined by the gas pipeline company. Test equipment must be tagged with the calibration or accuracy check expiration date. The requirements of this section also apply to equipment such as pressure charts, gauges, dead weights or other devices used to test, monitor or check system pressures or set-points

Finding(s):

Cardinal failed to tag pressure gauges used to monitor or check pressures with the calibration or accuracy check expiration date.

Response(s):

Cardinal will place calibration tags on all installed gauges used as pressure indicators in the facilities jurisdictional gas systems.