OPTIONAL FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

NOTES-FIELD INSPECTION

Company: Georgia Pacific **Field Inspection Date(s):** December 3, 2014

Unit: Camas

Field Readings									
Line & Location	Line		CP Volts		Rectifier		Pressures		Remarks
	Size	In.	P/S	Casing	Volts	Amps	Set	Actual	
Camas GP Gate Station	10”		-1.107v						Taken at E-valve #1
Williams inlet	4”		-1.394v						To show isolation
NWN	4”		-1.110v						To show isolation
Rectifier in yard			-1.45v		1.06v	0.7 (shunted)			
“ “ “			-0.970						Instant off