

FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

NOTES-FIELD INSPECTION

Company: Cascade Natural Gas Corporation

Date(s): August 27, 2014

Unit: Aberdeen District

Field Readings									
Line & Location	Line		CP Volts(Vdc)		Rectifier		Pressures (PSIG)		Remarks
	Size	In.	P/S	Casing	Volts(dc)	Amps	Set	Actual	
Shelton Springs Rd at Island Lake Rd - Shelton									
R-16 – Stand By							35	35.4	Atmospheric/Corrosion - OK
R-16 – Relief Valve							46	46.3	
Deegan Rd at Shelton Gate Station - Shelton									
R-55 – Stand By							350	349.6	Atmospheric/Corrosion - OK
R-55 - Relief							360	361.0	
Oakhurst Dr. W of Stamper Rd - Elma									
R-60 – Stand By							20	19.8	Atmospheric/Corrosion - OK
R-60 - Relief							28	27.8	
Ash Rd W of 7 th St - Elma									
R-42 – Stand By							20	20.3	Atmospheric/Corrosion - OK
R-42 - Relief							31	31.0	
V-67									Exercise Valve - OK
313 7 th St - Hoquiam									
Meter 585195			-1.229						
Idle riser in alley between 7 th &			-1.388						

