

FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

Page: ____ of ____

NOTES-FIELD INSPECTION

Company: Swissport Fueling Inc.

Date(s): June 3, 2014

Unit: Seattle--SeaTac Airport

Field Readings									
Line & Location	Line		CP Volts		Rectifier		Pressures		Remarks
	Size	In.	P/S	Casing	Volts	Amps	Set	Actual	
OPL upstream Pressure @ bypass								38 psig	Fixed mount gauge
Rectifier					67.9	7.1			Taps C3 F5 Shunt Factor = .5 The multimeter calibration date for #12638 was 3/19/14. Josh Reyes took all readings.
Reference Cell #1			-916 mV CSE						
Reference Cell #2			-1583 mV CSE						
T-115 Inlet			-3226 mV CSE						
OPL 12 to 8inch bypass test site			-2404 mV CSE						

FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

Page: ____ of ____
