

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

A completed **Standard Inspection Checklist, OQ Field Validation Protocol form and Cover Letter/Field Report** are to be submitted to the Chief Engineer within **30 days** from completion of the inspection.

Inspection Report			
Inspection ID/Docket Number	5850		
Inspector Name & Submit Date	Dennis Ritter, 7/09/2014, resubmit 7/28/2014		
Chief Eng Name & Review/Date	Joe Subsits		
Operator Information			
Name of Operator:	Puget Sound Energy	OP ID #:	22189
Name of Unit(s):	Thurston-Lewis		
Records Location:	Tacoma, Bellevue, Georgetown (Seattle), Lakewood		
Date(s) of Last (unit) Inspection:	November 8 – December 2, 2011	Inspection Date(s):	June 2-6, 9-13, 26, 2014

Inspection Summary:	<p>The 2014 Std Inspection for PSE Thurston-Lewis Unit was conducted in Thurston and Lewis Counties. Records were also reviewed in Pierce and King County on the dates noted above. An exit interview was held at PSE’s office in Bellevue on June 27, 2014.</p> <p>Field inspections locations are as noted in the inspection form. Records were reviewed at PSE’s Tacoma and Georgetown Operating Bases, PSE Headquarters in Bellevue and leak records were reviewed in Lakewood (Infrasource Operating Base). Additionally, some records were reviewed at WUTC’s office prior to field visit. Field and OQ assessments were conducted as follows: CP pipe to soil, isolation, casings, and rectifier inspections; bridge and steep slope patrols; pressure regulator and relief lock-up ; block valve operation; odorizer station check, odorant concentration testing:</p> <p>9-Regulator stations and associated valves 6-Odorant Level (Sniff) testing 2-Odorant station 9-Rectifiers- 1-casing 2-isolation test point 10-bridge patrols 1-flood patrol 1-steep slope 7 construction projects were reviewed: 109065177-Bare steel replacement Centralia, WA 109072319-RS replacement 918 Coal Creek Rd. Chehalis, WA 109065039-4” PE—Dupont Replacement, Lacey WA 109055321-8” MPE replacement Chehalis WA 106261754-7513 Cooper Point Olympia WA 106256339-102 Crimson Ct. SE Rainier WA 106253116-1712 Capitol Way S Olympia WA</p> <p>The inspection revealed the following potential issues: 164) <u>§192.739 Pressure limiting and regulating stations: Inspection and testing</u> (a) <i>Each pressure limiting station, relief device (except rupture discs), and Pressure regulating station and its equipment must be subjected at intervals not exceeding 15 months, but at least once each calendar year, to inspections and tests to determine that it is-</i></p> <p>(1) <i>In good mechanical condition;</i> (2) <i>Adequate from the standpoint of capacity and reliability of operation for the service in which it is employed;</i> (3) <i>Except as provided in paragraph (b) of this section, set to control or relieve at the correct pressure consistent with the pressure limits of §192.201(a); and</i></p>		
----------------------------	---	--	--

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Inspection Summary:

(4) *Properly installed and protected from dirt, liquids, or other conditions that might prevent proper operation.*

RS 313 (district regulator) Lacey WA: records showed this regulator was not able to be inspected per PSE procedures in 2013 as outlet equipment valve was inoperable. Run 1 stage 2 could not be isolated to perform the required annual maintenance. Annual maintenance was not completed as a result. PSE is aware of this and have implemented plans to replace the station. PSE expects it to be completed by late 2014.

§192.481 Atmospheric corrosion control: Monitoring

(a) *Each operator must inspect each pipeline or portion of pipeline that is exposed to the atmosphere for evidence of atmospheric corrosion, as follows:*

If the pipeline is located: Then the frequency of inspection is:

Onshore At least once every 3 calendar years, but with intervals not exceeding 39 months

Offshore At least once each calendar year, but with intervals not exceeding 15 months

(b) *During inspections the operator must give particular attention to pipe at soil-to-air interfaces, under thermal insulation, under disbonded coatings, at pipe supports, in splash zones, at deck penetrations, and in spans over water.*

(c) *If atmospheric corrosion is found during an inspection, the operator must provide protection against the corrosion as required by Sec. 192.479.*

During the inspection, atmospheric corrosion was noted at 4 separate sites: Steam Plant meter set, Olympia WA, Sears meter set, Lacey WA, Crown Cork and Seal meter set, Olympia WA and commercial meter set in alley at 4th and Washington, Olympia WA. As of the time of the exit interview, PSE had sent personnel to inspect two these sites. At the Steam Plant location crews found corrosion, wire brushed the corrosion area and painted the bare steel. They then recommended the concrete around the riser be removed and the pipe properly wrapped (currently its not wrapped); At the Sears meter set, crews rated this a SAI4 (most imminent threat). At the meter set in the alley, crews unwrapped the riser pipe and it started leaking. At the Crown Cork meter set, corrosion was evident at the soil to air interface, however, crews had not yet rated. All four of these were commercial/industrial meters with the corrosion occurring at the soil/air interface. There seemed to be some confusion during the inspection as to who is responsible for these facilities, as all of them involved an industrial/commercial meter set. In some instances, PSE's leak survey contractor would be responsible, in other such as hard to reach locations, PSE personnel are responsible. This must be clarified in PSE's procedures and/or standards as currently, in the instances noted, it is clearly not getting done.

165) §192.743 Pressure limiting and regulating stations: Capacity of relief devices

(a) *Pressure relief devices at pressure limiting stations and pressure regulating stations must have sufficient capacity to protect the facilities to which they are connected. Except as provided in §192.739(b), the capacity must be consistent with the pressure limits of §192.201(a). This capacity must be determined at intervals not exceeding 15 months, but at least once each calendar year, by testing the devices in place or by review and calculations*

(c) *If a relief device is of insufficient capacity, a new or additional device must be installed to provide the capacity required by paragraph (a) of this section.*

Records inspection showed that for 2012, RS 248 and 249 (Centralia WA) did not have a finalized capacity analyses completed. The engineer believed these stations were to be replaced in 2012. They were not replaced. Additionally, the analysis for RS 248 indicated it was not sufficient to provide necessary relief capacity to prevent over pressuring the pipeline. The code requires that a "new or additional device must be installed to provide the capacity." The code does not state when this needs to occur, however, PSE first calculated this deficiency in 2002.

There are two areas of concern:

- 1) PSE indicated that 2012 RS 248 and RS 249 relief capacity analyses did not get finalized, ie the records were not completed, because the engineer believed the stations would be retired in 2012. However these stations were not retired. The note in the database caused confusion and the records were incomplete. This should be evaluated by PSE to ensure it does not occur in the future.
- 2) Crown Cork and Seal meter set/RS 258, Olympia WA. The risers at the Crown Cork showed some evidence of corrosion, however, not nearly as bad as the two PSE facilities noted above. The 2013 S&A 3-yr atmospheric corrosion survey did not note any issue, nor did the annual RS 258 maintenance log. However, given that these risers are not wrapped and are located in an area which appears to be visited by landscapers using "weed eaters" PSE may want to consider ensuring that these high pressure risers are part of the annual regulator maintenance

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Inspection Summary:
inspection. Currently, it is unclear whether pressure control looks at these gas facilities as they are outside of the fenced compound.

The following should be noted in subsequent inspections:
The pipelines, 8-inch high pressure and a 6-inch intermediate pressure, cross adjacent to 5th Ave on a catwalk over the Capital Lake outlet. This is a hard to reach location. These pipelines are not sitting on the rollers. It would seem earth movement has pushed the pipelines inward and bowed them up off the rollers, especially the HP 8-inch. PSE produced engineering analyses showing the pipelines, especially the HP 8-inch, are integrally safe and the movement has stopped. They monitor this condition with their PI inspectors during bridge patrols. **Future inspections should continue to evaluate this situation.**

The Form 13 PHMSA Drug and Alcohol questionnaire was completed and posted under the CY2014 PSE-Pierce Co inspection. DDL

HQ Address: 355 110th Ave. NE Bellevue, WA 98004	System/Unit Name & Address: Tacoma Office (Pierce County) 3130 S 38 th Tacoma, WA 98409
Co. Official: Booga K. Gilbertson Phone No.: 425-462-3843 Fax No.: Emergency Phone No.:	Phone No.: Fax No.: Emergency Phone No.:

Persons Interviewed	Title	Phone No.
Darryl Hong	Sr. Regulatory Compliance Analyst	425.462.3911
	Pressure Control Lead	
Martin Medley	Pressure Control Tech	
Ken Johnson	Pressure Control Tech	
Scott Salazar	Corrosion Control Tech	
Keith Raines	Customer Service Field Tech	
Rich Eberly	PI Inspector	360-239-0928
Scott Hull	PI Inspector	
David Lockhart	Quality Assurance and Inspection	
Dave Wharton	Infrasource Contract Management	253-380-3451
Lenny Woods	Infrasource Contract Management	206-418-4248
Sharon Davenport	Infrasource Contract Management	253-617-6012
Dave Moffett	Supervisor of Corrosion South	253-476-6216
Jim Chartrey	Supervisor of Pressure Control South	206-571-2476
Cheryl McGrath	Manager of Compliance Programs	425-462-3207
Michelle Wildie	Engineer	425-456-2529
Jerry Games	Resource Coordinator	253-476-6224
John Klippert	Manager of Gas Systems Operations	206-517-3421
Signe Lippert	Supervisor of Maintenance Programs	206-716-2630
Stephanie Silva	Gas Compliance Program Manager	425-462-3923
Don Frieze	Senior Engineer	425-462-3862

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

WUTC staff conducted an abbreviated procedures inspection on 192 O&M and WAC items that changed since the last inspection. This checklist focuses on Records and Field items per a routine standard inspection. (check one below and enter appropriate date)			
<input type="checkbox"/>	Team inspection was performed (Within the past five years.) or,	Date:	
<input checked="" type="checkbox"/>	Other WUTC Inspector reviewed the O & M Manual (Since the last yearly review of the manual by the operator.) <i>Conducted by Joe Subsis.</i>	Date:	Nov 29, 2010
<input type="checkbox"/>	OQ Program Review (PHMSA Form 14) <i>Last Program review was Feb 28-Mar 16, 2004. Next Program review will occur November 6-10, 2014</i>	Date:	

GAS SYSTEM OPERATIONS			
Gas Supplier	Williams		
Services:	<i>Residential 54,166 Commercial 1231 Industrial 345 Other</i>		
Number of reportable safety related conditions last year	<i>0</i>	Number of deferred leaks in system	
Number of <u>non-reportable</u> safety related conditions last year	<i>0</i>	Number of third party hits last year	
Miles of transmission within inspection unit (total miles and miles in class 3 & 4 areas)	<i>3.23—2.23 in Thurston, 1 in Lewis</i>		
	Miles of main within inspection unit (total miles and miles in class 3 & 4 areas)	<i>other than HCAs PSE does not quantify miles of main in class 3 & 4</i>	
	Operating Pressure(s):	MAOP (Within last year)	Actual Operating Pressure (At time of Inspection)
Gate:	RS 0629 MCMILLAN GATE STATION, Chehalis	420 inlet 60 outlet	Did not visit
Gate:	RS 0991 LITTLEROCK GATE STATION, Tumwater	300 inlet 55outlet	Did not visit
Gate:	RS 1356 RAINIER TOWN GATE STATION, Rainier	250 inlet 44 outlet	235.2 inlet 40.7 outlet
Gate:	RS 1357 EAST OLYMPIA GATE STATION, Olympia	400 inlet 400 outlet	382 inlet 382 outlet
Gate:	RS 1359 WEST OLYMPIA GATE STATION, Tumwater	300 inlet 250 outlet	280.9 inlet 246.8 outlet
Gate:	RS 1360 CHEHALIS GATE STATION, Chehalis	350 inlet 280 outlet	337 inlet 277 outlet
Gate:	RS 1364 TOLEDO GATE STATION	420 inlet 60 outlet	256.6 inlet 56.2 outlet
Gate:	RS 2708 JACKSON PRARIE GATE STATION	978 inlet 60 outlet	760 inlet 17.3 outlet
Feeder:	OD 0032 YELM GATE STATION (odorizer only)	inlet outlet	Did not visit
Feeder:	OD 0031 WINLOCK GATE STATION (odorizer only)	inlet outlet	138
Does the operator have any transmission pipelines?		<i>Yes, 3.23 (2.23 in Thurston, 1 mile in Lewis) miles in this unit (this pipeline is inspected as part of the PSE Transmission Insp). All 6 inch--MOP of 400, MAOP of 440.</i>	
Compressor stations? Use Attachment 1.		<i>No</i>	

Pipe Specifications:			
Year Installed (Range)	1923 - 2014	Pipe Diameters (Range)	<i>5/8" – 20"</i>
Material Type	STW, PE, bare steel, wrought iron, unknown	Line Pipe Specification Used	<i>API 5L,</i>
Mileage	1100	SMYS %	<i>< 20% distribution, 25.5% Chehalis Gate station (between Williams and first pressure cut)</i>

Operator Qualification Field Validation
--

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Important: Per OPS, the OQ Field Inspection Protocol Form (Rev 4, May 2007) shall be used by the inspector as part of this standard inspection. When completed, the inspector will upload this information into the PHMSA OQ Database (OQDB) located at <http://primis.phmsa.dot.gov/oqdb/home.oq> **Date Completed/Uploaded** 7/31/2014

Integrity Management Field Validation

Important: Per PHMSA, IMP Field Verification Form (Rev 6/18/2012) shall be used by the inspector as part of this standard inspection. When completed, the inspector will upload this information into the PHMSA IM Database (IMDB) located at <http://primis.phmsa.dot.gov/gasimp/home.gim> **Date Completed/Uploaded:**

PART 199 Drug and Alcohol Testing Regulations and Procedures		S	U	NA	NC
Subparts A - C	Drug & Alcohol Testing & Misuse Prevention Program – Use PHMSA Form #13, Rev 3/19/2010. Do not ask the company to have a drug and alcohol expert available for this portion of your inspection.	X			

REPORTING RECORDS			S	U	N/A	N/C
1.	49 U.S.C. 60132, Subsection (b)	For Gas Transmission Pipelines and LNG Plants. Submission of Data to the National Pipeline Mapping System Under the Pipeline Safety Improvement Act of 2002 Updates to NMPS: Operators are required to make update submissions every 12 months if any system modifications have occurred. <u>If no modifications have occurred since the last complete submission (including operator contact information), send an email to opsgis@rspa.dot.gov stating that fact.</u> Include operator contact information with all updates. Submitted 2/10/2014 (No change notice)	X			
2.	RCW 81.88.080	Pipeline Mapping System: Has the operator provided accurate maps (or updates) of pipelines, operating over two hundred fifty pounds per square inch gauge, to specifications developed by the commission sufficient to meet the needs of first responders?	X			
3.	191.5	Immediate Notice of certain incidents to NRC (800) 424-8802 , or electronically at http://www.nrc.uscg.mil/nrchp.html , and additional report if significant new information becomes available. Operator must have a written procedure for calculating an initial estimate of the amount of product released in an accident. 303 San Mar, Olympia, 1/30/12	X			
4.	191.7	Reports (except SRCR and offshore pipeline condition reports) must be submitted electronically to PHMSA at http://portal.phmsa.dot.gov/pipeline at unless an alternative reporting method is authorized IAW with paragraph (d) of this section.	X			
5.	191.15(a)	30-day follow-up written reports to PHMSA (Form F7100.2) Submittal must be electronically to http://pipelineonlinereporting.phmsa.dot.gov	X			
6.	191.15(c)	Supplemental report (to 30-day follow-up) no supplemental reports			X	
7.	191.17	Complete and submit DOT Form PHMSA F 7100-2.1 by March 15 of each calendar year for the preceding year. <i>(NOTE: June 15, 2011 for the year 2010).</i>	X			
8.	191.22	Each operator must obtain an OPID, validate its OPIDs, and notify PHMSA of certain events at http://portal.phmsa.dot.gov/pipeline	X			
9.	191.23	Filing the Safety Related Condition Report (SRCR) no safety related conditions			X	

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

REPORTING RECORDS			S	U	N/A	N/C
10.	191.25 49 U.S.C. 60139, Subsection (b)(2)	Filing the SRCR within 5 days of determination, but not later than 10 days after discovery. no safety related conditions Note: Operators of gas transmission pipelines that if the pipeline pressure exceeds maximum allowable operating pressure (MAOP) plus the build-up, owner/operator must report the exceedance to PHMSA on or before the fifth day following the date on which the exceedance occurs. The report should be titled “Gas Transmission MAOP Exceedance” and provide the following information: <ul style="list-style-type: none"> • The name and principal address of the operator date of the report, name, job title, and business telephone number of the person submitting the report. • The name, job title, and business telephone number of the person who determined the condition exists. • The date the condition was discovered and the date the condition was first determined to exist. • The location of the condition, with reference to the town/city/county and state or offshore site, and as appropriate, nearest street address, offshore platform, survey station number, milepost, landmark, and the name of the commodity transported or stored. • The corrective action taken before the report was submitted and the planned follow-up or future corrective action, including the anticipated schedule for starting and concluding such action. 			X	
11.	.605(d)	Instructions to enable operation and maintenance personnel to recognize potential Safety Related Conditions no safety related conditions			X	
12.	191.27	Offshore pipeline condition reports – filed within 60 days after the inspections no offshore pipelines-Gulf of Mexico condition			X	
13.	192.727(g)	Abandoned facilities offshore, onshore crossing commercially navigable waterways reports No abandoned facilities			X	
14.	480-93-200(1)	Telephonic Reports to UTC Pipeline Safety Incident Notification 1-888-321-9144 (Within 2 hours) for events which results in;				
15.	480-93-200(1)(a)	A fatality or personal injury requiring hospitalization; No fatalities or injuries			X	
16.	480-93-200(1)(b)	Damage to property of the operator and others of a combined total exceeding fifty thousand dollars; none in this unit			X	
17.	480-93-200(1)(c)	The evacuation of a building, or high occupancy structures or areas;	X			
18.	480-93-200(1)(d)	The unintentional ignition of gas; none since last unit inspection			X	
19.	480-93-200(1)(e)	The unscheduled interruption of service furnished by any operator to twenty five or more distribution customers; none since last unit inspection			X	
20.	480-93-200(1)(f)	A pipeline pressure exceeding the MAOP plus ten percent or the maximum pressure allowed by proximity considerations outlined in WAC 480-93-020; none since last unit inspection			X	
21.	480-93-200(1)(g)	Is significant, in the judgment of the operator, even though it does not meet the criteria of (a) through (f) of this subsection; None in this unit			X	
22.	480-93-200(2)	Telephonic Reports to UTC Pipeline Safety Incident Notification 1-888-321-9146 (Within 24 hours) for;				
23.	480-93-200(2)(a)	The uncontrolled release of gas for more than two hours; pig farm Centralia 2013	X			
24.	480-93-200(2)(b)	The taking of a high pressure supply or transmission pipeline or a major distribution supply gas pipeline out of service; None since last unit inspection			X	
25.	480-93-200(2)(c)	A gas pipeline operating at low pressure dropping below the safe operating conditions of attached appliances and gas equipment; or No low pressure in this unit			X	
26.	480-93-200(2)(d)	A gas pipeline pressure exceeding the MAOP	X			
27.	480-93-200(4)	Did written incident reports (within 30 days of telephonic notice) include the following				
28.	480-93-200(4)(a)	Name(s) and address(es) of any person or persons injured or killed, or whose property was damaged; No injury or fatality incidents since last unit inspection			X	
29.	480-93-200(4)(b)	The extent of injuries and damage; No injury or fatality incidents since last unit inspection			X	

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

REPORTING RECORDS			S	U	N/A	N/C
30.	480-93-200(4)(c)	A description of the incident or hazardous condition including the date, time, and place, and reason why the incident occurred. If more than one reportable condition arises from a single incident, each must be included in the report;	X			
31.	480-93-200(4)(d)	A description of the gas pipeline involved in the incident or hazardous condition, the system operating pressure at that time, and the MAOP of the facilities involved;	X			
32.	480-93-200(4)(e)	The date and time the gas pipeline company was first notified of the incident;	X			
33.	480-93-200(4)(f)	The date and time the ((operators')) gas pipeline company's first responders arrived on-site;	X			
34.	480-93-200(4)(g)	The date and time the gas ((facility)) pipeline was made safe;	X			
35.	480-93-200(4)(h)	The date, time, and type of any temporary or permanent repair that was made;	X			
36.	480-93-200(4)(i)	The cost of the incident to the ((operator)) gas pipeline company;	X			
37.	480-93-200(4)(j)	Line type;	X			
38.	480-93-200(4)(k)	City and county of incident; and	X			
39.	480-93-200(4)(l)	Any other information deemed necessary by the commission.	X			
40.	480-93-200(5)	Supplemental report if required information becomes available after 30 day report submitted	X			
41.	480-93-200(6)	Written report within 5 days of receiving the failure analysis of any incident or hazardous condition due to construction defects or material failure <i>PSE does submit these analyses</i>	X			
42.	480-93-200(7)	Filing Reports of Damage to Gas Pipeline Facilities to the commission. (eff 4/1/2013) (Via the commission's Virtual DIRT system or on-line damage reporting form)				
43.	480-93-200(7)(a)	Does the operator report to the commission the requirements set forth in RCW 19.122.053(3) (a) through (n)	X			
44.	480-93-200(7)(b)	Does the operator report the name, address, and phone number of the person or entity that the company has reason to believe may have caused damage due to excavations conducted <u>without facilities locates</u> first being completed?	X			
45.	480-93-200(7)(c)	Does the operator retain all damage and damage claim records it creates related to damage events reported under 93-200(7)(b), including photographs and documentation supporting the conclusion that a facilities locate was not completed? Note: Records maintained for two years and made available to the commission upon request.	X			
46.	480-93-200(8)	Does the operator provide the following information to excavators who damage gas pipeline facilities?				
47.	480-93-200(8)(a)	<ul style="list-style-type: none"> • Notification requirements for excavators under RCW 19.122.050(1) 	X			
48.	480-93-200(8)(b)	<ul style="list-style-type: none"> • A description of the excavator's responsibilities for reporting damages under RCW 19.122.053; and 	X			
49.	480-93-200(8)(c)	<ul style="list-style-type: none"> • Information concerning the safety committee referenced under RCW 19.122.130, including committee contact information, and the process for filing a complaint with the safety committee. 	X			
50.	480-93-200(9)	Reports to the commission only when the operator or its contractor observes or becomes aware of the following activities <ul style="list-style-type: none"> • An excavator digs within thirty-five feet of a transmission pipeline, as defined by RCW 19.122.020(26) without first obtaining a facilities locate; (200(9)(a) • A person intentionally damages or removes marks indicating the location or presence of gas pipeline facilities. 200(9)(b) 	X			
51.	480-93-200(10)	Annual Reports filed with the commission no later than March 15 for the proceeding calendar year				
52.	480-93-200(10)(a)	A copy of PHMSA F-7100.1-1 and F-7100.2-1 annual report required by U.S. Department of Transportation, PHMSA/Office of Pipeline Safety	X			
53.	480-93-200(10)(b)	Reports detailing all construction defects and material failures resulting in leakage. Categorizing the different types of construction defects and material failures. The report must include the following: (i) Types and numbers of construction defects; and (ii) Types and numbers of material failures.	X			
54.	480-93-200(11)	Providing updated emergency contact information to the commission and appropriate officials of all municipalities where gas pipeline companies have facilities	X			

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

REPORTING RECORDS			S	U	N/A	N/C
55.	480-93-200(12)	Providing by email, reports of daily construction and repair activities no later than 10:00 a.m.	X			
56.	480-93-200(13)	Submitting copy of DOT Drug and Alcohol Testing MIS Data Collection Form when required	X			

Comments:

CUSTOMER and EXCESS FLOW VALVE INSTALLATION NOTIFICATION			S	U	N/A	N/C
57.	192.16	Customer notification - Customers notified, within 90 days , of their responsibility for those service lines not maintained by the operator	X			
58.	192.381	Does the excess flow valve meet the performance standards prescribed under §192.381? UMAC Series 2600 GasBreaker	X			
59.	192.383	Does the operator have an installation and reporting program for excess flow valves and does the program meet the requirements outlined in §192.383? Are records adequate?	X			

Comments:

CONSTRUCTION RECORDS			S	U	N/A	N/C
60.	480-93-013	OQ records for personnel performing New Construction covered tasks	X			
61.	192.225	Test Results to Qualify Welding Procedures	X			
62.	192.227	Welder Qualification	X			
63.	480-93-080(1)(b)	Appendix C Welders re-qualified 2/Yr (7.5Months)	X			
64.	480-93-080(2)	Plastic pipe joiners re-qualified 1/Yr (15 Months)	X			
65.	480-93-080(2)(b)	Plastic pipe joiners re-qualified if no production joints made during any 12 month period PSE requalifies all pipe joiners annually.			X	
66.	480-93-080(2)(c)	Tracking Production Joints or Re-qualify joiners 1/Yr (12Months) PSE requalifies all pipe joiners annually.			X	
67.	480-93-115(2)	Test leads on casings (without vents) installed after 9/05/1992 No casings installed this unit since last inspection			X	
68.	480-93-115(3)	Sealing ends of casings or conduits on transmission lines and mains No transmission casing construction this unit			X	
69.	480-93-115(4)	Sealing ends (nearest building wall) of casings or conduits on services Standard note on construction docs, but did not observed during this inspection	X			
70.	192.241(a)	Visual Weld Inspector Training/Experience	X			
71.	192.243(b)(2)	Nondestructive Technician Qualification	X			
72.	192.243(c)	NDT procedures	X			
73.	192.243(f)	Total Number of Girth Welds	X			
74.	192.243(f)	Number of Welds Inspected by NDT	X			

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

CONSTRUCTION RECORDS			S	U	N/A	N/C
75.	192.243(f)	Number of Welds Rejected None rejected			X	
76.	192.243(f)	Disposition of each Weld Rejected None rejected			X	
77.	.273/.283	Qualified Joining Procedures Including Test Results	X			
78.	192.303	Construction Specifications PSE procedures as note on drawing sets	X			
79.	192.325 WAC 480-93-178(4)(5)	Underground Clearances	X			
80.	192.327	Amount, location, cover of each size of pipe installed	X			
81.	480-93-160(1)	Report filed 45 days prior to construction or replacement of transmission pipelines ≥ 100 feet in length No transmission construction in this unit			X	
82.	480-93-160(2)	Did report describe the proposed route and the specifications for the pipeline and must include, but is not limited to the following items: No transmission construction in this unit			X	
83.	480-93-160(2)(a)	Description and purpose of the proposed pipeline; No transmission construction in this unit			X	
84.	480-93-160(2)(b)	Route map showing the type of construction to be used throughout the length of the line, and delineation of class location as defined in 49 CFR Part 192.5, and incorporated boundaries along the route. No transmission construction in this unit			X	
85.	480-93-160(2)(c)	Location and specification of principal valves, regulators, and other auxiliary equipment to be installed as a part of the pipeline system to be constructed No transmission in this unit			X	
86.	480-93-160(2)(d)	MAOP for the gas pipeline being constructed; No transmission construction in this unit			X	
87.	480-93-160(2)(e)	Location and construction details of all river crossings or other unusual construction requirements encountered en route. No transmission construction in this unit			X	
88.	480-93-160(2)(f)	Proposed corrosion control program to be followed inc specs for coating and wrapping, and method to ensure the integrity of the coating using holiday detection equipment;			X	
89.	480-93-160(2)(g)	Welding specifications; and No transmission construction in this unit			X	
90.	480-93-160(2)(h)	Bending procedures to be followed if needed. No transmission construction n in this unit			X	
91.	480-93-170(1)	Commission notified 2 days prior to pressure testing pipelines with an MAOP producing a hoop stress $\geq 20\%$ SMYS? No transmission construction in this unit			X	
92.	480-93-170(7)	Pressure tests records at a minimum include required information listed under 480-93-170(a-h)	X			
93.	480-93-170(9)	Individual pressure test records maintained for single installations where multiple pressure tests were performed?	X			
94.	480-93-170(10)	Pressure Testing Equipment checked for accuracy/intervals (Manufacturers Rec or Operators schedule)	X			
95.	480-93-175(2)	Study prepared and approved prior to moving and lowering of metallic pipelines > 60 psig None since last unit inspection			X	
96.	480-93-175(4)	Leak survey within 30 days of moving or lowering pipelines ≤ 60 psig None since last unit inspection			X	

Comments:

OPERATIONS and MAINTENANCE RECORDS			S	U	N/A	N/C
97.	192.517(a)	Pressure Testing (operates at or above 100 psig) – useful life of pipeline or 5-yr window for pre-code pipelines	X			

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

OPERATIONS and MAINTENANCE RECORDS			S	U	N/A	N/C
98.	192.517(b)	Pressure Testing (operates below 100 psig, service lines, plastic lines) – 5 years	X			
99.	192.605(a)	Procedural Manual Review – Operations and Maintenance (1 per yr/15 months) Note: Including review of OQ procedures as <u>suggested</u> by PHMSA - ADB-09-03 dated 2/7/09	X			
100.	192.605(b)(3)	Availability of construction records, maps, operating history to operating personnel	X			
101.	480-93-018(3)	Records, including maps and drawings updated within 6 months of completion of construction activity?	X			
102.	192.605(b)(8)	Periodic review of personnel work – effectiveness of normal O&M procedures PSE inhouse gas site audits for contractors, and QC audits for PSE personnel	X			
103.	192.605(c)(4)	Periodic review of personnel work – effectiveness of abnormal operation procedures Transmission covered in separate inspection			X	
104.	192.609	Class Location Study (If applicable) No class location study since last inspection			X	
105.	192.611	Confirmation or revision of MAOP No revisions to MAOP in this unit since last inspection..			X	
106.	192.614	Damage Prevention (Operator Internal Performance Measures)				
107.		Does the operator have a quality assurance program in place for monitoring the locating and marking of facilities? Do operators conduct regular field audits of the performance of locators/contractors and take action when necessary? (CGA Best Practices v. 6.0, Best Practice 4-18. Recommended only, not required)	X			
108.		Does operator including performance measures in facility locating services contracts with corresponding and meaningful incentives and penalties?	X			
109.		Do locate contractors address performance problems for persons performing locating services through mechanisms such as re-training, process change, or changes in staffing levels?	X			
110.		Does the operator periodically review the Operator Qualification plan criteria and methods used to qualify personnel to perform locates?	X			
111.		Review operator locating and excavation <u>procedures</u> for compliance with state law and regulations.	X			
112.		Are locates are being made within the timeframes required by state law and regulations? Examine record sample.	X			
113.		Are locating and excavating personnel properly <u>qualified</u> in accordance with the operator’s Operator Qualification plan and with federal and state requirements?	X			
114.		Follow-up inspection performed on the pipeline where there is reason to believe the pipeline could be damaged .614(c) (6) 1. Is the inspection the done as frequently as necessary during and after the activities to verify the integrity of the pipeline? 2. In the case of blasting, does the inspection include leakage surveys?	X			

Comments:

115.		Emergency Response Plans	S	U	N/A	N/C
116.	192.603(b)	Prompt and effective response to each type of emergency .615(a)(3) Note: Review operator records of previous accidents and failures including third-party damage and leak response	X			
117.	192.615(b)(1)	Location Specific Emergency Plan None in this unit			X	
118.	192.615(b)(2)	Emergency Procedure training, verify effectiveness of training	X			

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

119.	192.615(b)(3)	Employee Emergency activity review, determine if procedures were followed.	X																													
120.	192.615(c)	Liaison Program with Public Officials	X																													
121.	192.616	Public Awareness Program																														
122.	192.616(e&f)	Documentation properly and adequately reflects implementation of operator’s Public Awareness Program requirements - Stakeholder Audience identification, message type and content, delivery method and frequency, supplemental enhancements, program evaluations, etc. (i.e. contact or mailing rosters, postage receipts, return receipts, audience contact documentation, etc. for emergency responder, public officials, school superintendents, program evaluations, etc.). See table below:	X																													
123.		Operators in existence on June 20, 2005, must have completed their written programs no later than June 20, 2006. See 192.616(a) and (j) for exceptions.																														
124.		API RP 1162 Baseline* Recommended Message Deliveries																														
125.		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Stakeholder Audience (LDC’s)</th> <th style="text-align: center;">Baseline Message Frequency (starting from effective date of Plan)</th> </tr> </thead> <tbody> <tr> <td>Residence Along Local Distribution System</td> <td>Annual</td> </tr> <tr> <td>LDC Customers</td> <td>Twice annually</td> </tr> <tr> <td>One-Call Centers</td> <td>As required of One-Call Center</td> </tr> <tr> <td>Emergency Officials</td> <td>Annual</td> </tr> <tr> <td>Public Officials</td> <td>3 years</td> </tr> <tr> <td>Excavator and Contractors</td> <td>Annual</td> </tr> <tr> <th style="text-align: center;">Stakeholder Audience (Transmission line operators)</th> <th style="text-align: center;">Baseline Message Frequency (starting from effective date of Plan)</th> </tr> <tr> <td>Residence Along Local Distribution System</td> <td>2 years</td> </tr> <tr> <td>One-Call Centers</td> <td>As required of One-Call Center</td> </tr> <tr> <td>Emergency Officials</td> <td>Annual</td> </tr> <tr> <td>Public Officials</td> <td>3 years</td> </tr> <tr> <td>Excavator and Contractors</td> <td>Annual</td> </tr> </tbody> </table>	Stakeholder Audience (LDC’s)	Baseline Message Frequency (starting from effective date of Plan)	Residence Along Local Distribution System	Annual	LDC Customers	Twice annually	One-Call Centers	As required of One-Call Center	Emergency Officials	Annual	Public Officials	3 years	Excavator and Contractors	Annual	Stakeholder Audience (Transmission line operators)	Baseline Message Frequency (starting from effective date of Plan)	Residence Along Local Distribution System	2 years	One-Call Centers	As required of One-Call Center	Emergency Officials	Annual	Public Officials	3 years	Excavator and Contractors	Annual				
Stakeholder Audience (LDC’s)	Baseline Message Frequency (starting from effective date of Plan)																															
Residence Along Local Distribution System	Annual																															
LDC Customers	Twice annually																															
One-Call Centers	As required of One-Call Center																															
Emergency Officials	Annual																															
Public Officials	3 years																															
Excavator and Contractors	Annual																															
Stakeholder Audience (Transmission line operators)	Baseline Message Frequency (starting from effective date of Plan)																															
Residence Along Local Distribution System	2 years																															
One-Call Centers	As required of One-Call Center																															
Emergency Officials	Annual																															
Public Officials	3 years																															
Excavator and Contractors	Annual																															
126.		* Refer to API RP 1162 for additional requirements, including general program recommendations, supplemental requirements, recordkeeping, program evaluation, etc.																														
127.	192.616(g)	The program conducted in English and any other languages commonly understood by a significant number of the population in the operator's area.	X																													
128.	.616(h)	IAW API RP 1162, the operator’s program should be reviewed for effectiveness within four years of the date the operator’s program was first completed. <u>For operators in existence on June 20, 2005</u> , who must have completed their written programs no later than June 20, 2006, the first evaluation is due no later than June 20, 2010 . .616(h)	X																													
129.	192.616(j)	Operators of a Master Meter or petroleum gas system – public awareness messages 2 times annually: PSE does operate gas distribution system (1) A description of the purpose and reliability of the pipeline; (2) An overview of the hazards of the pipeline and prevention measures used; (3) Information about damage prevention; (4) How to recognize and respond to a leak; and (5) How to get additional information.				X																										
130.	192.617	Review operator records of accidents and failures including laboratory analysis where appropriate to determine cause and prevention of recurrence .617 Note: Including excavation damage and leak response records (PHMSA area of emphasis) (NTSB B.10)	X																													

Comments:

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

--	--

131.	192.619/621/623	Maximum Allowable Operating Pressure (MAOP) Note: New PA-11 design criteria is incorporated into 192.121 & .123 (Final Rule Pub. 12/24/08) PSE has records indicating MAOP based on 5 yr operating history, original pressure tests, historic pipe purchase records and historic pipe specifications and design pressure calculations. Winlock, Chehalis, and Olympia HP	X											
132.	480-93-015(1)	Odorization of Gas – Concentrations adequate	X											
133.	480-93-015(2)	Monthly Odorant Sniff Testing	X											
134.	480-93-015(3)	Prompt action taken to investigate and remediate odorant concentrations not meeting the minimum requirements None since last inspection			X									
135.	480-93-015(4)	Odorant Testing Equipment Calibration/Intervals (Annually or Manufacturers Recommendation)	X											
136.	480-93-124(3)	Pipeline markers attached to bridges or other spans inspected? 1/yr(15 months)	X											
137.	480-93-124(4)	Markers reported missing or damaged replaced within 45 days?	X											
138.	480-93-140(2)	Service regulators and associated safety devices tested during initial turn-on	X											
139.	480-93-155(1)	Up-rating of system MAOP to >60 psig? Procedures and specifications submitted 45 days prior? Littlerock Gate Station Docket 111454	X											
140.	480-93-185(1)	Reported gas leaks promptly investigated? Graded in accordance with 480-93-186? Records retained?	X											
141.	480-93-185(3)(a)	Leaks originating from a foreign source. Take appropriate action to protect life and property regarding the pipeline company's own facilities, and;	X											
142.	480-93-185(3)(b)	Leaks originating from a foreign source reported promptly/notification by mail. Records retained? PSE has not needed to send any letters as required by this regulation			X									
143.	480-93-186(3)	Leak evaluations: Are follow-up inspections performed within 30 days of a leak repair?	X											
144.	480-93-186(4)	Leak evaluations: Grade 1 and 2 leaks (if any), downgraded once to a grade 3 without physical repair?	X											
145.	480-93-187	Gas leak records: at a minimum include required information listed under 480-93-187(1-13)	X											
146.	480-93-188(1)	Gas leak surveys	X											
147.	480-93-188(2)	Gas detection instruments tested for accuracy/intervals (Mfct recommended or monthly not to exceed 45 days)	X											
148.	480-93-188(3)	Leak survey frequency (Refer to Table Below) leak survey same interval as atmos 1/3 yr	X											
<table border="1" style="margin: auto; border-collapse: collapse;"> <tr> <td style="padding: 5px;">Business Districts (implement by 6/02/07)</td> <td style="padding: 5px; text-align: center;">1/yr (15 months)</td> </tr> <tr> <td style="padding: 5px;">High Occupancy Structures</td> <td style="padding: 5px; text-align: center;">1/yr (15 months)</td> </tr> <tr> <td style="padding: 5px;">Pipelines Operating \geq 250 psig</td> <td style="padding: 5px; text-align: center;">1/yr (15 months)</td> </tr> <tr> <td style="padding: 5px;">Other Mains: CI, WI, copper, unprotected steel</td> <td style="padding: 5px; text-align: center;">2/yr (7.5 months)</td> </tr> </table>							Business Districts (implement by 6/02/07)	1/yr (15 months)	High Occupancy Structures	1/yr (15 months)	Pipelines Operating \geq 250 psig	1/yr (15 months)	Other Mains: CI, WI, copper, unprotected steel	2/yr (7.5 months)
Business Districts (implement by 6/02/07)	1/yr (15 months)													
High Occupancy Structures	1/yr (15 months)													
Pipelines Operating \geq 250 psig	1/yr (15 months)													
Other Mains: CI, WI, copper, unprotected steel	2/yr (7.5 months)													
149.	480-93-188(4)(a)	Special leak surveys - Prior to paving or resurfacing, following street alterations or repairs or other related construction	X											
150.	480-93-188(4)(b)	Special leak surveys - areas where substructure construction occurs adjacent to underground gas facilities, and damage could have occurred	X											
151.	480-93-188(4)(c)	Special leak surveys - Unstable soil areas where active gas lines could be affected None since last inspection			X									
152.	480-93-188(4)(d)	Special leak surveys - areas and at times of unusual activity, such as earthquake, floods, and explosions None since last inspection			X									

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

153.	480-93-188(4)(e)	Special leak surveys - After third-party excavation damage to services, operators must perform a gas leak survey to eliminate the possibility of multiple leaks and underground migration into nearby buildings. PSE performs this as part of normal response to leak call	X															
154.	480-93-188(5)	Gas Survey Records (Min 5 yrs) and at a minimum include required information listed under 480-93-188 (5) (a-f)	X															
155.	480-93-188(6)	Leak program - Self Audits	X															
156.	192.709	Patrolling (Transmission Lines) (Refer to Table Below) .705 Transmission covered in separate inspection			X													
<table border="1" style="width: 100%; text-align: center;"> <thead> <tr> <th>Class Location</th> <th>At Highway and Railroad Crossings</th> <th>At All Other Places</th> </tr> </thead> <tbody> <tr> <td>1 and 2</td> <td>2/yr (7½ months)</td> <td>1/yr (15 months)</td> </tr> <tr> <td>3</td> <td>4/yr (4½ months)</td> <td>2/yr (7½ months)</td> </tr> <tr> <td>4</td> <td>4/yr (4½ months)</td> <td>4/yr (4½ months)</td> </tr> </tbody> </table>							Class Location	At Highway and Railroad Crossings	At All Other Places	1 and 2	2/yr (7½ months)	1/yr (15 months)	3	4/yr (4½ months)	2/yr (7½ months)	4	4/yr (4½ months)	4/yr (4½ months)
Class Location	At Highway and Railroad Crossings	At All Other Places																
1 and 2	2/yr (7½ months)	1/yr (15 months)																
3	4/yr (4½ months)	2/yr (7½ months)																
4	4/yr (4½ months)	4/yr (4½ months)																
157.	192.709	Leak Surveys (Transmission Lines) (Refer to Table Below) .706 Transmission covered in separate inspection			X													
<table border="1" style="width: 100%; text-align: center;"> <thead> <tr> <th>Class Location</th> <th>Required</th> <th>Not Exceed</th> </tr> </thead> <tbody> <tr> <td>1 and 2</td> <td>1/yr</td> <td>15 months</td> </tr> <tr> <td>3</td> <td>2/yr</td> <td>7½ months</td> </tr> <tr> <td>4</td> <td>4/yr</td> <td>4½ months</td> </tr> </tbody> </table>							Class Location	Required	Not Exceed	1 and 2	1/yr	15 months	3	2/yr	7½ months	4	4/yr	4½ months
Class Location	Required	Not Exceed																
1 and 2	1/yr	15 months																
3	2/yr	7½ months																
4	4/yr	4½ months																
158.	192.603(b)	Patrolling Business District (4 per yr/4½ months) .721(b)(1) PSE monitors the 5th Ave bridge at Capital Lake outlet; pipelines not sitting on rollers. See Summary above	X															
159.	192.603(b)	Patrolling Outside Business District (2 per yr/7½ months) 192.721(b)(2)	X															
160.	192.603(b)	Leakage Survey - Outside Business District (5 years) 192.723(b)(1) 1/3 yrs with atmos	X															
161.	192.603(b)	Leakage Survey 192.723(b)(2) <ul style="list-style-type: none"> • Outside Business District (5 years) • Cathodically unprotected distribution lines (3 years) 	X															
162.	192.603(b)	Tests for Reinstating Service Lines 192.725	X															
163.	192.603(b)/.727(g)	Abandoned Pipelines; Underwater Facility Reports 192.727 None in this unit			X													
164.	192.709	Pressure Limiting and Regulating Stations (1 per yr/15 months) .739 Valves at RS 313 Franz and Lacey Blvd-cannot turn and isolate station-cannot perform annual maintenance 2013		X														
165.	192.709	Pressure Limiting and Regulator Stations – Capacity (1 per yr/15 months) .743 RS 248 Centralia 2012 and 2013		X														
166.	192.709	Valve Maintenance – Transmission (1 per yr/15 months) .745 Transmission covered in separate inspection AOC as need to be completed by Oct 2014			X													
167.	192.709	Valve Maintenance – Distribution (1 per yr/15 months) .747 Run one stage 2 outlet equipment valve for RS 313 Franz and Lacey Blvd-cannot turn cannot service 2013. Include as part of RS 313.		X														
168.	480-93-100(3)	Service valve maintenance (1 per yr/15 months)	X															
169.	192.709	Vault maintenance (≥200 cubic feet)(1 per yr/15 months) .749 No vaults meeting regulation			X													
170.	192.603(b)	Prevention of Accidental Ignition (hot work permits) .751 PSE does not use hot work permits—procedures cover this			X													
171.	192.603(b)	Welding – Procedure 192.225(b)	X															
172.	192.603(b)	Welding – Welder Qualification 192.227/.229	X															
173.	192.603(b)	NDT – NDT Personnel Qualification .243(b)(2)	X															
174.	192.709	NDT Records (pipeline life) .243(f) Transmission covered in separate inspection			X													
175.	192.709	Repair: pipe (pipeline life); Other than pipe (5 years) Transmission covered in separate inspection			X													
176.	192.905(c)	Periodically examining their transmission line routes for the appearance of newly identified area’s (HCA’s) Transmission covered in separate inspection			X													

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Comments:

CORROSION CONTROL RECORDS			S	U	N/A	N/C
177.	192.455(a)(1)	Pipeline coatings meet requirements of 192.461 <i>(for buried pipelines installed after 7/31/71)</i>	X			
178.	192.455(a)(2)	CP system installed on and operating within 1 yr of completion of pipeline construction <i>(after 7/31/71)</i>	X			
179.	192.465(a)	Annual Pipe-to-soil Monitoring (1 per yr/15 months) for short sections (10% per year; all in 10 years)	X			
180.	192.491	Test Lead Maintenance .471	X			
181.	192.491	Maps or Records .491(a)	X			
182.	192.491	Examination of Buried Pipe when exposed .459	X			
183.	480-93-110(8)	CP test reading on all exposed facilities where coating has been removed	X			
184.	192.491	Annual Pipe-to-soil monitoring (1 per yr/15 months) .465(a)	X			
185.	192.491	Rectifier Monitoring (6 per yr/2½ months) .465(b)	X			
186.	192.491	Interference Bond Monitoring – Critical (6 per yr/2½ months) .465(c) <i>None in this unit</i>			X	
187.	192.491	Interference Bond Monitoring – Non-critical (1 per yr/15 months) .465(c) <i>None in this unit</i>			X	
188.	480-93-110(2)	Remedial action taken within 90 days (Up to 30 additional days if other circumstances. Must document) .465(d)	X			
189.	480-93-110(3)	CP equipment/ instrumentation maintained, tested for accuracy, calibrated, and operated in accordance with manufactures recommendations, or at appropriate schedule determined by gas company if no recommendation.	X			
190.	192.491	Unprotected Pipeline Surveys, CP active corrosion areas (1 per 3 cal yr/39 months) .465(e)	X			
191.	192.491	Electrical Isolation (Including Casings) .	X			
192.	480-93-110(5)	Casings inspected/tested annually not to exceed fifteen months	X			
193.	480-93-110(5)(a)	Casings w/no test leads installed prior to 9/05/1992. Demonstrate other acceptable test methods	X			
194.	480-93-110(5)(b)	Possible shorted conditions – Perform confirmatory follow-up inspection within 90 days	X			
195.	480-93-110(5)(c)	Casing shorts cleared when practical <i>No casing shorts cleared-on list for leak survey</i>			X	
196.	480-93-110(5)(d)	Shorted conditions leak surveyed within 90 days of discovery. Twice annually/7.5 months	X			
197.	192.491	Interference Currents .473 <i>No interference currents</i>			X	
198.	192.491	Internal Corrosion; Corrosive Gas Investigation .475(a) <i>PSE has no internal corrosion issues—Williams does not supply corrosive gas</i>			X	
199.	192.491	Internal Corrosion; Internal Surface Inspection; Pipe Replacement .475(b)	X			
200.	192.491	Internal Corrosion Control Coupon Monitoring (2 per yr/7½ months) .477 <i>PSE has no internal corrosion issues—Williams does not supply corrosive gas</i>			X	
201.	192.491	Atmospheric Corrosion Control Monitoring (1 per 3 cal yr/39 months onshore; 1 per yr/15 months offshore) .481	X			
202.	192.491	Remedial: Replaced or Repaired Pipe; coated and protected; corrosion evaluation and actions .483/485	X			

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Comments:

PIPELINE INSPECTION (Field)			S	U	N/A	N/C
203.	192.161	Supports and anchors	X			
204.	480-93-080(1)(d)	Welding procedures located on site where welding is performed? No welding witnessed during field inspection			X	
205.	480-93-080(1)(b)	Use of testing equipment to record and document essential variables No welding witnessed during field inspection			X	
206.	480-93-080(2)(a)	Plastic procedures located on site where welding is performed? No fusion witnessed during field inspection			X	
207.	480-93-080(3)	Identification and qualification cards/certificates w/name of welder/joiner, their qualifications, date of qualification and operator whose qualification procedures were followed. No fusion witnessed during field inspection			X	
208.	480-93-013	Personnel performing “New Construction” covered tasks OQ qualified? No construction crews witnessed during field inspection			X	
209.	480-93-015(1)	Odorization	X			
210.	480-93-018(3)	Updated records, inc maps and drawings made available to appropriate operations personnel?	X			
211.	192.179	Valve Protection from Tampering or Damage	X			
212.	192.455	Pipeline coatings meet requirements of 192.461 <i>(for buried pipelines installed after 7/31/71)</i>	X			
213.	192.463	Levels of cathodic protection	X			
214.	192.465	Rectifiers	X			
215.	192.467	CP - Electrical Isolation	X			
216.	192.476	Systems designed to reduce internal corrosion PSE has no internal corrosion issues—Williams does not supply corrosive gas			X	
217.	192.479	Pipeline Components exposed to the atmosphere	X			
218.	192.481	Atmospheric Corrosion: monitoring Steam Plant, Sears meter, RS 258 See 201 above—See write up in Summary above.		X		
219.	192.491	Test Stations – Sufficient Number .469	X			
220.	480-93-115(2)	Casings – Test Leads (casings w/o vents installed after 9/05/1992)	X			
221.	480-93-115(2)	Mains or transmission lines installed in casings/conduit. Are casing ends sealed? Did not witness installation in casing or conduit.			X	
222.	480-93-115(4)	Service lines installed in casings/conduit. Are casing ends nearest to building walls sealed? Did not witness installation in casing or conduit.			X	
223.	192.605(a)	Appropriate parts of manuals kept at locations where O&M activities are conducted	X			
224.	192.605	Knowledge of Operating Personnel	X			
225.	480-93-124	Pipeline markers	X			
226.	480-93-124(4)	Markers reported missing or damaged replaced within 45 days?	X			
227.	192.719	Pre-pressure Tested Pipe (Markings and Inventory) No pretested pipe at Lakewood operating base			X	
228.	192.195	Overpressure protection designed and installed where required?	X			
229.	192.739/743	Pressure Limiting and Regulating Devices (Mechanical/Capacities)	X			
230.	192.741	Telemetry, Recording Gauges	X			
231.	192.751	Warning Signs	X			
232.	192.355	Customer meters and regulators. Protection from damage	X			

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

PIPELINE INSPECTION (Field)			S	U	N/A	N/C
233.	192.355(c)	Pits and vaults: Able to support vehicular traffic where anticipated. No regulated pits or vaults			X	
234.	480-93-140	Service regulators installed, operated and maintained per state/fed regs and manufacturers recommended practices?	X			
235.	480-93-178(2)	Plastic Pipe Storage facilities – Maximum Exposure to Ultraviolet Light (2yrs)	X			
236.	480-93-178(4)	Minimum Clearances from other utilities. For parallel lines a minimum of twelve inches. Where a minimum twelve inches of separation is not possible, must take adequate precautions, such as inserting the plastic pipeline in conduit, to minimize any potential hazards. Did not witness construction in trench with other utilities			X	
237.	480-93-178(5)	Minimum Clearances from other utilities. For perpendicular lines a minimum of six inches of separation from the other utilities. Where a minimum six inches of separation is not possible, must take adequate precautions, such as inserting the plastic pipeline in conduit, to minimize any potential hazards Did not witness construction in trench crossing other utilities			X	
238.	480-93-178(6)	Are there Temporary above ground PE pipe installations currently? Yes No X				
239.	480-93-178(6)(a)	If yes, is facility monitored and protected from potential damage? No temporary PE installed			X	
240.	480-93-178(6)(b)	If installation exceeded 30 days, was commission staff notified prior to exceeding the deadline? No temporary PE installed			X	
241.	192.745	Valve Maintenance (Transmission) Transmission covered in separate inspection			X	
242.	192.747	Valve Maintenance (Distribution)	X			

Facility Sites Visited:

Facility Type	Facility ID Number	Location
Regulator station	RS 1360	Chehalis WA
Regulator station	RS 1356	Rainier WA
Regulator station	RS 1357	E. Olympia WA
Regulator station	RS 1359	W. Olympia WA
Regulator station	RS 1364	Toledo WA
Regulator station	RS 2708	Jackson Prairie WA
Regulator station	RS 2717	Winlock WA
Regulator station	RS 2785	Olympia WA
Regulator station	RS 313	Franz St., Lacey WA
Regulator station	RS 2602	Lacey WA
Rectifier	PS XXXX	Military at Neville, Winlock WA
Rectifier	PS XXXX	NE Kresky, Chehalis WA
Rectifier	PS XXXX	Gerth St., Tumwater WA
Rectifier	PS 198	41 st at Blvd, Olympia WA
Rectifier	PS 212	Trailblazer, Lacey WA
Odorizer and Storage Tank	OD 031	Winlock, WA
Casing		Prindle at RR tracks
Isolation Test Point	RS 1364	Toledo Gate
Isolation Test Point	RS 1360	Chehalis Gate

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

PIPELINE INSPECTION (Field)			S	U	N/A	N/C
Bridge Crossing	PBS-	McCallister Creek at Steilacoom, Lacey WA				
Bridge Crossing	PBS-	Afflerbaugh at UPRR Trestle Lacey WA				
Bridge Crossing	PBS-	Holmes Is Rd Bridge, Lacey WA				
Bridge Crossing	PBS-317	5 th Ave at Capital Lk, Olympia WA				
Bridge Crossing	PBS-	Henderson Blvd at Deschutes River, Tumwater WA				
Bridge Crossing	PBS-	Capital Way at Deschutes River, Tumwater WA				
Bridge Crossing	PBS-	Old 99 at Thurston/Lewis County line				
Bridge Crossing	PBS-	Reynolds at Coffee Creek, Centralia WA				
Bridge Crossing	PBS-	Mellon at Chehalis River, Centralia WA				
Bridge Crossing	PBS-	Yew at China Creek, Chehalis				
Bridge Crossing	PBS-	Pearl St at Skookumchuck River, Centralia				
Steep Slope	PBS-	Salmon Lane, Lacey WA				

Comments:

Recent Gas Pipeline Safety Advisory Bulletins: (Last 2 years)

<u>Number</u>	<u>Date</u>	<u>Subject</u>
ADB-2013-07	July 12, 13	Potential for Damage to Pipeline Facilities Caused by Flooding
ADB-2012-10	Dec 5, 12	Using Meaningful Metrics in Conducting Integrity Management Program Evaluations
ADB-2012-09	Oct 11, 12	Communication During Emergency Situations
ADB-2012-08	Jul 31, 12	Inspection and Protection of Pipeline Facilities After Railway Accidents
ADB-12-07	Jun 11, 12	Mechanical Fitting Failure Reports
ADB-12-06	May 7, 12	Verification of Records establishing MAOP and MOP

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

ADB-12-05	Mar 23, 12	Cast Iron Pipe (Supplementary Advisory Bulletin)
ADB -12-04	Mar 21, 12	Implementation of the National Registry of Pipeline and Liquefied Natural Gas Operators
ADB-12-03	Mar 6, 12	Notice to Operators of Driscopipe 8000 High Density Polyethylene Pipe of the Potential for Material Degradation
ADB-11-05	Sep 1, 11	Potential for Damage to Pipeline Facilities Caused by the Passage of Hurricanes

For more PHMSA Advisory Bulletins, go to <http://phmsa.dot.gov/pipeline/regs/advisory-bulletin>

Attachment 1

Distribution Operator Compressor Station Inspection

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

		COMPRESSOR STATION PROCEDURES No compressor stations	S	U	N/A	N/C
243.	.605(b)					
244.		.605(b)(6) Maintenance procedures, including provisions for isolating units or sections of pipe and for purging before returning to service				
245.		.605(b)(7) Starting, operating, and shutdown procedures for gas compressor units				
246.		.731 Inspection and testing procedures for remote control shutdowns and pressure relieving devices (1 per yr/15 months), prompt repair or replacement				
247.		.735 (a) Storage of excess flammable or combustible materials at a safe distance from the compressor buildings				
248.		(b) Tank must be protected according to NFPA #30				
249.		.736 Compressor buildings in a compressor station must have fixed gas detection and alarm systems (must be performance tested), unless:				
250.		• 50% of the upright side areas are permanently open, or				
251.		• It is an unattended field compressor station of 1000 hp or less				

Comments:

			COMPRESSOR STATION O&M PERFORMANCE AND RECORDS	S	U	N/A	N/C
252.	.709	.731(a) Compressor Station Relief Devices (1 per yr/15 months)					
253.		.731(c) Compressor Station Emergency Shutdown (1 per yr/15 months)					
254.		.736(c) Compressor Stations – Detection and Alarms (Performance Test)					

Comments:

			COMPRESSOR STATIONS INSPECTION (Field)	S	U	N/A	N/C
			(Note: Facilities may be “Grandfathered”)				
255.	.163	(c)	Main operating floor must have (at least) two (2) separate and unobstructed exits				
256.			Door latch must open from inside without a key				
257.			Doors must swing outward				
258.		(d)	Each fence around a compressor station must have (at least) 2 gates or other facilities for emergency exit				
259.			Each gate located within 200 ft of any compressor plant building must open outward				
260.			When occupied, the door must be opened from the inside without a key				
261.		(e)	Does the equipment and wiring within compressor stations conform to the National Electric Code, ANSI/NFPA 70?				
262.	.165	(a)	If applicable, are there liquid separator(s) on the intake to the compressors?				
263.		(b)	Do the liquid separators have a manual means of removing liquids?				
264.			If slugs of liquid could be carried into the compressors, are there automatic dumps on the separators, Automatic compressor shutdown devices, or high liquid level alarms?				
265.	.167	(a)	ESD system must:				

Attachment 1

Distribution Operator Compressor Station Inspection

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

COMPRESSOR STATIONS INSPECTION (Field)			S	U	N/A	N/C
(Note: Facilities may be “Grandfathered”)						
266.		- Discharge blowdown gas to a safe location				
267.		- Block and blow down the gas in the station				
268.		- Shut down gas compressing equipment, gas fires, electrical facilities in compressor building and near gas headers				
269.		- Maintain necessary electrical circuits for emergency lighting and circuits needed to protect equipment from damage				
270.		ESD system must be operable from at least two locations, each of which is:				
271.	.167	- Outside the gas area of the station				
272.		- Not more than 500 feet from the limits of the station				
273.		- ESD switches near emergency exits?				
274.	(b)	For stations supplying gas directly to distribution systems, is the ESD system configured so that the LDC will not be shut down if the ESD is activated?				
275.	(c)	Are ESDs on platforms designed to actuate automatically by...				
276.		- For unattended compressor stations, when:				
277.		▪ The gas pressure equals MAOP plus 15%?				
278.		▪ An uncontrolled fire occurs on the platform?				
279.		- For compressor station in a building, when				
280.		▪ An uncontrolled fire occurs in the building?				
281.		▪ Gas in air reaches 50% or more of LEL in a building with a source of ignition (facility conforming to NEC Class 1, Group D is not a source of ignition)?				
282.	.171	(a) Does the compressor station have adequate fire protection facilities? If fire pumps are used, they must not be affected by the ESD system.				
283.		(b) Do the compressor station prime movers (other than electrical movers) have over-speed shutdown?				
284.		(c) Do the compressor units alarm or shutdown in the event of inadequate cooling or lubrication of the unit(s)?				
285.		(d) Are the gas compressor units equipped to automatically stop fuel flow and vent the engine if the engine is stopped for any reason?				
286.		(e) Are the mufflers equipped with vents to vent any trapped gas?				
287.	.173	Is each compressor station building adequately ventilated?				
288.	.457	Is all buried piping cathodically protected?				
289.	.481	Atmospheric corrosion of aboveground facilities				
290.	.603	Does the operator have procedures for the start-up and shut-down of the station and/or compressor units?				
291.		Are facility maps current/up-to-date?				
292.	.615	Emergency Plan for the station on site?				
293.	.619	Review pressure recording charts and/or SCADA				
294.	.707	Markers				
295.	.731	Overpressure protection – relief’s or shutdowns				
296.	.735	Are combustible materials in quantities exceeding normal daily usage, stored a safe distance from the compressor building?				
297.		Is aboveground oil or gasoline storage tanks protected in accordance with NFPA standard No. 30?				
298.	.736	Gas detection – location				

Comments:

Attachment 1

Distribution Operator Compressor Station Inspection

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Comments: