FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

NOTES-FIELD INSPECTION

Company: **Akzo Nobel** **Date(s):** **September 15, 2015**

Unit: **Moses Lake**

Field Readings									
Line & Location	**Line**		**CP Volts**		**Rectifier**		**Pressures**		**Remarks**
	Size	**In.**	**P/S**	**Casing**	**Volts**	**Amps**	**Set**	**Actual**	
Leak Survey									Lind used a unit that had current calibration and was suitable for Hydrogen service.
Marker Patrol									The markers were in good overall condition.
Valve Inspection									They were flowing top Simplot and due to the valve design the operator did not want to close the valve and cause a potential system upset in Simplot's boilers.