

FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

NOTES-FIELD INSPECTION

Company: Cascade Nat Gas Corporation
Unit: Bremerton

Date(s): March 5, 2015

Field Readings									
Line & Location	Line		CP Volts		Rectifier		Pressures		Remarks
	Size	In.	P/S	Casing	Volts	Amps	Set	Actual	
303 N. N. Montgomery Ave, Bremerton	3/4"		-1.552v						
308A Callow Ave N, Bremerton	1"		-1.631v						
Rectifier GB04			-7.69v		26.05v	N/C			
Rectifier GB09			-5.270v		25.65v	N/C			
District Regulator R-73 Silverdale							35 psig	35 psig	Left at 30 psig
							30 psig	31 psig	Left at 35 psig
Relief at above							41 psig	44 psig	Left at 41 psig
District Regulator Poulsbo							53 psig	54 psig	Left at 58 psig
							58 psig	58 psig	Left at 53 psig
Relief at above							63 psig	64 psig	Left at 63 psig
Odorant test site Silverdale end point at Keyport Naval Station									Readily detectable at .15%