

FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

Thrall Rd & #6 Rd									
Cove Rd Bridge Xing			-1543						Galvanic
GA-039285 TS-074991 Cove Rd & Cedar Cove Rd			-1117 on -923 off						
IC-037673 PS-0333 1701 - Hwy 970			-1363 (on)		2.5 VDC	340mA			Output set at 6% 50mV/10A shunt
IC-037673 TS-044284 1111 BROWN ROAD			-1093 on -977 off						
TS-076874 840 #81 RD			-1590						Galvanic
RS-2548 Gate Station E HWY & N FERGUSON RD								737 inlet 373 interstage outlet to HPZ-0031 139.5	Gate Vantage Hwy and Williams
RS-2549 District Regulator Station E HWY & N FERGUSON RD							90 interstage SP LU Run 2 Monitor SP 62	139 psig inlet 89.6 interstage LU as found 55 flowing downstream Run 2 Monitor 62.8 as found	
RS-2560 District Regulator							LU SP 57	LU as found 57.9	HPZ-0031 Flowing at 136.0 upstream

