FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

NOTES-FIELD INSPECTION

Company: Swissport Fueling, Inc. **Date(s):** 9/12/17-9/13/17

Unit: Swissport **Insp. No.** 7257

Field Readings									
Line & Location	**Line**		**CP Volts**		**Rectifier**		**Pressures**		**Remarks**
	Size	**In.**	**P/S**	**Casing**	**Volts**	**Amps**	**Set**	**Actual**	
Tank 115 Rectifier					30.54VDC	.008 A			22.4 mV on a 50mV 25A shunt 11.2A coming from the shunt. Taps set at C3 F2
Permanent Cell 1			-1.416V						
Permanent Cell 2			-2.576V						
Operated Relief Valve on T-115									Operation good
Tested Overfill Alarm									Tested good