

FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

NOTES-FIELD INSPECTION

Company: Cascade Natural Gas Corp
9/27/2019

Date(s): 9/24/2019-

Unit: Yakima

Insp. No.: 7809

Field Readings									
Line & Location	Line		CP Volts (mV CSE)		Rectifier		Pressures (psig)		Remarks
	Size	In.	P/S	Casing	Volts	Amps	Set	Actual	
R-36 2 nd Run			-1080				Inlet MAOP 250 Outlet MAOP 60 LU 29 Relief 38	Inlet 229 LU 29.3 Outlet 31 Relief 36.5	OQ checked Greg Olney EVL 1434 Bypass and EVL 702 Reg limiting exp 1/25/2022 CP EVL 512 exp 7/13/21 Gauge 0-1000 psig #7552103083 and Gauge 0-100 #7552102083 exp 4-22-2020 Half cell was checked as well.
R-29 2 nd Run							Inlet MAOP 250 Outlet MAOP 60 LU 28 Relief 37	Inlet 229 LU 29.3 Outlet 31.2 Relief 36.6	
Rectifier GB-09 Wernex			-2104		3.096 VAC 5.54 VDC	6.6A			Greg Olney OQ EVL 505 checked for power sources. Taps F5 C1
1315 W Goodlander Rd									SY1001 Odorometer exp 9/9/20 Odorant .55 readily

FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

									detectable
R-01 2 nd Run			-1262				Inlet MAOP 200 Outlet MAOP 60 LU 53.3 Relief 63	Inlet 180 LU 53.3 Outlet 53.1 Relief 62.5	
R-38 2 nd Run							Inlet MAOP 250 Outlet MAOP 60 LU 53.8 Relief 62	Inlet 210 LU 53.8 Relief 61.7	
Casing @ Beaudry and Hwy 24				-738					RR Xing
Casing @ Beaudry Hwy 24				-675					Hwy 24
R-12 2 nd Run							Inlet MAOP 250 Outlet MAOP 60 LU 54 Relief 62	Inlet 201 LU 54 Outlet 54.14 Relief 61.1 Relief full blow 64	

