FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

NOTES-FIELD INSPECTION

Company: Cardinal FG **Date(s): March 12, 2019**

Unit: Winlock WA **Insp. No.: 7818**

Field Readings									
Line & Location	**Line**		**CP Volts dc**		**Rectifier**		**Pressures**		**Remarks**
	Size	**In.**	**P/S**	**Casing**	**Volts**	**Amps**	**Set**	**Actual**	
Cardinal FG Winlock WA	6-inch								Leak Test on pipeline inside of fenced Cardinal site at Williams Compressor Station. No leaks found. Instrument Heath DPIR S/N 9101446001 Self calibration
Cardinal FG Winlock WA	6-inch		-1.298 V						Just outside of Cardinal site. Halfcell good till 2/12/2020 Multimeter good till 10/12/19
Insulating Joint at Williams Station	6-inch								Williams side -1.237 V Cardinal side -1.445 V
Cardinal FG Winlock WA	6-inch								Exercise Outlet valve on Regulator Run B. OK
Cardinal FG Following pipeline after crossing under I5.			-1.485 V						CP Test Point #12 On the road behind the plant.
Cardinal FG Odorometer readings on NON-Jurisdictional side.									Odorometer readings taken at the end of pipeline on the NON-Jurisdictional Side of Cardinal Input Odorometer calibration OK Just detectable 0.33 (0.28) Readily detectable 0.61 (0.51) -