

FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

Tumwater Odor Check Fred Meyer 555 Trosper									
Olympia Bridge Patrol-5 th Ave Bridge									Hold down hoop touching top of pipe-6" line
Olympia Bridge Patrol-Capitol Way Bridge at I-5									Pipe hangers are using steel conduit as tie off for pipe support.
Olympia Odor Check Crown Cork Fones Rd									0.49 0.42
July 7, 2020 Cathodic Protection									
Reg station 2657 Winlock HS			-1497 -1036						
PS 0399 Yardbirds Chehalis			-1504 -897		5.62 vdc	2.88			14.4 mv SF 7.2amps Taps 15%
PS 0239 Winlock HS Winlock			-1526 -1063		1.11	0.48			4.8 mv SF 0.1 0.48 amps Taps 2%
PS 212 Tanglewilde Lacey			-1997 -970		8.08	0.264			6.6mv SF 0.2 0.264 amps Taps 17%
PS 231 Garth at Capitol Way Tumwater			-1678 -850		46.41	2.34			23.4 mv SF 0.1 2.34 amps Taps 44%
9027 Littlerock Rd			-1042 -869						
Maple at UP/BNRR casing Centralia			-1115 -919	-731 -624					
E 2 nd @ E St Bond Centralia			-2004 -1029						
Tullis at Yew St 803 Tullis, Olympia			-1195 -869						

FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

Tullis at San Francisco 1347 Tullis			-1181 -869						
22 nd Ave at Woodland Trail Lacey			-1065 -870	-418					
3530 6 th St SE Olympia			-1459 -1012						
4503 Monclair Ct			=1149 -857						
4912 Chambers Lake DR Lacey			-1301 -1031						
8327 Hartman Ct Lacey			-1305 -931						
July 8 Pressure Control									
RS 2826 Drewes Prairie									Run 1 Set 57 Found 56.75 Run 2 set 57 found 56.8 Relief Set 62 found 62 MAOP 60 Williams 138.75 March 11, 2020 last insp
RS 2815 Karabe Ln Chehalis Farm Tap									Run 1 set 32 found 31.66 Run 2 set 32 found 31.1 Inlet 271.4
RS 0246 Hickory St Centralia									Run 1 set 47 found 46.15 Run 2 set 47 found 47.05 Relief set 52 found 52 Last insp 10/2/2019
RS 6149 W Olympia Gate Olympia									Run 1 set 247 found 246 Run 2 set 247 found 246 Relief set 252 found 251
RS 1643 Overhulse Rd Olympia									Set 28 found 28.5 Reset to 27.95 Inlet 235.8

FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

RS 2622 Steilicoom and Dutterow Lacey									Run 1 set 52 found 51.6 Run 2 set 52 found 52 Relief set 57 found 58.5 Reset to 57
RS 2827 North St Olympia									This station is new, replaced RS 244 and 462 Run 1 set 52 found 51.3 Run 2 no lock Cleaned pilot orifice Set 52 Relief Set 57 found 57 Inlet 235.8
RS 2747 Bald Hills Rd Yelm									Inlet 260 Last insp 6/14/20 Run 1 stage 1 set 155 found 155 Run 1 stage 2 set 57 found 57.1 Run 2 stage 1 set 155 no lock Cleaned diaphragm Set 155 Run 2 stage 2 set 57 found 57.2 set to 56.95