

Inspection Results (IRR)

Generated on 2020.October.15 07:52

- PSE W King (140)

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Qst #	Question ID	References	Question Text
1.	PSE W King	Sat		PRR.REPORT	1.	RPT.RR.IMMEDREPORT.R	191.5(a) (191.7(a), 191.7(d))	Do records indicate immediate notifications of incidents were made in accordance with 191.5?
2.	PSE W King	Sat	(2)	PRR.REPORT	2.	GDIM.RR.MECHANICALFITTINGDATAIMPL.R	192.1009 (191.12)	Have accurate records been maintained documenting mechanical fitting failures that resulted in hazardous leaks?
3.	PSE W King	Sat		PRR.REPORT	3.	RPT.RR.INCIDENTREPORT.R	191.9(a)	Do records indicate reportable incidents were identified and reports were submitted to DOT on Form 7100.2 (01-2002) within the required timeframe?
4.	PSE W King	Sat		PRR.REPORT	4.	RPT.RR.INCIDENTREPORTSUPP.R	191.9(b)	Do records indicate accurate supplemental incident reports were filed and within the required timeframe?
5.	PSE W King	Sat		PRR.REPORT	5.	RPT.RR.ANNUALREPORT.R	191.11(a)	Have complete and accurate Annual Reports been submitted?
6.	PSE W King	NA		PRR.REPORT	6.	RPT.RR.SRCR.R	191.23(a) (191.23(b), 191.25(a), 191.25(b))	Do records indicate safety-related condition reports were filed as required?
7.	PSE W King	Sat		PRR.REPORT	7.	MO.GO.CUSTNOTIFY.R	192.16(d) (192.16(a), 192.16(b), 192.16(c))	Do records indicate the customer notification

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Question #	Question ID	References	Question Text
								process satisfies the requirements of 192.16?
8.	PSE W King	NA		PRR.REPORT	8.	RPT.RR.MAOPINCREASENOTIFY.R		Do records indicate submittal of a written plan of procedures to the commission at least forty-five days before upgrading to a MAOP greater than 60 psig?
9.	PSE W King	Sat		PRR.REPORT	9.	RPT.RR.DAILYCONSTRUCTIONRPT.R		Do records indicate daily construction and repair activities were emailed to the commission no later than 10 AM each day work is scheduled?
10.	PSE W King	Sat		PRR.CORROSION	1.	TQ.QU.CORROSION.R	192.453 (192.807(a), 192.807(b))	Do records indicate qualification of personnel implementing pipeline corrosion control methods?
11.	PSE W King	Sat		PRR.CORROSION	2.	TD.CP.ELECISOLATE.R	192.491(c) (192.467(a), 192.467(b), 192.467(c), 192.467(d), 192.467(e))	Do records adequately document electrical isolation of each buried or submerged pipeline from other metallic structures unless they electrically interconnect and cathodically protect the pipeline and the other structures as a single unit?
12.	PSE W King	Sat		PRR.CORROSION	3.	TD.CP.RECORDS.R	192.491(a)	Do records indicate the location of all items listed in 192.491(a)?
13.	PSE W King	Sat		PRR.CORROSION	4.	TD.CPEXPOSED.EXPOSEINSPECT.R	192.491(c) (192.459)	Do records adequately document that exposed buried piping was

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Qst #	Question ID	References	Question Text
								examined for corrosion?
14.	PSE W King	Sat		PRR.CORROSION	5.	TD.CPMONITOR.CURRENTTEST.R	192.491(c) (192.465(b))	Do records document details of electrical checks of sources of rectifiers or other impressed current sources?
15.	PSE W King	Sat		PRR.CORROSION	6.	TD.CPMONITOR.TEST.R	192.491(c) (192.465(a))	Do records adequately document cathodic protection monitoring tests have occurred as required?
16.	PSE W King	NA		PRR.CORROSION	7.	TD.CPMONITOR.REVCURRENTTEST.R	192.491(c) (192.465(c))	Do records document details of electrical checks interference bonds, diodes, and reverse current switches?
17.	PSE W King	Sat		PRR.CORROSION	8.	TD.CPMONITOR.DEFICIENCY.R	192.491(c) (192.465(d))	Do records adequately document actions taken to correct any identified deficiencies in corrosion control?
18.	PSE W King	NA		PRR.CORROSION	9.	TD.CP.UNPROTECT.R	192.491(c) (192.465(e))	Do records adequately document that exposed buried piping was examined for corrosion and deteriorated coating?
19.	PSE W King	Sat		PRR.CORROSION	10.	TD.CPMONITOR.TESTSTATION.R	192.469	Do records identify the location of test stations and show a sufficient number of test stations?
20.	PSE W King	Sat		PRR.CORROSION	11.	TD.CPMONITOR.TESTLEAD.R	192.491(c) (192.471(a), 192.471(b), 192.471(c))	Do records document that pipelines with cathodic protection have electrical test leads installed in accordance with

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Question #	Question ID	References	Question Text
								requirements of Subpart I?
21.	PSE W King	NA		PRR.CORROSION	12.	TD.CPMONITOR.INTFRCURRENT.R	192.491(c) (192.473(a))	Do records document an effective program is in place to minimize detrimental effects of interference currents and that detrimental effects of interference currents from CP systems on other underground metallic structures are minimized?
22.	PSE W King	Sat		PRR.CORROSION	13.	FS.FG.CASINGTESTLEAD.R		Do records indicate that all casings without vents installed after September 5, 1992 had separate test lead wires installed?
23.	PSE W King	NA		PRR.CORROSION	14.	FS.FG.CASINGSEALS.R		Do records indicate that mains and service lines installed in casing or conduit are sealed at the ends as required?
24.	PSE W King	NA		PRR.CORROSION	15.	TD.ICP.CORRGAS.R	192.491(c) (192.475(a))	Do the records demonstrate that the corrosive effect of the gas in the pipeline has been investigated and if determined to be corrosive, steps be taken to minimize internal corrosion?
25.	PSE W King	Sat		PRR.CORROSION	16.	TD.ICP.EXAMINE.R	192.491(c) (192.475(a), 192.475(b))	Do records document examination of removed pipe for evidence of internal corrosion?

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Question #	Question ID	References	Question Text
26.	PSE W King	NA		PRR.CORROSION	17.	TD.ICP.CORRGASACTION.R	192.491(c) (192.477)	Do records document the actions taken when corrosive gas is being transported by pipeline?
27.	PSE W King	Sat		PRR.CORROSION	18.	TD.ATM.ATMCORRODEINSP.R	192.491(c) (192.481(a), 192.481(b), 192.481(c))	Do records document inspection of aboveground pipe for atmospheric corrosion?
28.	PSE W King	Sat		PRR.CORROSION	19.	TD.COAT.NEWPIPE.R	192.491(c) (192.455(a), 192.461(a), 192.461(b), 192.483(a))	Do records document that each buried or submerged pipeline installed after July 31, 1971 has been externally coated with a suitable coating material?
29.	PSE W King	NA		PRR.CORROSION	20.	TD.ICP.REPAIR.R	192.485(a) (192.485(b))	Do records document the repair or replacement of pipe that has been internally corroded to an extent that there is not sufficient remaining strength in the pipe wall?
30.	PSE W King	NA		PRR.CORROSION	21.	TD.ICP.EVALUATE.R	192.491(c) (192.485(c))	Do records document adequate evaluation of internally corroded pipe?
31.	PSE W King	Sat		PRR.PT	1.	DC.PTLOWPRESS.PRESSTEST100PSIG.R	192.517(b) (192.509(a), 192.509(b))	Do records indicate that pressure testing is conducted in accordance with 192.509(a)?
32.	PSE W King	NA		PRR.PT	2.	DC.PTLOWPRESS.PRESSTESTLOWSTRES S.R	192.517(a) (192.507(a), 192.507(b), 192.507(c))	Do records indicate that pressure testing is conducted in accordance with 192.507?
33.	PSE W King	Sat		PRR.PT	3.	DC.PT.SERVICELINE.R	192.517(b) (192.511(a), 192.511(b), 192.511(c))	Do records indicate that pressure testing is conducted in accordance with 192.511?

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Question #	Question ID	References	Question Text
34.	PSE W King	Sat		PRR.PT	4.	DC.PT.PRESSTESTPLASTIC.R	192.517(b) (192.513(a), 192.513(b), 192.513(c), 192.513(d))	Do records indicate that pressure testing is conducted in accordance with 192.513?
35.	PSE W King	NA		PRR.UPRATE	1.	MO.GOUPRATE.MAOPINCREASE.R	192.553(a) (192.553(b), 192.553(c))	Do records indicate that increases in MAOP of pipeline were determined in accordance with 192.553?
36.	PSE W King	NA		PRR.UPRATE	2.	MO.GOUPRATE.MAOPINCREASECASTDUCTILE.R	192.553(b) (192.553(c), 192.557(d))	Do records indicate that requirements were followed for increasing the MAOP for cast iron or ductile iron pipe where records are inadequate for evaluating the level of safety of the pipeline when operating at the proposed increased pressure?
37.	PSE W King	NA		PRR.UPRATE	3.	MO.GOUPRATE.MAOPINCREASELIMIT.R	192.553(b) (192.553(c), 192.553(d), 192.557(a))	Do records indicate that increases in MAOP are limited in accordance with 192.519 and 192.621?
38.	PSE W King	NA		PRR.UPRATE	4.	MO.GOUPRATE.MAOPINCREASEPREP.R	192.553(b) (192.553(c), 192.553(a), 192.557(b), 192.557(c))	Do records indicate that increases in MAOP were preceded by the actions specified in 192.557?
39.	PSE W King	Sat	(2)	PRR.OM	1.	EP.ERG.LIAISON.R	192.605(a) (192.615(c)(1), 192.615(c)(2), 192.615(c)(3), 192.615(c)(4), 192.616(c), ADB-05-03)	Do records indicate liaisons established and maintained with appropriate fire, police and other public officials and utility owners in accordance with procedures?
40.	PSE W King	Sat		PRR.OM	2.	MO.GO.OMANNUALREVIEW.R	192.605(a)	Has the operator conducted annual reviews of the written procedures or

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Qst #	Question ID	References	Question Text
								processes in the manual as required?
41.	PSE W King	Sat		PRR.OM	3.	MO.RW.MARKERREPLACE.R		Do records indicate that damaged or missing markers were replaced within forty-five days of discovery?
42.	PSE W King	Sat	(2)	PRR.OM	4.	PD.PA.EVALEFFECTIVENESS.R	192.616(c) (API RP 1162 Section 8.4)	Have effectiveness evaluation(s) of the program been performed for all stakeholder groups in all notification areas along all systems covered by the program?
43.	PSE W King	NA	(2)	PRR.OM	5.	PD.PA.LANGUAGE.R	192.616(g) (API RP 1162 Section 2.3.1)	Were materials and messages developed and delivered in other languages commonly understood by a significant number and concentration of non-English speaking populations in the operator's areas?
44.	PSE W King	NA	(2)	PRR.OM	6.	PD.PA.MSTRMETER.R	192.616(j) (192.616(h), API RP 1162 Section 2.7 (Step 12), API RP 1162 Section 8.5)	Do records indicate the public awareness program for a master meter or petroleum gas system operator has met the requirements of Part 192?
45.	PSE W King	Sat		PRR.OM	7.	MO.GO.OMHISTORY.R	192.605(a) (192.605(b)(3))	Are construction records, maps and operating history available to appropriate operating personnel?
46.	PSE W King	Sat		PRR.OM	8.	MO.GO.OMEFFECTREVIEW.R	192.605(a) (192.605(b)(8))	Do records indicate periodic review of the work done by operator personnel to determine the

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Qs t #	Question ID	References	Question Text
								effectiveness, and adequacy of the processes used in normal operations and maintenance and modifying the processes when deficiencies are found?
47.	PSE W King	Sat		PRR.OM	9.	MO.RW.DISTPATROL.R	192.603(b) (192.721(a), 192.721(b))	Do records indicate distribution patrolling was conducted as required?
48.	PSE W King	Sat		PRR.OM	10.	MO.RW.DISTPATROLLEAKAGE.R	192.603(b) (192.723(a), 192.723(b))	Do records indicate distribution leakage surveys were conducted as required?
49.	PSE W King	Sat		PRR.OM	11.	MO.RW.MARKERSMAPSDRAW.R		Are records sufficient to indicate class location and other areas where pipeline markers are required?
50.	PSE W King	Sat		PRR.OM	12.	MO.RW.MARKERSURVEY.R		Do records indicate that pipeline marker surveys were completed and completed in the timeframe specified by WAC 480-93-124?
51.	PSE W King	NA		PRR.OM	13.	MO.RW.TRANSLEAKAGE.R	192.709(c) (192.706, 192.706(a), 192.706(b))	Do records indicate transmission leakage surveys conducted as required?
52.	PSE W King	NA		PRR.OM	14.	MO.RW.TRANSPATROL.R	192.709(c) (192.705(a), 192.705(b), 192.705(c))	Do records indicate that transmission line ROW surface conditions have been patrolled as required?
53.	PSE W King	NA		PRR.OM	15.	MO.GOABNORMAL.ABNORMALREVIEW.R	192.605(a) (192.605(c)(4))	Do records indicate periodic review of work done by operator personnel to determine the effectiveness of the abnormal

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Question #	Question ID	References	Question Text
								operation processes and corrective action taken where deficiencies are found?
54.	PSE W King	Sat		PRR.OM	16.	PD.OC.PDPROGRAM.R	192.614(c)	Does the damage prevention program meet minimum requirements specified in 192.614(c)?
55.	PSE W King	NA		PRR.OM	17.	MO.GOCLASS.CLASSLOCATESTUDY.R	192.605(b)(1) (192.609(a), 192.609(b), 192.609(c), 192.609(d), 192.609(e), 192.609(f))	Do records indicate performance of the required study whenever the population along a pipeline increased or there was an indication that the pipe hoop stress was not commensurate with the present class location?
56.	PSE W King	Sat		PRR.OM	18.	EP.ERG.POSTEVTREVIEW.R	192.605(a) (192.615(b)(1), 192.615(b)(3))	Do records indicate review of employee activities to determine whether the procedures were effectively followed in each emergency?
57.	PSE W King	Sat		PRR.OM	19.	EP.ERG.TRAINING.R	192.605(a) (192.615(b)(2))	Has the operator trained the appropriate operating personnel on emergency procedures and verified that the training was effective in accordance with its procedures?
58.	PSE W King	Sat		PRR.OM	20.	EP.ERG.INCIDENTANALYSIS.R	192.605(a) (192.617)	Do records indicate actions initiated to analyze accidents and failures, including the collection of appropriate samples for laboratory examination to determine the

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Question #	Question ID	References	Question Text
								causes of the failure and minimize the possibility of recurrence, in accordance with its procedures?
59.	PSE W King	Sat		PRR.OM	21.	MO.GOMAOP.MAOPDETERMINE.R	192.619(a), (1192.619(b), 192.621(a), 192.621(b), 192.623(a), 192.623(b))	Do records indicate determination of the MAOP of pipeline segments in accordance with 192.619 and limiting of the operating pressure as required?
60.	PSE W King	Sat		PRR.OM	22.	MO.GOODOR.ODORIZE.R	192.709(c), (192.625(a), 192.625(b), 192.625(c), 192.625(d), 192.625(e), 192.625(f))	Do records indicate appropriate odorization of its combustible gases in accordance with its processes and conduct of the required testing to verify odorant levels met requirements?
61.	PSE W King	NA		PRR.OM	23.	AR.RMP.TESTREINSTATE.R	192.603(b), (192.725(a), 192.725(b))	From the review of records, did the operator properly test disconnected service lines?
62.	PSE W King	NA		PRR.OM	24.	MO.GM.MOVEANDLOWER.R		Do records indicate that a study was prepared before moving or lowering a steel gas pipeline as required?
63.	PSE W King	NA		PRR.OM	25.	MO.GM.MOVEANDLOWERSURVEY.R		Do records indicate that a leak survey was conducted not more than thirty days after moving and/or lowering a metallic pipeline?
64.	PSE W King	Sat		PRR.OM	26.	MO.GM.ABANDONPIPE.R	192.709(c), (192.727(a), 192.727(b), 192.727(c), 192.727(d), 192.727(e),	Do records indicate pipelines and facilities were abandoned or deactivated in

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Qs t #	Question ID	References	Question Text
							192.727(f), 192.727(g))	accordance with requirements?
65.	PSE W King	Sat		PRR.OM	27.	MO.GMOPP.PRESSREGTEST.R	192.709(c) (192.739(a), 192.739(b))	Do records indicate inspection and testing of pressure limiting, relief devices, and pressure regulating stations as required and at the specified intervals?
66.	PSE W King	Sat		PRR.OM	28.	MO.GMOPP.PRESSREGCAP.R	192.709(c) (192.743(a), 192.743(b), 192.743(c))	Do records indicate testing or review of the capacity of each pressure relief device at each pressure limiting station and pressure regulating station as required and a new or additional device installed if determined to have insufficient capacity?
67.	PSE W King	Sat		PRR.OM	29.	MO.GM.DISTVALVEINSPECT.R	192.603(b) (192.747(a), 192.747(b))	Do records indicate proper inspection and partial operation of each distribution system valve that might be required in an emergency at intervals not exceeding 15 months, but at least once each calendar year, and prompt remedial action to correct any valve found inoperable?
68.	PSE W King	NA		PRR.OM	30.	FS.FG.VAULTINSPECTFAC.R	192.709(c) (192.749(a), 192.749(b), 192.749(c), 192.749(d))	Do records document inspections at the required interval of all vaults having a volumetric internal content of 200 cubic feet (5.66 cubic meters) or more that house

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Question #	Question ID	References	Question Text
								pressure regulating/limiting equipment?
69.	PSE W King	Sat		PRR.OM	31.	MO.GM.IGNITION.R	192.709 (192.751(a), 192.751(b), 192.751(c))	Do records indicate personnel followed processes for minimizing the danger of accidental ignition where the presence of gas constituted a hazard of fire or explosion?
70.	PSE W King	NA		PRR.OM	32.	MO.GM.BELLSPIGOTJOINT.R	192.603(b) (192.753(a), 192.753(b))	Do records indicate that caulked bell and spigot joints were correctly sealed?
71.	PSE W King	Sat		PRR.OM	33.	DC.WELDPROCEDURE.WELD.R	192.225(a) (192.225(b))	Do records indicate weld procedures are being qualified in accordance with 192.225?
72.	PSE W King	Sat		PRR.OM	34.	TQ.QUOMCONST.WELDER.R	192.227(a) (192.227(b), 192.229(a), 192.229(b), 192.229(c), 192.229(d), 192.328(a), 192.328(b), 192.807(a), 192.807(b))	Do records indicate adequate qualification of welders?
73.	PSE W King	Sat		PRR.OM	35.	TQ.QUOMCONST.NDT.R	192.243(b)(2) (192.807(a), 192.807(b), 192.328(a), 192.328(b))	Do records indicate the qualification of nondestructive testing personnel?
74.	PSE W King	Sat		PRR.OM	36.	DC.CO.PLASTICJOINTPROCEDURE.R	192.273(b) (192.283(a), 192.283(b), 192.283(c), 192.283(d))	Have plastic pipe joining procedures been qualified in accordance with 192.283?
75.	PSE W King	Sat		PRR.OM	37.	DC.CO.PLASTICJOINTQUAL.R	192.285(d) (192.285(a), 192.285(b), 192.285(c), 192.807(a), 192.807(b))	Do records indicate persons making joints in plastic pipelines are qualified in accordance with 192.285?
76.	PSE W King	Sat		PRR.OM	38.	DC.CO.PLASTICJOINTINSP.R	192.287 (192.807(a), 192.807(b))	Do records indicate persons inspecting the making of plastic pipe

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Qs t #	Question ID	References	Question Text
								joints have been qualified?
77.	PSE W King	Sat		PRR.OM	39.	DC.CO.PLASTICPIPESEP.R		Do records indicate minimum separation requirements are met for plastic pipelines?
78.	PSE W King	Sat		PRR.OM	40.	DC.METERREGSVC.REGTEST.R		Do records indicate that service regulators have been installed, operated, maintained, tested during initial turn-on and tested when customers experience pressure problems?
79.	PSE W King	Sat		PRR.OM	41.	MO.RW.LEAKFOLLOW.R		Do records indicate that a follow-up inspection was performed not more than thirty days following a repair where residual gas remained in the ground?
80.	PSE W King	Sat		PRR.OM	42.	MO.RW.DOWNGRADELEAKREPAIR.R		Do records indicate that leaks that have been downgraded are repaired within twenty-one months?
81.	PSE W King	Sat		PRR.OM	43.	MO.RW.LEAKREPAIRTIME.R		Do records indicate that leaks were repaired and re-evaluated in the timeframes specified in WAC 480-93-18601?
82.	PSE W King	Sat		PRR.OM	44.	MO.RW.LEAKRECORDS.R		Have gas leak records been prepared and maintained as required?
83.	PSE W King	Unsat		PRR.OM	45.	MO.GM.RECORDS.R	192.605(b)(1) (192.243(f), 192.709(a), 192.709(b), 192.709(c))	Do records indicate that records are maintained of each pipe/"other than pipe" repair,

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Question #	Question ID	References	Question Text
								NDT required record, and (as required by subparts L or M) patrol, survey, inspection or test?
84.	PSE W King	NA		FR.FIELDPIPE	1.	DC.MA.MARKING.O	192.63(a) (192.63(b), 192.63(c), 192.63(d))	Are pipe, valves, and fittings properly marked for identification?
85.	PSE W King	Sat		FR.FIELDPIPE	2.	DC.DPC.GDVALVEPLACEMENT.O	192.141 (192.181(a), 192.181(b), 192.181(c))	Are distribution line valves being installed as required of 192.181?
86.	PSE W King	Sat		FR.FIELDPIPE	3.	DC.METERREGSVC.CUSTOMETERREGLOC.O	192.351 (192.353(a), 192.353(b), 192.353(c), 192.353(d))	Are meters and service regulators being located consistent with the requirements of 192.353?
87.	PSE W King	Sat		FR.FIELDPIPE	4.	DC.METERREGSVC.CUSTOMETERREGPROT.O	192.351 (192.355(a), 192.355(b), 192.355(c))	Are meters and service regulators being protected from damage consistent with the requirements of 192.355?
88.	PSE W King	Sat	(2)	FR.FIELDPIPE	5.	MO.RW.ROWMARKER.O	192.707(a) (192.707(b), 192.707(d), CGA Best Practices, v4.0, Practice 2-5, CGA Best Practices, v4.0, Practice 4-20)	Are line markers placed and maintained as required?
89.	PSE W King	NA	(2)	FR.FIELDPIPE	6.	MO.RW.ROWMARKERABOVE.O	192.707(c) (CGA Best Practices, v4.0, Practice 2-5, CGA Best Practices, v4.0, Practice 4-20)	Are line markers placed and maintained as required for above ground pipelines?
90.	PSE W King	NA		FR.FIELDPIPE	7.	DC.METERREGSVC.CUSTOMETERREGINSTALL.O	192.351 (192.357(a), 192.357(b), 192.357(c), 192.357(d))	Are meters and service regulators being installed consistent with the requirements of 192.357?

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Question #	Question ID	References	Question Text
91.	PSE W King	NA		FR.FIELDPIPE	8.	DC.METERREGSVC.CUSTOMETEROPPRESS.O	192.351 (192.359(a), 192.359(b), 192.359(c))	Are customer meter operating pressures consistent with the requirements of 192.359?
92.	PSE W King	NA		FR.FIELDPIPE	9.	DC.METERREGSVC.SVCLINEINSTALL.O	192.351 (192.361(a), 192.361(b), 192.361(c), 192.361(d), 192.361(e), 192.361(f), 192.361(g))	Are customer service lines being installed consistent with the requirements of 192.361?
93.	PSE W King	NA		FR.FIELDPIPE	10.	DC.METERREGSVC.SVCLINEVLVLOCATEREQT.O	192.351 (192.363(a), 192.363(b), 192.363(c), 192.365(a), 192.365(b), 192.365(c))	Are customer service line valves being installed meeting the valve and locations requirements of 192.363 and 192.365?
94.	PSE W King	NA		FR.FIELDPIPE	11.	DC.METERREGSVC.SVCLINECONNECT.O	192.351 (192.367(a), 192.367(b), 192.369(a), 192.369(b))	Are customer service lines being installed with connections meeting the requirements of 192.367 and 192.369?
95.	PSE W King	NA		FR.FIELDPIPE	12.	DC.METERREGSVC.SVCLINEMATERIAL.O	192.351 (192.371, 192.373(a), 192.373(b), 192.373(c), 192.375(a), 192.375(b), 192.377)	Are customer service lines being installed constructed appropriately for the types of materials used?
96.	PSE W King	NA		FR.FIELDPIPE	13.	DC.METERREGSVC.NEWSVCLINENOTUSED.O	192.351 (192.379, 192.379(a), 192.379(b), 192.379(c))	Are new customer service lines not in use configured in accordance with the requirements of 192.379?
97.	PSE W King	NA		FR.FIELDPIPE	14.	DC.METERREGSVC.EXCSFLOWVLVLOCATE.O	192.351 (192.381(c), 192.381(d), 192.381(e))	Are service line excess flow valves located and identified in accordance with the requirements of 192.381?
98.	PSE W King	NA		FR.FIELDPIPE	15.	DC.METERREGSVC.REGTEST.O		Are service regulators operated, maintained, installed and

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Question #	Question ID	References	Question Text
								tested during the initial turn-on in accordance with manufacturer's recommendations and WAC requirements?
99.	PSE W King	NA		FR.FIELDPIPE	16.	TD.COAT.NEWPIPEINSTALL.O	192.461(d)	Is external protective coating being protected from damage that could result from adverse ditch conditions or supporting blocks?
100	PSE W King	Sat		FR.FIELDPIPE	17.	TD.CPMONITOR.MONITORCRITERIA.O	192.465(a) (192.463(b), 192.463(c))	Are methods used for taking CP monitoring readings that allow for the application of appropriate CP monitoring criteria?
101	PSE W King	Sat		FR.FIELDPIPE	18.	TD.CPMONITOR.CURRENTTEST.O	192.465(b)	Are impressed current sources properly maintained and are they functioning properly?
102	PSE W King	Sat		FR.FIELDPIPE	19.	TD.CP.ELECISOLATE.O	192.467(a) (192.467(b), 192.467(c), 192.467(d), 192.467(e))	Are measures performed to ensure electrical isolation of each buried or submerged pipeline from other metallic structures unless they electrically interconnect and cathodically protect the pipeline and the other structures as a single unit?
103	PSE W King	Sat		FR.FIELDPIPE	20.	TD.CPMONITOR.TESTSTATION.O	192.469	Do cathodically protected pipelines have a sufficient number of test stations?
104	PSE W King	Sat		FR.FIELDPIPE	21.	TD.CPMONITOR.TESTLEAD.O	192.471(a)	Do pipelines with cathodic protection have electrical test leads installed in accordance

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Qs t #	Question ID	References	Question Text
								with requirements of Subpart I?
105	PSE W King	Sat		FR.FIELDPIPE	22.	FS.FG.CASING.O		Are all casings bare steel and do they have test leads installed on new casings without vents?
106	PSE W King	NA		FR.FIELDPIPE	23.	FS.FG.CASESEAL.O		Does the operator seal both ends of casings/conduits for mains and transmission lines and seal the end nearest the building for service lines?
107	PSE W King	NA		FR.FIELDPIPE	24.	TD.CP.MONITOR.INTFRCURRENT.O	192.473(a)	Are areas of potential stray current identified, and if found, the detrimental effects of stray currents minimized?
108	PSE W King	Concern		FR.FIELDPIPE	25.	TD.CP.ADJACENTMETAL.O	192.473(b)	Are impressed current type cathodic protection systems and galvanic anode systems installed so as to minimize any adverse effect on existing adjacent underground metallic structures?
109	PSE W King	NA		FR.FIELDPIPE	26.	TD.ICP.CORRGASPRVNT.O	192.475(a)	If the transportation of corrosive gas is not allowed, is the transportation of corrosive gas prevented?
110	PSE W King	NA		FR.FIELDPIPE	27.	TD.ICP.CORRGASACTION.O	192.477	Are adequate actions taken when corrosive gas is being transported by pipeline?
111	PSE W King	NA		FR.FIELDPIPE	28.	TD.ICP.PIPEBOTTLE.O	192.475(c)	Is gas containing more than 0.25 grain of hydrogen sulfide per 100 standard cubic

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Qs t #	Question ID	References	Question Text
								feet (5.8 milligrams/m3) at standard conditions (4 parts per million) being stored in pipe-type or bottle-type holders?
112	PSE W King	Sat	(2)	FR.FIELDPIPE	29.	TD.ATM.ATMCORRODEINSP.O	192.481(b) (192.481(c), 192.479(a), 192.479(b), 192.479(c))	Is pipe that is exposed to atmospheric corrosion protected?
113	PSE W King	NA		FR.FIELDPIPE	30.	AR.RCOM.REMEDIATIONOM.O	192.487(a) (192.487(b))	Is anomaly remediation and documentation of remediation adequate for all segments?
114	PSE W King	NA		FR.FIELDPIPE	31.	TD.CP.GRAPHITIZE.O	192.489(a) (192.489(b))	Has there been adequate remediation for the graphitization of cast iron or ductile iron pipe?
115	PSE W King	Sat		FR.FIELDPIPE	32.	MO.GOODOR.ODORIZE.O	192.625(a) (192.625(c), 192.625(d), 192.625(e), 192.625(f))	Is sampling of combustible gases adequate using an instrument capable of determining the percentage of gas in air at which it becomes readily detectable?
116	PSE W King	NA		FR.FIELDPIPE	33.	MO.GO.PURGE.O	192.629(a) (192.629(b))	Are lines being purged in accordance with 192.629?
117	PSE W King	Sat		FR.FIELDPIPE	34.	MO.GMOPP.PRESSREGTEST.O	192.739(a) (192.739(b))	Are field or bench tests or inspections of regulating stations, pressure limiting stations or relief devices adequate?
118	PSE W King	Sat		FR.FIELDPIPE	35.	MO.GMOPP.PRESSREGMETER.O	192.741(a) (192.741(b), 192.741(c))	Are telemetering or recording gauges properly utilized as required for distribution systems?
119	PSE W King	Sat		FR.FIELDPIPE	36.	MO.GMOPP.MULTIPRESSREG.O		Are regulator stations

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Question #	Question ID	References	Question Text
								installed in a manner to provide protection between regulator stages?
120	PSE W King	Sat		FR.FIELDPIPE	37.	MO.GM.DISTVALVEINSPECT.O	192.747(a) (192.747(b))	Is proper inspection and partial operation being performed for each distribution system valve that might be required in an emergency, and prompt remedial action to correct any valves found inoperable?
121	PSE W King	NA		FR.FIELDPIPE	38.	MO.GM.VAULTINSPECT.O	192.749(a) (192.749(b)), 192.749(c), 192.749(d)	Are vault inspections adequate?
122	PSE W King	NA		FR.FIELDPIPE	39.	AR.RMP.IGNITION.O	192.751(a) (192.751(b)), 192.751(c))	Perform observations of selected locations to verify that adequate steps have been taken by the operator to minimize the potential for accidental ignition.
123	PSE W King	NA		FR.FIELDPIPE	40.	MO.GM.BELLSPIGOTJOINT.O	192.753(a) (192.753(b))	Do records indicate that caulked bell and spigot joints were correctly sealed?
124	PSE W King	NA		FR.FIELDPIPE	41.	MO.GM.CASTIRONPROTECT.O	192.755(a) (192.755(b))	Is adequate protection in place for segments of a buried cast-iron pipeline for which support has been disturbed?
125	PSE W King	NA		FR.FIELDPIPE	42.	AR.PTI.PLASTICPRESSURETEST.O		Is plastic pipe installed and backfilled prior to pressure testing?
126	PSE W King	Sat		FR.FIELDPIPE	43.	AR.PTI.EQUIPCALIB.O		Is pressure testing equipment calibrated

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Question #	Question ID	References	Question Text
								according to calibration schedules and procedures?
127	PSE W King	NA		FR.FIELDPIPE	44.	DC.CO.PLASTICPIPEPROC.O		Is plastic pipe handled, stored and installed in accordance with manufacturer's recommendations, including maximum ultraviolet exposure?
128	PSE W King	NA		FR.FIELDPIPE	45.	DC.CO.PLASTICWEAKLINK.O		Is a weak link installed when pulling plastic pipe by mechanical means?
129	PSE W King	NA		FR.FIELDPIPE	46.	DC.CO.PLASTICPIPESEP.O		Are plastic pipelines installed with the minimum separation from other utilities as required?
130	PSE W King	NA		FR.FIELDPIPE	47.	DC.CO.PLASTICBACKFILL.O		Is plastic pipe buried in essentially rock-free material or material recommended by the pipe manufacturer?
131	PSE W King	NA		FR.FIELDPIPE	48.	DC.CO.PLASTICSQUEEZING.O		Is the number of times plastic pipe can be squeezed and how far from fittings plastic pipe can be squeezed limited?
132	PSE W King	Sat		FR.FIELDPIPE	49.	MO.GM.ONSITEPROCS.O		Are procedures applicable to the work being done located onsite where the work is being done?
133	PSE W King	Sat	(2)	ATT1FR.FIELDPCS	5.	MO.RW.ROWMARKER.O	192.707(a) 192.707(b), 192.707(d), CGA Best Practices, v4.0, Practice 2-5, CGA Best Practices, v4.0, Practice 4-20)	Are line markers placed and maintained as required?

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Qst #	Question ID	References	Question Text
134	PSE W King	NA	(2)	ATT1FR.FIELDSCS	6.	MO.RW.ROWMARKERABOVE.O	192.707(c) (CGA Best Practices, v4.0, Practice 2-5, CGA Best Practices, v4.0, Practice 4-20)	Are line markers placed and maintained as required for above ground pipelines?
135	PSE W King	Sat	(2)	ATT1FR.FIELDSCS	22.	TD.ATM.ATMCORRODEINSP.O	192.481(b) (192.481(c), 192.479(a), 192.479(b), 192.479(c))	Is pipe that is exposed to atmospheric corrosion protected?
136	PSE W King	Sat	(2)	GDIM.IMPL	43.	GDIM.RR.MECHANICALFITTINGDATAIMPL.R	192.1009 (191.12)	Have accurate records been maintained documenting mechanical fitting failures that resulted in hazardous leaks?
137	PSE W King	Sat	(2)	MISCTOPICS.PUBAW ARE	21.	EP.ERG.LIAISON.R	192.605(a) (192.615(c)(1), 192.615(c)(2), 192.615(c)(3), 192.615(c)(4), 192.616(c), ADB-05-03)	Do records indicate liaisons established and maintained with appropriate fire, police and other public officials and utility owners in accordance with procedures?
138	PSE W King	Sat	(2)	MISCTOPICS.PUBAW ARE	22.	PD.PA.EVALEFFECTIVENESS.R	192.616(c) (API RP 1162 Section 8.4)	Have effectiveness evaluation(s) of the program been performed for all stakeholder groups in all notification areas along all systems covered by the program?
139	PSE W King	NA	(2)	MISCTOPICS.PUBAW ARE	23.	PD.PA.LANGUAGE.R	192.616(g) (API RP 1162 Section 2.3.1)	Were materials and messages developed and delivered in other languages commonly understood by a significant number and concentration of non-English speaking populations in the operator's areas?
140	PSE W King	NA	(2)	MISCTOPICS.PUBAW ARE	25.	PD.PA.MSTRMETER.R	192.616(j) (192.616(h),	Do records indicate the

Inspection Results Report (ALL Non-Empty Results) - Scp_PK PSE W King

Row	Assets	Result	(Note 1)	Sub-Group	Qs t #	Question ID	References	Question Text
							API RP 1162 Section 2.7 (Step 12), API RP 1162 Section 8.5)	public awareness program for a master meter or petroleum gas system operator has met the requirements of Part 192?

1. Result is repeated (N) times in this report due to re-presentation of the question in multiple sub-groups.

Report Parameters: All non-empty Results

Except as required to be disclosed by law, any inspection documentation, including completed protocol forms, summary reports, executive summary reports, and enforcement documentation are for internal use only by federal or state pipeline safety regulators. Some inspection documentation may contain information which the operator considers to be confidential. In addition, supplemental inspection guidance and related documents in the file library are also for internal use only by federal or state pipeline safety regulators (with the exception of documents published in the federal register, such as advisory bulletins). Do not distribute or otherwise disclose such material outside of the state or federal pipeline regulatory organizations. Requests for such information from other government organizations (including, but not limited to, NTSB, GAO, IG, or Congressional Staff) should be referred to PHMSA Headquarters Management.