

Inspection Results (IRR)

Generated on 2020.June.05 14:49

- NWN DIMP 8058 (85)

Inspection Results Report (ALL Results) - Scp_PK NWN DIMP 8058

| Row | Assets | Result | Note (1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------|--------|----------|------------|------------|-------------------------------------|-------------------|--|
| 1. | NWN DIMP 8058 | Sat | (2) | PRR.REPORT | 5. | GDIM.RR.MECHANICALFITTINGDATAIMPL.R | 192.1009 (191.12) | Have accurate records been maintained documenting mechanical fitting failures that resulted in hazardous leaks? |
| 2. | NWN DIMP 8058 | Sat | | GDIM.IM | 2. | GDIM.RA.SOURCES.P | 192.1007(a) (1) | Do the procedures identify or reference the appropriate sources used to determine certain characteristics (e.g., Design, Operating Conditions, Operating Environmental Factors) necessary to assess the threats and risks to the pipeline? |
| 3. | NWN DIMP 8058 | Sat | | GDIM.KN | 1. | GDIM.RA.GAPS.P | 192.1007(a) (3) | Does the plan contain procedures to identify additional information that is needed to fill gaps due to missing, inaccurate, or incomplete records? |
| 4. | NWN DIMP 8058 | Sat | | GDIM.KN | 2. | GDIM.RA.INFORMATION.P | 192.1007(a) (2) | Do the procedures require the consideration of information gained from past design, operations, and maintenance (e.g. O&M activities, field surveys, One-Call system information, excavation damage, etc.)? |
| 5. | NWN DIMP 8058 | Sat | | GDIM.KN | 3. | GDIM.RA.INFONEEDS.P | 192.1007(a) (3) | Do the procedures specify the means to collect the additional information needed to fill gaps due to missing, inaccurate, or incomplete records (e.g., O&M activities, field surveys, One-Call System, etc.)? |
| 6. | NWN DIMP 8058 | Sat | | GDIM.KN | 4. | GDIM.RA.INFONEEDS.R | 192.1007(a) (3) | Does the plan list the additional information needed to fill gaps due to missing, inaccurate, or incomplete records? |
| 7. | NWN DIMP 8058 | Sat | | GDIM.KN | 5. | GDIM.RA.NEWPIPEDATA.P | 192.1007(a) (5) | Do the procedures require the capture and retention of data on any new pipeline installed? |
| 8. | NWN DIMP 8058 | Sat | | GDIM.KN | 6. | GDIM.RA.NEWPIPEDATA.R | 192.1007(a) (5) | Does the data required for capture and retention include, at a minimum, the location where the new pipeline is installed and the material from which it is constructed? |
| 9. | NWN DIMP 8058 | Sat | | GDIM.KN | 7. | GDIM.RA.DEMOKNOWLEDGE.R | 192.1007(a) | Do records demonstrate implementation of the element "Knowledge of the System"? |
| 10. | NWN DIMP 8058 | Sat | | GDIM.KN | 8. | GDIM.RA.DEMOUNDERSTANDING.R | 192.1007(a) | Has the operator demonstrated an adequate understanding of the system? |
| 11. | NWN DIMP 8058 | Sat | | GDIM.TH | 1. | GDIM.RA.THREATCATEGORIES.P | 192.1007(b) | In identifying threats, do the procedures include consideration of all of the required threat |

Inspection Results Report (ALL Results) - Scp_PK NWN DIMP 8058

| Row | Assets | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------|--------|----------|-----------|------------|-----------------------------|-------------|---|
| | | | | | | | | categories to each gas distribution pipeline? |
| 12. | NWN DIMP 8058 | Sat | | GDIM.TH | 2. | GDIM.RA.INFOCONSIDERED.P | 192.1007(b) | Did the operator consider the information that was reasonably available to identify existing and potential threats? |
| 13. | NWN DIMP 8058 | Sat | | GDIM.TH | 3. | GDIM.RA.INFOCONSIDERED.R | 192.1007(b) | In identifying threats did the information considered include all of the required data and information sources? |
| 14. | NWN DIMP 8058 | Sat | | GDIM.TH | 4. | GDIM.RA.OUTSIDESOURCES.P | 192.1007(b) | Do the procedures consider, in addition to the operator's own information, data from external sources (e.g. trade associations, government agencies, or other system operators, etc.) to assist in identifying potential threats? |
| 15. | NWN DIMP 8058 | Sat | | GDIM.TH | 5. | GDIM.RA.IMPLEMENTTH.R | 192.1007(b) | Do records demonstrate implementation of the element "Identify Threats"? |
| 16. | NWN DIMP 8058 | Sat | | GDIM.RR | 1. | GDIM.RA.RISKRANKING.P | 192.1007(c) | Do the procedures contain the method(s) used to determine the relative importance of each threat and estimate and rank the risks posed? |
| 17. | NWN DIMP 8058 | Sat | | GDIM.RR | 2. | GDIM.RA.THREATSCONSIDERED.P | 192.1007(c) | Do the procedures to evaluate and rank risk consider each applicable current and potential threat? |
| 18. | NWN DIMP 8058 | Sat | | GDIM.RR | 3. | GDIM.RA.LIKELIHOOD.P | 192.1007(c) | Do the procedures to evaluate and rank risk consider the likelihood of failure associated with each threat? |
| 19. | NWN DIMP 8058 | Sat | | GDIM.RR | 4. | GDIM.RA.CONSEQUENCE.P | 192.1007(c) | Do the procedures to evaluate and rank risk consider the potential consequence of failure for all applicable threats? |
| 20. | NWN DIMP 8058 | NA | | GDIM.RR | 5. | GDIM.RA.SUBDIVIDE.R | 192.1007(c) | If subdivision of system occurs, does the plan subdivide the system into regions with similar characteristics and for which similar actions are likely to be effective in reducing risk? |
| 21. | NWN DIMP 8058 | Sat | | GDIM.RR | 6. | GDIM.RA.RESULTS.R | 192.1007(c) | Are the results of the risk ranking supported by the risk evaluation model/method? |
| 22. | NWN DIMP 8058 | Sat | | GDIM.RR | 7. | GDIM.RA.RESULTSVALIDATION.R | 192.1007(c) | Did the operator validate the results generated by the risk evaluation model/method? |
| 23. | NWN DIMP 8058 | Sat | | GDIM.RR | 8. | GDIM.RA.IMPLEMENRR.R | 192.1007(c) | Do records demonstrate implementation of the element "Evaluate and Rank Risk"? |
| 24. | NWN DIMP 8058 | Sat | | GDIM.PM | 1. | GDIM.PM.IDENTIFYMEASURES.P | 192.1007(d) | Does the plan include procedures to identify when measures, beyond minimum code requirements specified outside of Part 192 Subpart P, are required to reduce risk? |
| 25. | NWN DIMP 8058 | Sat | | GDIM.PM | 2. | GDIM.PM.IDENTIFYMEASURES.R | 192.1007(d) | When measures, beyond minimum code requirements specified outside of Part 192 |

Inspection Results Report (ALL Results) - Scp_PK NWN DIMP 8058

| Row | Assets | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------|--------|----------|-----------|------------|--------------------------------|-------------|--|
| | | | | | | | | Subpart P, are required to reduce risk, does the plan identify the measures selected, how they will be implemented, and the risks they are addressing? |
| 26. | NWN DIMP 8058 | Sat | | GDIM.PM | 3. | GDIM.PM.LEAKMANAGEMENT.P | 192.1007(d) | Does the plan include an effective leak management program (unless all leaks are repaired when found)? |
| 27. | NWN DIMP 8058 | Sat | | GDIM.PM | 4. | GDIM.PM.IMPLEMENTPM.R | 192.1007(d) | Do records demonstrate implementation of the measures, required by Part 192 Subpart P, to reduce risk? |
| 28. | NWN DIMP 8058 | Sat | | GDIM.EV | 1. | GDIM.QA.PERFMEASUREBASELINE.P | 192.1007(e) | Does the plan contain procedures for how the operator established a baseline for each performance measure? |
| 29. | NWN DIMP 8058 | Sat | | GDIM.EV | 2. | GDIM.QA.PERFMEASUREBASELINE.R | 192.1007(e) | Does the plan establish a baseline for each performance measure? |
| 30. | NWN DIMP 8058 | Sat | | GDIM.EV | 3. | GDIM.QA.PERFMEASUREDATA.P | 192.1007(e) | Does the operator have procedures to collect the data for each performance measure? |
| 31. | NWN DIMP 8058 | Sat | | GDIM.EV | 4. | GDIM.QA.PERFMEASUREMONITOR.P | 192.1007(e) | Do the procedures require the operator to monitor each performance measure? |
| 32. | NWN DIMP 8058 | Sat | | GDIM.EV | 5. | GDIM.QA.MEASUREEFFECTIVENESS.P | 192.1007(e) | When measures are required to reduce risk, do the procedures provide how their effectiveness will be measured? |
| 33. | NWN DIMP 8058 | Sat | | GDIM.EV | 6. | GDIM.QA.IMPLEMENTEV.R | 192.1007(e) | Do records demonstrate implementation of the element "Measure Performance, Monitor Results, and Evaluate Effectiveness"? |
| 34. | NWN DIMP 8058 | Sat | | GDIM.PE | 1. | GDIM.CA.PERIODICEVAL.P | 192.1007(f) | Do the procedures for periodic evaluation include all of the requirements of 192.1007(f)? |
| 35. | NWN DIMP 8058 | Sat | | GDIM.PE | 2. | GDIM.CA.PERIODICEVAL.R | 192.1007(f) | Do records demonstrate implementation of the element "Periodic Evaluation and Improvement"? |
| 36. | NWN DIMP 8058 | Sat | | GDIM.RP | 1. | GDIM.RR.ANNUALREPORT.P | 192.1007(g) | Does the plan contain or reference procedures for reporting, on an annual basis, the four measures listed in 192.1007(e)(1)(i) through (e)(1)(iv) to PHMSA as part of the annual report required by 191.11 and the State regulatory authority? |
| 37. | NWN DIMP 8058 | Sat | | GDIM.RP | 2. | GDIM.RR.SUBMITREPORTS.R | 192.1007(g) | Has the operator submitted the required reports? |
| 38. | NWN DIMP 8058 | Sat | | GDIM.MF | 1. | GDIM.RR.MECHANICALFITTING.P | 192.1009 | Are there procedures to collect information necessary to comply with the reporting requirements of 192.1009? |
| 39. | NWN DIMP 8058 | Sat | | GDIM.RC | 1. | GDIM.QA.RECORDREQUIREMENTS.P | 192.1011 | Are there procedures specifying which records demonstrating compliance with Subpart P will be maintained for at least 10 years? |
| 40. | NWN DIMP 8058 | Sat | | GDIM.RC | 2. | GDIM.QA.PLANRETENTION.P | 192.1011 | Are there procedures specifying that copies of superseded |

Inspection Results Report (ALL Results) - Scp_PK NWN DIMP 8058

| Row | Assets | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------|--------|----------|-----------|------------|---------------------------------|----------------|---|
| | | | | | | | | integrity management plans will be maintained for at least 10 years? |
| 41. | NWN DIMP 8058 | Sat | | GDIM.RC | 3. | GDIM.QA.RECORDREQUIREMENTS.R | 192.1011 | Has the operator maintained the required records? |
| 42. | NWN DIMP 8058 | NA | | GDIM.IMPL | 1. | GDIM.QA.ISSUESIMPL.R | 192.1005 | Have all issues raised in previous DIMP inspections been satisfactorily addressed? |
| 43. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 2. | GDIM.RA.GAPSIMPL.R | 192.1007(a)(3) | Is missing or incomplete system information and data needed to fill knowledge gaps to assess existing and potential threats being collected? |
| 44. | NWN DIMP 8058 | NA | | GDIM.IMPL | 3. | GDIM.RA.OUTSIDESOURCESIMPL.R | 192.1007(b) | Has the operator identified information or data from external sources (e.g. trade associations, operator's consultants, government agencies, other operators, manufacturers, etc.) that may require re-evaluation of threats and risks? |
| 45. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 4. | GDIM.RA.SYSINFONEEDSIMPL.R | 192.1007(a)(3) | Is missing or incomplete system information and data using the procedures prescribed in the DIMP plan being collected? |
| 46. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 5. | GDIM.RA.OMINFONEEDSIMPL.R | 192.1007(a)(3) | Has any new or missing information identified or acquired during normal operations, maintenance, and inspection activities been incorporated into the DIMP plan? |
| 47. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 6. | GDIM.RA.NEWPIPEIMPL.R | 192.1007(a)(5) | Have required data on any new pipeline installations since August 2, 2011 been captured (e.g., location, wall thickness/SDR, manufacturer, lot/production number)? |
| 48. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 7. | GDIM.RA.DATAFORMIMPL.R | 192.1007(a) | Are data collection forms used in conjunction with the operator's DIMP plan being fully and accurately completed? |
| 49. | NWN DIMP 8058 | NA | | GDIM.IMPL | 8. | GDIM.RA.SMEIMPL.R | 192.1007(a) | If new Subject Matter Experts (SMEs) input is incorporated into the DIMP plan, do SMEs have the necessary knowledge and/or experience (skills sets) regarding the areas of expertise for which the SME provided knowledge or supplemental information for input into the DIMP plan? |
| 50. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 9. | GDIM.RA.DEMOUNDERSTANDINGIMPL.O | 192.1007(a) | Do operator personnel in the field understand their responsibilities under the DIMP plan? |
| 51. | NWN DIMP 8058 | NA | | GDIM.IMPL | 10. | GDIM.RA.THREATCATEGORIESIMPL.R | 192.1007(b) | Has the operator acquired any new information relevant to system knowledge that may affect its threat identification? |
| 52. | NWN DIMP 8058 | NA | | GDIM.IMPL | 11. | GDIM.RA.INFOCONSIDEREDIMPL.R | 192.1007(b) | Have any changes occurred that require re-evaluation of threats and risks? |

Inspection Results Report (ALL Results) - Scp_PK NWN DIMP 8058

| Row | Assets | Result | (Notes) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------|--------|---------|-----------|------------|-------------------------------------|-------------|--|
| 53. | NWN DIMP 8058 | NA | | GDIM.IMPL | 12 | GDIM.RA.IMPLEMENTTHUPDATEIMPL.R | 192.1007(c) | Since the last DIMP plan review by the regulatory agency, has the threat identification and risk assessment been updated based on newly acquired information or data relevant to system knowledge? |
| 54. | NWN DIMP 8058 | NA | | GDIM.IMPL | 13 | GDIM.RA.IMPLEMENTTHUPDATEPLANIMPL.R | 192.1007(c) | If the threat identification and risk evaluation and ranking have been modified, were the revisions made in accordance with the procedure in the DIMP plan? |
| 55. | NWN DIMP 8058 | NA | | GDIM.IMPL | 14 | GDIM.RA.SUBDIVIDEADEQIMPL.R | 192.1007(c) | Does the current subdivision process (grouping of materials, geographic areas, etc.) adequately meet the need to properly evaluate and rank the existing and potential threats to the integrity of the system? |
| 56. | NWN DIMP 8058 | NA | | GDIM.IMPL | 15 | GDIM.RA.SUBDIVIDEUPDATEIMPL.R | 192.1007(c) | Have the system subdivisions within the risk evaluation and ranking been added to or modified since the last plan review by the regulatory agency? |
| 57. | NWN DIMP 8058 | NA | | GDIM.IMPL | 16 | GDIM.RA.SUBDIVIDEDIMPIMPL.R | 192.1007(c) | If system subdivisions have been added or modified, was it done in accordance with the procedures described in the DIMP plan? |
| 58. | NWN DIMP 8058 | NA | | GDIM.IMPL | 17 | GDIM.RA.SUBDIVIDERESULTIMPL.R | 192.1007(c) | If system subdivisions have been added or modified, did the new system subdivision result in modifications to the risk evaluation and ranking? |
| 59. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 18 | GDIM.PM.IMPLEMENTPMIMPL.R | 192.1007(d) | Does documentation reviewed demonstrate that measures to reduce risks per the DIMP plan are being implemented? |
| 60. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 19 | GDIM.PM.IMPLEMENTPMCOMPLETEIMPL.R | 192.1007(d) | Have any measures to reduce risks resulting in the elimination/mitigation of the associated identified threat been completed (e.g., pipe replacement program completed, etc.)? |
| 61. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 20 | GDIM.PM.IMPLEMENTPMREEVALIMPL.R | 192.1007(d) | If answering "Satisfactory/Yes" to previous question implementation question GDIM.PM.IMPLEMENTPMCOMPLETEIMPL.R, have risks (192.1007(c)) been re-evaluated and ranked because of the elimination/mitigation of an identified threat to ensure that risk reduction measures in place are appropriate? |
| 62. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 21 | GDIM.PM.IMPLEMENTPMSPECIFRISKIMPL.R | 192.1007(d) | Does each implemented risk reduction measure identified in the DIMP plan address a specific risk? |
| 63. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 22 | GDIM.PM.LEAKMANAGEMENTIMPL.R | 192.1007(d) | Can the operator provide documentation to demonstrate that an effective leak management program is being |

Inspection Results Report (ALL Results) - Scp_PK NWN DIMP 8058

| Row | Assets | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------|--------|----------|-----------|------------|-------------------------------------|------------------------------|---|
| | | | | | | | | implemented (answer "N/A" if all leaks are repaired when found)? |
| 64. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 23 | GDIM.QA.IMPLEMENTEVDATAIMPL.R | 192.1007(e) | Is data being collected for the required performance measures in 192.1007(e)? |
| 65. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 24 | GDIM.QA.IMPLEMENTEVDATADIMPL.R | 192.1007(e) | Based on field observations and/or record reviews, is the data used to measure performance being accurately collected in accordance with the procedures in its DIMP plan? |
| 66. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 25 | GDIM.QA.IMPLEMENTEVBASELINEIMPL.R | 192.1007(e) | Is each performance measure being monitored from an established baseline? |
| 67. | NWN DIMP 8058 | NA | | GDIM.IMPL | 26 | GDIM.QA.IMPLEMENTEVRISKIMPL.R | 192.1007(e) | Is each performance measure added since the DIMP plan was last updated tied to a specific risk reduction measure or group of measures? |
| 68. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 27 | GDIM.CA.PERIODICEVALFREQIMPL.R | 192.1007(f) | Have periodic evaluations of the DIMP plan been performed on the frequency specified in the plan? [If a periodic evaluation has not been required since plan implementation or the last inspection, mark questions 27-32 as "N/A".] |
| 69. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 28 | GDIM.CA.PERIODICEVALREQTSIMPL.R | 192.1007(f) | Did the periodic evaluation include all required elements? |
| 70. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 29 | GDIM.CA.PERIODICEVALHIRISKIMPL.R | 192.1007(f) (192.1007(e)) | If any established performance measures indicated an increase in risk beyond an acceptable level (as established in the DIMP plan), were new risk reduction measures implemented along with their associated performance measures? |
| 71. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 30 | GDIM.CA.PERIODICEVALRISKREDIMPL.R | 192.1007(f) | If the periodic evaluation indicates that implemented measures to reduce risks are NOT effective, were risk reduction measures modified, deleted or added? |
| 72. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 31 | GDIM.CA.PERIODICEVALPRFMESIMPL.R | 192.1007(f) | Did the periodic evaluation indicate that the selected performance measures are assessing the effectiveness of risk reduction measures, and, if not, were performance measures modified, deleted or added? |
| 73. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 32 | GDIM.CA.PERIODICEVALDIMPIMPL.R | 192.1007(f) | Were procedures followed in conducting periodic evaluations and program improvements? |
| 74. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 33 | GDIM.RR.SUBMITREPORTSIMPL.R | 192.1007(g) | Were Parts C and D of the PHMSA Distribution Annual Report (Form 7100.1-1) completed in the submission to PHMSA and the state regulatory authority having jurisdiction, if required, for each year since the last inspection? |
| 75. | NWN DIMP 8058 | Sat | (2) | GDIM.IMPL | 34 | GDIM.RR.MECHANICALFITTINGDATAIMPL.R | 192.1009 (191.12) | Have accurate records been maintained documenting |

Inspection Results Report (ALL Results) - Scp_PK NWN DIMP 8058

| Row | Assets | Result | (Note 1) | Sub-Group | Question # | Question ID | References | Question Text |
|-----|---------------|--------|----------|-----------|------------|--------------------------------------|-------------------|---|
| | | | | | | | | mechanical fitting failures that resulted in hazardous leaks? |
| 76. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 35 | GDIM.RR.MECHANICALFITTINGRPTIMPL.R | 192.1009 (191.12) | Did the operator report all mechanical fitting failures that resulted in a hazardous leak for the previous calendar year to PHMSA and State authorities, as appropriate, by March 15th of the next calendar year, and did the reports contain the information required by Department of Transportation Form PHMSA F-7100.1-2? |
| 77. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 36 | GDIM.RR.MECHANICALFITTINGDIMPI.MPL.O | 192.1009 (191.12) | Were procedure(s) followed for collecting the appropriate information and submitting PHMSA Form F-7100.1-2? |
| 78. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 37 | GDIM.QA.RECORDREQUIREMENTSIMPL.R | 192.1011 | Are records retained demonstrating compliance with Subpart P, as specified in its DIMP plan, for 10 years (or since 08/02/2011)? |
| 79. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 38 | GDIM.QA.RECORDREQTSRETAINIMPL.R | 192.1011 | Were copies of superseded DIMP plans retained for 10 years (or since 08/02/2011)? |
| 80. | NWN DIMP 8058 | Sat | | GDIM.IMPL | 39 | GDIM.QA.RECORDREQTSDIMPIMPL.R | 192.1011 | Were DIMP procedures followed as applicable to records retention? |
| 81. | NWN DIMP 8058 | NA | | GDIM.IMPL | 40 | GDIM.PI.PERIODICINSPDEVAPPRVIMPL.R | 192.1013(c) | Has approval been received from PHMSA or the appropriate State Regulatory Authority for alternate (less strict than code) periodic inspection intervals? [If no, mark questions 40-44 "N/A".] |
| 82. | NWN DIMP 8058 | NA | | GDIM.IMPL | 41 | GDIM.PI.PERIODICINSPDEVPERFRMIMPL.R | 192.1013(c) | Have the periodic inspections been conducted at the specified alternate intervals? |
| 83. | NWN DIMP 8058 | NA | | GDIM.IMPL | 42 | GDIM.PI.PERIODICINSPDEVREQTIMPL.R | 192.1013(c) | Have all conditions been complied with that were required as part of the alternate inspection interval approval? |
| 84. | NWN DIMP 8058 | NA | | GDIM.IMPL | 43 | GDIM.PI.PERIODICINSPDEVPRFMESIMPL.R | 192.1013(c) | Do performance measure records indicate that an equal or greater overall level of safety has been achieved since the alternate inspection frequency was implemented? |
| 85. | NWN DIMP 8058 | NA | | GDIM.IMPL | 44 | GDIM.PI.PERIODICINSPDEVACTIONIMPL.R | 192.1013(c) | If that an equal or greater overall level of safety has not been achieved, has corrective action been taken? |

1. Result is repeated (N) times in this report due to re-presentation of the question in multiple sub-groups.

Except as required to be disclosed by law, any inspection documentation, including completed protocol forms, summary reports, executive summary reports, and enforcement documentation are for internal use only by federal or state pipeline safety regulators. Some inspection documentation may contain information which the operator considers to be confidential. In addition, supplemental inspection guidance and

related documents in the file library are also for internal use only by federal or state pipeline safety regulators (with the exception of documents published in the federal register, such as advisory bulletins). Do not distribute or otherwise disclose such material outside of the state or federal pipeline regulatory organizations. Requests for such information from other government organizations (including, but not limited to, NTSB, GAO, IG, or Congressional Staff) should be referred to PHMSA Headquarters Management.